

BIB 712-13

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD

\$10.00

TYPE BUILDINGS

PERMIT NO.		LOCATION		A-1	
E-2900		2614 - San Jose Way			
DATE		PURPOSE			
Dec 19-62		Enclose porch in rear of dwlg.			
ZONE		OWNER		Same	
R-1		Ray Blackshire			
		ARCH'T		GL 7-6749	
		CONT'R American Home Service 7133-Power Inn			
VAL. \$1,000.		STORIES	ROOMS	APTS.	SIZE
					168 sq. ft.
INSP.	DATE	BLDG. TYPE	OCCUPANCY GROUP		
FORM	12-27-62	J. Barbato			
JOIST					
FRAME	1-17-63	Larsen			
SHEET ROCK					
FINAL	4-29-63	<i>[Signature]</i>	<i>[Signature]</i>		

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
12-21-62	<p>pt footing not deep enough. have midmill on job. Tell your notice to call me. Do not pour concrete. Backlot</p>
1-14-63	<p>pt 4th plans. Question about making an inside beam of running wall</p>
COMPLETE AND OK	INSPECTOR