

CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 0512925

Insp Area: 1

Thos Bros: 297B3

Site Address: 1112 2ND ST SAC

Parcel No: 006-0072-036

Sub-Type: REP

Housing (Y/N): N

CONTRACTOR
BOS SHEET METAL
3325 52ND AV
SACRAMENTO CA 95823

OWNER
HARVEGO REAL ESTATE
2356 GOLD MEADOW WY
GOLD RIVER, CA 95670

ARCHITECT

Nature of Work: C/O 2 GAS/ELECTRIC PACKAGE ROOF MOUNTED HVAC UNITS ON RESTAURANT

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class C-20 License Number 254689 Date 1/31/06 Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, **PAID** and no structure is not intended or offered for sale (Sec. 7044, Business and Professional Code. The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such work is done for the purpose of sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code. The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and herby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 8-24-05 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE COMP INS FUND Policy Number 1748379 Exp Date 07/01/2006

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 8-24-05 Applicant Signature [Signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

APPLICATION FOR COMMERCIAL BUILDING PERMIT

CITY OF SACRAMENTO
 PLANNING & BUILDING DIVISION
 PERMIT SERVICES SECTION
 (916) 808-2534 FAX: (916) 808-7046

ACTIVITY # <u>0512925</u>	Insp. Area <u>1</u>
------------------------------	------------------------

Applicant **MUST** complete ALL Unshaded Areas

ADDRESS: 1112 Second St, Old Sacramento Suite: _____

PARCEL #: _____

<p style="text-align: center;">CONTACT</p> <p>Name: <u>Mike Horrasley</u> Street Address: <u>1112 Second St</u> City/State/Zip: <u>Old Sacramento CA 95814</u> Phone: <u>442-4772</u> E-Mail: _____</p>	<p style="text-align: center;">LICENSED CONTRACTOR Lic No. # <u>254689</u></p> <p>Name: <u>Bos Sheet Metal Inc</u> Street Address: <u>3325 52nd Ave</u> City/State/Zip: <u>Sacramento CA 95823</u> Phone: <u>(916) 428-1780</u> E-Mail: <u>Mike@Bossheetmetal.com</u></p>
<p style="text-align: center;">ARCHITECT/ENGINEER</p> <p>Name: <u>Mike Presum / Bos Sheet Metal Inc</u> Street Address: <u>Same</u> City/State/Zip: _____ Phone: _____ E-Mail: _____</p>	<p style="text-align: center;">OWNER</p> <p>Name: <u>Lloyd Harvego</u> Street Address: <u>1112 Second St</u> City/State/Zip: <u>Old Sacramento CA 95814</u> Phone: <u>442-4772</u> E-Mail: _____</p>

⇒ Will permittee have any employees on the jobsite? No Yes ⇒ Insurance Co.: State Compensation Fund

⇒ WORKER'S COMPANSATION POLICY # 1748379-03 EXPROATION DATE: 7/1/06

NATURE OF WORK IN DETAIL: Change Out 1-3 ton & 1-5 ton Gas electric Package with new units (Like for Like)

OCCUPANT/TENANT: Firehouse Restaurant VALUATION: \$9,720.00

FLOOD STATUS:			S.C.A.T.							
JOB DISCRPTION	BLDG	SHELL	APT	TI()	REM()	SW	FIRE	ADD	OTH	
INSPECTION DISCIPLINES			BLDG	MECH	PLUMB	ELEC		SITE	FIRE	
# Stories	1 st Flr Area	Total Area	Use Zone	Occp Group	Const type	Fire Req. Y / N		Fed Code	Vio. [H]	File [Quad]
						SPR	ALARM			
B	L	P	M	E	F	S		D	PW	UTIL

COMMENTS: _____

REGIONAL SANITATION FEES? Yes No HEALTH DEPARTMENT: Yes No

WATER FLOW TEST FOR NEW BUILDINGS OR ADDITIONS? Provided Faxed

HEATING

BOS SHEET METAL, INC.

AIR CONDITIONING

3325 - 52nd Avenue

State Contractor's License No. 254689
Phone 428-1780

Sacramento, CA 95823

Proposal and Agreement

Customer Name Firehouse ~~Restaurant~~ Restaurant Phone _____ Date 8-18-2005

Address _____ Job Address _____

City, State, Zip Sacramento, CA Work Phone(s) _____

We will furnish, install and service the equipment listed below at the price, terms and conditions outlined on both sides of this proposal.

EQUIPMENT SPECIFICATIONS

Make Carrier Model Number(s) 1 - 48GX036 & 1 - 48GX060

SEER 12 EER _____ AFUE 80 Btuh Cooling 3 & 5 ton Btuh Heating _____ CFM _____

Installation shall include 2 Carrier packaged rooftop air conditioning units. Complete with Duct transitions, filter rack on the 5 ton unit, permit, start-up, electrical disconnect, hook up to existing electrical, hook up to existing condensate drain piping, hook up to existing gas pipe, removal of existing equipment.

X in boxes = Yes

- | | | |
|--|---|---|
| <input checked="" type="checkbox"/> New _____ Amp disconnect | <input checked="" type="checkbox"/> Remove existing equipment from premises | <input type="checkbox"/> New condensate drain system |
| <input type="checkbox"/> New _____ Amp electric service | <input type="checkbox"/> Install energy saving setback thermostat | <input type="checkbox"/> New condensate pump |
| <input type="checkbox"/> New low voltage wiring | <input type="checkbox"/> New copper wire from _____ to _____ | <input type="checkbox"/> Install aux. condensate drain pan |
| <input type="checkbox"/> New weather resistant equipment stand | <input checked="" type="checkbox"/> Make air tight plenum transition | <input type="checkbox"/> New high efficiency air filter |
| <input type="checkbox"/> New reinforced equipment pad | <input type="checkbox"/> _____ new supply diffuser(s) | <input type="checkbox"/> New humidification system |
| <input type="checkbox"/> New vibration isolation pads | <input type="checkbox"/> New duct run from _____ to _____ | <input type="checkbox"/> New return air filter grill |
| <input type="checkbox"/> New properly sized refrigerant lines | <input type="checkbox"/> Noise reducing flexible duct connector | <input checked="" type="checkbox"/> Meet all code requirements |
| <input type="checkbox"/> Refrigerant Recovery per E.P.A. Req. | <input type="checkbox"/> Balance for uniform supply air distribution | <input checked="" type="checkbox"/> Complete system start up |
| <input type="checkbox"/> Insulate refrigerant suction line(s) | <input type="checkbox"/> Provide for external combustion air | <input checked="" type="checkbox"/> <u>1</u> year parts warranty |
| <input type="checkbox"/> Install refrigerant drier(s) | <input type="checkbox"/> New gas piping from _____ to _____ | <input checked="" type="checkbox"/> <u>1</u> year labor warranty |
| <input checked="" type="checkbox"/> Charge to manufacturer's specs | <input type="checkbox"/> New vent pipe and cap | <input checked="" type="checkbox"/> <u>5</u> year compressor warranty |
| <input type="checkbox"/> Evacuate refrigerant system | <input type="checkbox"/> Clean work area to customer's satisfaction | <input type="checkbox"/> _____ year service agreement |
| <input type="checkbox"/> _____ | <input type="checkbox"/> _____ | <input checked="" type="checkbox"/> Includes all permits |

Option (below) Alternative (below) Is (Is Not) included in price

Installed Price \$ 9,720.00

Total Amount \$ 9,720.00

Down Payment \$ 0

Balance Due \$ 9,720.00

Terms Net 30 Days ~~100% NON-COMPLETION~~ - PROPOSAL EXPIRES 30 DAYS FROM DATE

Acceptance (Customer)

Approval (Company)

By _____

Date _____

By Mind D.

Date 8-18-05

Terms & Conditions On Reverse Side

CERTIFICATE OF COMPLIANCE

Part 1 of 2

MECH-1

PROJECT NAME Firehouse Restaurant	DATE 8/24/2005
PROJECT ADDRESS 1112 Second Street Old Sacramento	Building Permit #
PRINCIPAL DESIGNER - MECHANICAL Bos Sheet Metal, Inc.	Checked by/Date Enforcement Agency Use
DOCUMENTATION AUTHOR Bos Sheet Metal, Inc.	TELEPHONE (916) 428-1780
	TELEPHONE (916) 428-1780



This set of plans and specifications must be kept on the job at all times and it is unlawful to make any changes or alterations from the same without written permission from the Building Inspection Division.
The approval of this plan and specification SHALL NOT be held to permit a violation of any City Ordinance or State Law.

GENERAL INFORMATION	
DATE OF PLANS	BUILDING CONDITIONED FLOOR AREA 2,400 Sq.Ft.
	CLIMATE ZONE 12
BUILDING TYPE	<input checked="" type="checkbox"/> NONRESIDENTIAL <input type="checkbox"/> HIGH RISE RESIDENTIAL <input type="checkbox"/> HOTEL/MOTEL GUEST ROOM
PHASE OF CONSTRUCTION	<input type="checkbox"/> NEW CONSTRUCTION <input type="checkbox"/> ADDITION <input checked="" type="checkbox"/> ALTERATION <input type="checkbox"/> EXISTING + ADDITION
METHOD OF MECHANICAL COMPLIANCE	<input checked="" type="checkbox"/> PRESCRIPTIVE <input type="checkbox"/> PERFORMANCE
PROOF OF ENVELOPE COMPLIANCE	<input type="checkbox"/> PREVIOUS ENVELOPE PERMIT <input type="checkbox"/> ENVELOPE COMPLIANCE ATTACHED

STATEMENT OF COMPLIANCE
This Certificate of Compliance lists the building features and performance specifications needed to comply with Parts 1 and 6 of the California Code of Regulations. This certificate applies only to building mechanical requirements.

CITY COPY

The documentation preparer hereby certifies that the documentation is accurate and complete.

DOCUMENTATION AUTHOR Mike Pierson	SIGNATURE <i>Mike Pierson</i>	DATE 8-24-05
--------------------------------------	----------------------------------	-----------------

The Principal Mechanical Designer hereby certifies that the proposed building design represented in this set of construction documents is consistent with the other compliance forms and worksheets, with the specifications, and with any other calculations submitted with this permit application. The proposed building has been designed to meet the mechanical requirements contained in Sections 110 through 115, 120 through 124, 140 through 142, 144 and 145.

- Please check one:
- I hereby affirm that I am eligible under the provisions of Division 3 of the Business and Professions Code to sign this document as the person responsible for its preparation; and that I am licensed in the State of California as a civil engineer, or mechanical engineer or I am a licensed architect.
 - I affirm that I am eligible under the exemption to Division 3 of the Business and Professions Code by Section 5537.2 or 6737.3 to sign this document as the person responsible for its preparation; and that I am a licensed contractor performing this work.
 - I affirm that I am eligible under the exemption to Division 3 of the Business and Professions Code to sign this document because it pertains to a structure or type of work described pursuant to Business and Professions Code sections 5537, 5538, and 6737.1.

PRINCIPAL MECHANICAL DESIGNER - NAME Bos Sheet Metal, Inc.	SIGNATURE <i>Mike Pierson</i>	DATE 8-24-05	LIC. # 259689
---	----------------------------------	-----------------	------------------

MECHANICAL MANDATORY MEASURES

Indicate location on plans of Note Block for Mandatory Measures

INSTRUCTIONS TO APPLICANT

For detailed instructions on the use of this and all Energy Efficiency Standards compliance forms, please refer to the Nonresidential Manual published by the California Energy Commission.

MECH-1: Required on plans for all submittals. Parts 2 may be incorporated in schedules on plans.

MECH-2: Required for all submittals, but may be incorporated in schedules on plans.

MECH-3: Required for all submittals unless required outdoor ventilation rates are shown on plans as Section 4.3.4.

MECH-4: Required for Prescriptive submittals.

MECH-5: Optional. Performance use only for mechanical distribution summary.

EnergyPro 3.1 By EnergySoft User Number: 5412 Job Number: 107107 Date: 8-24-05 Page: 1 of 7

APPROVED
City of Sacramento Plan Review
PLUMBING/MECHANICAL

0512925 1112 2ND ST.

CERTIFICATE OF COMPLIANCE

Part 2 of 2

MECH-1

PROJECT NAME Firehouse Restaurant	DATE 8/24/2005
---	--------------------------

SYSTEM FEATURES

SYSTEM NAME	MECHANICAL SYSTEMS		NOTE TO FIELD
	AC-1	AC-2	
TIME CONTROL	Programmable Switch	Programmable Switch	
SETBACK CONTROL	Heating & Cooling Required	Heating & Cooling Required	
ISOLATION ZONES	n/a	n/a	
HEAT PUMP THERMOSTAT?	n/a	n/a	
ELECTRIC HEAT?	n/a	n/a	
FAN CONTROL	Constant Volume	Constant Volume	
VAV MINIMUM POSITION CONTROL?	No	No	
SIMULTANEOUS HEAT/COOL?	No	No	
HEATING SUPPLY RESET	Constant Temp	Constant Temp	
COOLING SUPPLY RESET	Constant Temp	Constant Temp	
HEAT REJECTION CONTROL	n/a	n/a	
VENTILATION	Air Balance	Air Balance	
OUTDOOR DAMPER CONTROL	Auto	Auto	
ECONOMIZER TYPE	No Economizer	No Economizer	
DESIGN O.A. CFM (MECH-3, COLUMN I)	450 cfm	750 cfm	
HEATING EQUIPMENT TYPE	Gas Furnace	Gas Furnace	
HEATING EQUIPMENT EFFICIENCY	80% AFUE	79% AFUE	
COOLING EQUIPMENT TYPE	Packaged DX	Packaged DX	
COOLING EQUIPMENT EFFICIENCY	12.0 SEER / 10.5 EER CARRIER 48GX03609030	12.0 SEER / 10.5 EER CARRIER 48GX06009050	
MAKE AND MODEL NUMBER			
PIPE INSULATION REQUIRED?	Yes	Yes	
PIPE/DUCT INSULATION PROTECTED?	Yes	Yes	
HEATING DUCT LOCATION	Ducts in Attic	Ducts in Attic	
R-VALUE	4.2	4.2	
COOLING DUCT LOCATION	Ducts in Attic	Ducts in Attic	
R-VALUE	4.2	4.2	
VERIFIED SEALED DUCTS IN CEILING/ROOF SPACE	No	No	

CODE TABLES: Enter code from table below into columns above.

		TIME CONTROL	SETBACK CTRL.	ISOLATION ZONES	FAN CONTROL
HEAT PUMP THERMOSTAT?	Y: Yes N: No	S: Prog. Switch	H: Heating	Enter Number of Isolation Zones.	I: Inlet Vanes P: Variable Pitch V: VFD O: Other C: Curve
ELECTRIC HEAT?		O: Occupancy Sensor	C: Cooling		
VAV MINIMUM POSITION CONTROL?		M: Manual Timer	B: Both		
SIMULTANEOUS HEAT / COOL?					
HEAT AND COOL SUPPLY RESET?					
HIGH EFFICIENCY?					
PIPE INSULATION REQUIRED?					
PIPE/DUCT INSULATION PROTECTED?					
SEALED DUCTS IN CEILING/ROOF SPACE?					

NOTES TO FIELD - For Building Department Use Only

--	--	--	--

MECHANICAL EQUIPMENT SUMMARY

Part 1 of 2

MECH-2

PROJECT NAME
Firehouse Restaurant

DATE
8/24/2005

CHILLER AND TOWER SUMMARY

Equipment Name	Equipment Type	Qty.	Efficiency	Tons	PUMPS					
					Tot. Qty	GPM	BHP	Motor Eff.	Drive Eff.	Pump Control

DHW / BOILER SUMMARY

System Name	System Type	Distribution Type	Qty	Rated Input	Vol. (Gals.)	Energy Factor or Recovery Efficiency	Standby Loss or Pilot	TANK INSUL.
								Ext. R-Val.

CENTRAL SYSTEM RATINGS

System Name	System Type	Qty.	HEATING			COOLING			Economizer Type
			Output	Aux. kW	Eff.	Output	Sensible	Efficiency	
CARRIER 48GX03609030	Packaged DX	1	70,000	0.0	80% AFUE	35,000	24,500	12.0 SEER / 10.5 EER	No Economizer
CARRIER 48GX06009050	Packaged DX	1	70,000	0.0	79% AFUE	58,500	40,950	12.0 SEER / 10.5 EER	No Economizer

CENTRAL SYSTEM FAN SUMMARY

System Name	Fan Type	Motor Location	SUPPLY FAN				RETURN FAN			
			CFM	BHP	Motor Eff.	Drive Eff.	CFM	BHP	Motor Eff.	Drive Eff.
CARRIER 48GX03609030	Constant Volume	Blow-Through	1,200	0.50	77.0%	100.0%	none			
CARRIER 48GX06009050	Constant Volume	Draw-Through	1,990	0.75	77.0%	100.0%	none			

PROJECT NAME Firehouse Restaurant	DATE 8/24/2005
--------------------------------------	-------------------

DESCRIPTION	Designer	Enforcement
Equipment and Systems Efficiencies		
<input type="checkbox"/> § 111 Any appliance for which there is a California standard established in the Appliance Efficiency Regulations will comply with the applicable standard.		
<input checked="" type="checkbox"/> § 115(a) Fan type central furnaces shall not have a pilot light.		
<input checked="" type="checkbox"/> § 123 Piping, except that conveying fluids at temperatures between 60 and 105 degrees Fahrenheit, or within HVAC equipment, shall be insulated in accordance with Standards Section 123.		
<input type="checkbox"/> § 124 Air handling duct systems shall be installed and insulated in compliance with Sections 601, 603 and 604 of the Uniform Mechanical Code.		
Controls		
§ 122(e) Each space conditioning system shall be installed with one of the following:		
<input checked="" type="checkbox"/> § 122(e)1A Each space conditioning system serving building types such as offices and manufacturing facilities (and all others not explicitly exempt from the requirements of Section 112 (d)) shall be installed with an automatic time switch with an accessible manual override that allows operation of the system during off-hours for up to 4 hours. The time switch shall be capable of programming different schedules for weekdays and weekends and have program backup capabilities that prevent the loss of the device's program and time setting for at least 10 hours if power is interrupted; or		
<input checked="" type="checkbox"/> § 122(e)1B An occupancy sensor to control the operating period of the system; or		
<input checked="" type="checkbox"/> § 122(e)1C A 4-hour timer that can be manually operated to control the operating period of the system.		
<input checked="" type="checkbox"/> § 122(e)2 Each space conditioning system shall be installed with controls that temporarily restart and temporarily operate the system as required to maintain a setback heating and/or a setup cooling thermostat setpoint.		
<input type="checkbox"/> § 122(g) Each space conditioning system serving multiple zones with a combined conditioned floor area more than 25,000 square feet shall be provided with isolation zones. Each zone: shall not exceed 25,000 square feet; shall be provided with isolation devices, such as valves or dampers, that allow the supply of heating or cooling to be setback or shut off independently of other isolation areas; and shall be controlled by a time control device as described above.		
<input checked="" type="checkbox"/> § 122(a&b) Each space conditioning system shall be controlled by an individual thermostat that responds to temperature within the zone. Where used to control heating, the control shall be adjustable down to 55 degrees F or lower. For cooling, the control shall be adjustable up to 85 degrees F or higher. Where used for both heating and cooling, the control shall be capable of providing a deadband of at least 5 degrees F within which the supply of heating and cooling is shut off or reduced to a minimum.		
<input checked="" type="checkbox"/> § 122(c) Thermostats shall have numeric setpoints in degrees Fahrenheit (F) and adjustable setpoint stops accessible only to authorized personnel.		
<input type="checkbox"/> § 112(b) Heat pumps shall be installed with controls to prevent electric resistance supplementary heater operation when the heating load can be met by the heat pump alone.		

PROJECT NAME Firehouse Restaurant	DATE 8/24/2005
--------------------------------------	-------------------

Description	Designer	Enforcement
Ventilation		
<input checked="" type="checkbox"/> § 121(e) Controls shall be provided to allow outside air dampers or devices to be operated at the ventilation rates as specified on these plans.		
<input checked="" type="checkbox"/> § 122(f) Gravity or automatic dampers interlocked and closed on fan shutdown shall be provided on the outside air intakes and discharges of all space conditioning and exhaust systems.		
<input checked="" type="checkbox"/> § 122(f) All gravity ventilating systems shall be provided with automatic or readily accessible manually operated dampers in all openings to the outside, except for combustion air openings.		
<input checked="" type="checkbox"/> § 121(f)1 Air Balancing: The system shall be balanced in accordance with the National Environmental Balancing Bureau (NEBB) Procedural Standards (1983), or Associated Air Balance Council (AABC) National Standards (1989); or		
<input checked="" type="checkbox"/> § 121(f)2 Outside Air Certification: The system shall provide the minimum outside air as shown on the mechanical drawings, and shall be measured and certified by the installing licensed C-20 mechanical contractor and certified by (1) the design mechanical engineer, (2) the installing licenced C-20 mechanical contractor, or (3) the person with overall responsibility for the design of the ventilation system; or		
<input checked="" type="checkbox"/> § 121(f)3 Outside Air Measurement: The system shall be equipped with a calibrated local or remote device capable of measuring the quantity of outside air on a continuous basis and displaying that quantity on a readily accessible display device; or		
<input checked="" type="checkbox"/> § 121(f)4 Another method approved by the Commission.		
Service Water Heating Systems		
<input type="checkbox"/> § 113(b)2 If a circulating hot water system is installed, it shall have a control capable of automatically turning off the circulating pump(s) when hot water is not required.		
<input type="checkbox"/> § 113(b)3B Lavatories in restrooms of public facilities shall be equipped with controls to limit the outlet temperature to 110 degrees F.		
<input type="checkbox"/> § 113(b)3C Lavatories in restrooms of public facilities shall be equipped with one of the following: Outlet devices that limit the flow of hot water to a maximum of 0.5 gallons per minute. Foot actuated control valves, and outlet devices that limit the flow of hot water to a maximum of 0.75 gallons per minute. Proximity sensor actuated control valves, and outlet devices that limit the flow of hot water to a maximum of 0.75 gallons per minute. Self-closing valves, and outlet devices that limit the flow of hot water to a maximum of 2.5 gallons per minute, and 0.25 gallons/cycle (circulating system). Self-closing valves, and outlet devices that limit the flow of hot water to a maximum of 2.5 gallons per minute, and 0.50 gallons/cycle (non-circulating system). Self-closing valves, and outlet devices that limit the flow of hot water to a maximum of 2.5 gallons per minute, and 0.75 gallons/cycle (foot switches and proximity sensor controls).		
EnergyPro 3.1 By EnergySoft User Number: 5412	Job Number:	Page:7 of 7




Product Data

This set of plans and specifications must be kept on the job at all times and it is unlawful to make any changes or alterations from the same without written permission from the Building Inspection Division. The approval of this plan and specification SHALL NOT be held to permit or approve the violation of any City Ordinance or State Law.

48GX/48GXN Single-Packaged Gas Heating/Electric Cooling Units


2 to 5 Nominal Tons



AC-1 - 48 GX036 - 3 TON

AC-2 - 48 GX060 - 5 TON

CITY COPY



APPROVED
City of Sacramento Plan Review
PLUMBING/MECHANICAL

107127 8/24/05
Signature Date

Single-Packaged Rooftop Products with Energy-Saving Features.

- Direct Spark Ignition
- Low Sound Levels
- Up to 81% AFUE
- 12 SEER

FEATURES/BENEFITS

One-piece heating and cooling units with low sound levels, easy installation, low maintenance, and dependable performance.

Easy Installation

Factory-assembled package is a compact, fully self-contained, combination gas heating/electric cooling unit that is pre-wired, pre-piped, and pre-charged for minimum installation expense.

These units are available in a variety of standard and optional heating/cooling size combinations with voltage options to meet residential and light commercial requirements. Units are lightweight and install easily on a rooftop or at ground level. The high tech composite unit base eliminates rust problems associated with ground level applications.

Convertible duct configuration


Unit is designed for easy use in either downflow or horizontal applications. Each unit is easily converted from horizontal to downflow with the use of the two standard duct covers.

Efficient operation

High-efficiency design with SEER (Seasonal Energy Efficiency Ratios) of 12.0 and AFUE (Annual Fuel Utilization Efficiency) ratings as high as 81%.

0512925 1112 2ND ST.

Model number nomenclature



LEGEND
AL - Aluminum
CU - Copper

ARI* capacities

COOLING CAPACITIES AND EFFICIENCIES

UNIT 48GX	NOMINAL TONS	STANDARD CFM	NET COOLING CAPACITIES (Btuh)	SEER†	SOUND RATINGS‡ (dB)
024040 024060	2	800	24,000	12.0	72
030040 030060	2-1/2	1000	30,000	12.0	72
AC-1 → 036060 036090	3	1200	35,000	12.0	74
042060 042090	3-1/2	1400	42,000	12.0	74
048090 048115 048130	4	1450	48,000	12.0	80
AC-2 → 060090 060115 060130	5	1750	58,000	12.0	78

LEGEND
Bels - Sound Levels (decibels)
db - Dry Bulb
SEER - Seasonal Energy Efficiency Ratio
wb - Wet Bulb
* Air Conditioning & Refrigeration Institute.
† Rated in accordance with U.S. Government DOE Department of Energy) test procedures and/or ARI Standard 210/240-89.
‡ Tested in accordance with ARI Standard 270-95 (not listed in ARI).

NOTES:

- Ratings are net values, reflecting the effects of circulating fan heat. Ratings are based on:
Cooling Standard: 80°F db, 67°F wb indoor entering-air temperature and 95°F db outdoor entering-air temperature.
- Before purchasing this appliance, read important energy cost and efficiency information available from your retailer.

ARI* capacities (cont)

HEATING CAPACITIES AND EFFICIENCIES

UNIT 48GX	HEATING INPUT (Btuh)	OUTPUT CAPACITY (Btuh)	TEMPERATURE RISE RANGE (°F)	AFUE (%)
024040	40,000	31,000	20-50	80.1
030040				80.1
024060	60,000	46,000	35-65	78.4
030060		46,000	35-65	78.4
AC-1 → 036060		46,000	25-55	78.7
042060		47,000	15-45	78.7
036090		70,000	45-75	79.9
042090	90,000	71,000	35-65	79.9
048090	90,000	70,000	25-55	78.6
AC-2 → 060090	90,000	70,000	25-55	78.6
048115	115,000	92,000	35-65	81.1
060115				81.1
048130	130,000	104,000	40-70	80.3
060130		103,000		80.3

LEGEND

AFUE -- Annual Fuel Utilization Efficiency

NOTE: Before purchasing this appliance, read important energy cost and efficiency information available from your retailer.



OUTDOOR SOUND: OCTAVE BAND DATA — DECIBELS

UNIT	48GX					
	024	030	036	042	048	060
Frequency (Hz)						
63	43.6	52.6	49.5	56.8	54.7	55.5
125	54.1	47.3	56.4	56.9	64.0	64.1
250	57.1	58.2	61.0	64.0	69.9	66.6
500	64.9	63.2	67.4	68.0	73.3	70.6
1000	67.6	66.1	68.1	67.7	73.5	72.6
2000	64.1	64.0	65.8	64.6	70.4	69.8
4000	59.7	61.3	64.8	61.3	66.7	67.5
8000	53.5	57.0	56.8	55.5	60.5	61.6

LEGEND

Sound Levels (decibels)

Physical data

AC-1
↓

UNIT SIZE 48GX	024040	024060	030040	030060	036060	036090	042060	042090
NOMINAL CAPACITY (ton)	2	2	2-1/2	2-1/2	3	3	3-1/2	3-1/2
OPERATING WEIGHT (lb)	290	290	313	313	321	321	382	382
COMPRESSORS Quantity	Scroll 1							
REFRIGERANT (R-22) Quantity (lb)	3.7	3.7	4.4	4.4	5.2	5.2	6.4	6.4
REFRIGERANT METERING DEVICE Orifice ID (In.)	Acutrol™ Device							
	.034	.034	.030	.030	.032	.032	.034	.034
CONDENSER COIL Rows—Fins/In. Face Area (sq ft)	1—17 10.8	1—17 10.8	1—17 12.7	1—17 12.7	2—17 9.1	2—17 9.1	2—17 12.3	2—17 12.3
CONDENSER FAN Nominal Cfm Diameter (in.) Motor Hp (Rpm)	2350 22 1/8 (825)	2350 22 1/8 (825)	2350 22 1/8 (825)	2350 22 1/8 (825)	2350 22 1/8 (1100)	2350 22 1/8 (825)	3300 22 1/4 (1100)	3300 22 1/4 (1100)
EVAPORATOR COIL Rows—Fins/In. Face Area (sq ft)	3—15 3.1	3—15 3.1	3—15 3.7	3—15 3.7	3—15 3.7	3—15 3.7	3—15 4.7	3—15 4.7
EVAPORATOR BLOWER Nominal Airflow (Cfm) Size (in.) Motor Hp (RPM)	800 10 x 10 1/4 (1075)	800 10 x 10 1/4 (1075)	1000 10 x 10 1/4 (1075)	1000 10 x 10 1/4 (1075)	1200 11 x 10 1/2 (1075)	1200 11 x 10 1/2 (1075)	1400 11 x 10 3/4 (1075)	1400 11 x 10 3/4 (1075)
FURNACE SECTION* Burner Orifice No. (Qty—Drill Size) Natural Gas Burner Orifice No. (Qty—Drill Size) Liquid Propane	2—44 2—50	2—38 2—46	2—44 2—50	2—38 2—46	2—38 2—46	3—38 3—46	2—38 2—46	3—38 3—46
RETURN-AIR FILTERS (in.)† Throwaway	20 x 20 x 1	20 x 20 x 1	20 x 20 x 1	20 x 20 x 1	20 x 24 x 1	20 x 24 x 1	24 x 30 x 1	24 x 30 x 1

AC-2
↓

UNIT SIZE 48GX	048090	048115	048130	060090	060115	060130
NOMINAL CAPACITY (ton)	4	4	4	5	5	5
OPERATING WEIGHT (lb)	421	421	421	468	468	468
COMPRESSORS Quantity	Scroll 1					
REFRIGERANT (R-22) Quantity (lb)	8.3	8.3	8.3	8.1	8.1	8.1
REFRIGERANT METERING DEVICE Orifice ID (In.)	Acutrol Device					
	.034	.034	.034	.032	.032	.032
CONDENSER COIL Rows—Fins/In. Face Area (sq ft)	2—17 12.3	2—17 12.3	2—17 12.3	2—17 16.4	2—17 16.4	2—17 16.4
CONDENSER FAN Nominal Cfm Diameter (in.) Motor Hp (Rpm)	3300 22 1/4 (1100)	3300 22 1/4 (1100)	3300 22 1/4 (1100)	3300 22 1/4 (1100)	3300 22 1/4 (1100)	3300 22 1/4 (1100)
EVAPORATOR COIL Rows—fins/in. Face Area (sq ft)	4—15 4.7	4—15 4.7	4—15 4.7	4—15 4.7	4—15 4.7	4—15 4.7
EVAPORATOR BLOWER Nominal Airflow (Cfm) Size (in.) Motor Hp (RPM)	1600 11 x 10 3/4 (1075)	1600 11 x 10 3/4 (1075)	1600 11 x 10 3/4 (1075)	1750 11 x 10 1.0 (1075)	1750 11 x 10 1.0 (1075)	1750 11 x 10 1.0 (1075)
FURNACE SECTION* Burner Orifice No. (Qty—Drill Size) Natural Gas Burner Orifice No. (Qty—Drill Size) Liquid Propane	3—38 3—46	3—33 3—42	3—31 3—41	3—38 3—46	3—33 3—42	3—31 3—41
RETURN-AIR FILTERS (in.)† Throwaway	24 x 30 x 1	24 x 30 x 1	24 x 30 x 1	24 x 30 x 1	24 x 30 x 1	24 x 30 x 1

* Based on altitude of 0 to 2000 feet.

† Required filter sizes shown are based on the larger of the ARI (Air Conditioning and Refrigeration Institute) rated cooling airflow or the heating airflow velocity of 300 ft/min for throwaway type or 450 ft/min for high-capacity type. Air filter pressure drop for non-standard filters must not exceed 0.08 in. wg.

Electrical data

UNIT SIZE 48GX	V-PH-Hz	VOLTAGE RANGE		COMPRESSOR		OUTDOOR FAN MOTOR	INDOOR FAN MOTOR	POWER SUPPLY	
		Min	Max	RLA	LRA	FLA	FLA	MCA	MAX FUSE or CKT BKR
024	208/230-1-60	187	253	10.9	54.0	0.9	2.0	16.5	25
030	208/230-1-60	187	253	13.5	73.0	0.8	2.1	19.8	30
	208/230-3-60	187	253	9.0	63.0	0.8	2.1	14.2	20
036	208/230-1-60	187	253	16.7	97.0	0.8	3.6	25.3	40
	208/230-3-60	187	253	11.2	75.0	0.8	3.6	18.4	25
	460-3-60	414	506	5.4	37.5	0.9	1.9	9.6	15
042	208/230-1-60	187	253	17.9	104.0	1.6	4.1	28.1	45
	208/230-3-60	187	253	12.4	88.0	1.6	4.1	21.2	30
	460-3-60	414	506	6.1	44.0	0.9	2.0	10.5	15
048	208-230/1/60	187	253	23.4	126.0	1.6	4.1	34.9	45
	208/230-3-60	187	253	13.0	93.0	1.6	4.1	21.9	30
	460-3-60	414	506	6.4	46.5	0.9	2.0	10.8	15
060	208/230-1-60	187	253	28.8	169.0	1.6	6.2	43.8	60
	208/230-3-60	187	253	17.3	123.0	1.6	6.2	29.4	45
	460-3-60	414	506	9.0	62.0	0.9	3.2	15.4	20

AC-1 →

AC-2 →

LEGEND

- FLA — Full Load Amps
- LRA — Locked Rotor Amps
- MCA — Minimum Circuit Amps
- MOCP — Maximum Overcurrent Protection
- RLA — Rated Load Amps



*Heater capacity (KW) based on heater voltage of 208v, 240v, & 480v. If power distribution voltage to unit varies from rated heater voltage, heater KW will vary accordingly.


NOTES:

- In compliance with NEC (National Electrical Code) requirements for multimotor and combination load equipment (refer to NEC Articles 430 and 440), the overcurrent protective device for the unit shall be Power Supply fuse. The CGA (Canadian Gas Association) units may be fuse or circuit breaker.
- Minimum wire size is based on 60 C copper wire. If other than 60 C wire is used, or if length exceeds wire length in table, determine size from NEC.
- Unbalanced 3-Phase Supply Voltage
Never operate a motor where a phase imbalance in supply voltage is greater than 2%. Use the following formula to determine the percentage of voltage imbalance.

% Voltage imbalance

$$= 100 \times \frac{\text{max voltage deviation from average voltage}}{\text{average voltage}}$$

EXAMPLE: Supply voltage is 460-3-60.



AB = 452 v
BC = 464 v
AC = 455 v

$$\begin{aligned} \text{Average Voltage} &= \frac{452 + 464 + 455}{3} \\ &= \frac{1371}{3} \\ &= 457 \end{aligned}$$

Determine maximum deviation from average voltage.

(AB) 457 - 452 = 5 v
(BC) 464 - 457 = 7 v
(AC) 457 - 455 = 2 v

Maximum deviation is 7 v.

Determine percent of voltage imbalance.

$$\begin{aligned} \% \text{ Voltage Imbalance} &= 100 \times \frac{7}{457} \\ &= 1.53\% \end{aligned}$$

This amount of phase imbalance is satisfactory as it is below the maximum allowable 2%.

IMPORTANT: If the supply voltage phase imbalance is more than 2%, contact your local electric utility company immediately.