

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 0002338
Insp Area: 2

Site Address: 8180 ARROYO VISTA DR SAC
Parcel No: 117-1120-056

Sub-Type: AOTHR
Housing (Y/N): N

CONTRACTOR
INNERWORKS FIRE&CONSTRUCTION
POB6388
VACAVILLE CA 95696-6388

OWNER
SACRAMENTO CA
95529

ARCHITECT
PAC REGENCY PLACE ASSOCIATION

Nature of Work: INSTALL FIRE SUPRESSION SYSTEM FOR HOOD & DUCT SYSTEM

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name MGNE Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class C14 License Number 730356 Date 3/8/00 Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code: any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure. prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

_____, I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

_____, I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

_____, I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 3/8/00 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

_____, I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

_____, I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier NO EMPLOYEES Policy Number _____ Exp Date _____

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 3/8/00 Applicant/Agent Signature [Signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

**CITY OF SACRAMENTO
APPLICATION FOR COMMERCIAL BUILDING PERMIT**

DEVELOPMENT SERVICES DIVISION
PERMIT SERVICES SECTION

1231 I Street, Rm. 200
Sacramento, CA 95814 (916) 264-7619 FAX 264-7046

ACTIVITY # 00-02338 Insp. Area U

Applicant MUST complete ALL Unshaded areas

ADDRESS 8180 Arroyo Vista DR Suite _____

PARCEL # 117-1120-056

| | | | |
|---------------------------|-------------------------|----------------------------|----------------------------------|
| CONTACT | | LICENSED CONTRACTOR | |
| Name <u>Tony Bruce</u> | Address _____ | Name <u>Innernet</u> | Lic No. # <u>730356</u> |
| Phone <u>707-446-3383</u> | FAX <u>707-447-6252</u> | Address <u>PO Box 5321</u> | Phone <u>707-446-3383</u> |
| E-mail _____ | | FAX <u>707-447-6252</u> | E-mail _____ |
| ARCHITECT/ENGINEER | | OWNER | |
| Name _____ | Address <u>None</u> | Name <u>Assirel Lung</u> | Address <u>8180 Arroyo Vista</u> |
| Phone _____ | FAX _____ | Phone <u>916-371-7777</u> | FAX _____ |
| E-mail _____ | | E-mail _____ | |

→ Will permittee have any employees on the jobsite? No Yes → INSURANCE CO: _____

→ WORKER'S COMPENSATION POLICY # _____ EXPIRATION DATE: _____

NATURE OF WORK IN DETAIL: install Hood & Duct Fire System

OCCUPANT/TENANT: ASSIREL LUNG VALUATION: \$ 1250⁰⁰

| | | | | | | | | | | |
|--------------------------|--------------|------------|----------|------------|---------------|-----------------|----------|------------|------------|--------|
| FLOOD STATUS: <u>N/A</u> | | S.C.A.T. | | | | | | | | |
| JOB DESCRIPTION | | BLDG | SHELL | APT | TI() | REM() | SW | FIRE | ADD | OTH |
| INSPECTION DISCIPLINES | | BLDG | MECH | PLUMB | ELEC | | SITE | FIRE | | |
| # Stories | 1st flr Area | Total Area | Use Zone | Occp Group | Const type | Fire Req. Y / N | | Fed Code | Vio. File | |
| | | | | <u>18</u> | | SPR | ALARM | <u>B</u> | [H] | [Quad] |
| <u>B</u> | <u>L</u> | <u>P</u> | <u>M</u> | <u>E</u> | <u>F</u> | <u>S</u> | <u>D</u> | <u>PWB</u> | <u>UTL</u> | |
| | | | | | <u>13 ETC</u> | | | <u>PSB</u> | | |

COMMENTS: 5.8.00

REGIONAL SANITATION FEES? Yes No HEALTH DEPARTMENT? Yes No

WATER FLOW TEST FOR NEW BUILDINGS OR ADDITIONS? Provided Faxed


SYSTEM LAYOUT

CITY OF SACRAMENTO
PERMIT ASSISTANCE

MAR 08 2000

RECEIVED

6C-02338



FLOOR PLAN

ISSUED

MAR 08 2000

CITY OF SACRAMENTO
DEVELOPMENT SERVICES DIV

This set of plans and specifications must be kept on the job at all times and it is unlawful to make any changes or alterations from the same without written permission from the Building Inspection Division.
The approval of this plan and specification SHALL NOT be held to permit or approve the violation of any City Ordinance or State Law.

APPROVED
E.H. [Signature]
Sacramento Fire Department
PENDING FIELD INSPECTION
3.8.00

INSTALLING CONTRACTOR:

INNERWORKS FIRE & CONSTRUCTION, INC.
600 D Embanks Ct., Vacaville, CA 95688-9404
Contractors Lic. # 730356
707-446-3383 Fax: 707-447-6252


JOB SITE

Assisted Housing
8180 Arroyo Vista
Sac Ca 95628

| No. | Description | Quan. | Part # | Flows Per | Comments |
|-----|-----------------------|-------|------------|-----------|-----------------------------|
| 1 | PYRO CHEM FIRE SYSTEM | 1 | PLU 350 | 13 | A MAX ALLOWABLE FLOWS 13 |
| 2 | REMOTE MANUAL PULL | 1 | RPS M | | B ACTUAL NO. OF FLOWS 10 |
| 3 | AUTO. MECH. GAS VALVE | 1 | GVSO-1 1/2 | | C SINGLE BANK FILTERS 1 |
| 4 | DETECTOR BRACKET | 2 | FLK-1 | | D DUCT PERIMETER (S) 16 Y/L |
| 5 | PLENUM NOZZLE | 2 | NL-A | 2 x 1 = 2 | E 450' FUSIBLE LINKS 3 |
| 6 | DUCT NOZZLE | 1 | NL-D2 | 1 x 2 = 2 | F DRAWINGS NOT TO SCALE |
| 7 | FRYER NOZZLE | 1 | NL-F2 | 1 x 2 = 2 | |
| 8 | RANGE NOZZLE | 1 | NL-F1 | 1 | |
| 9 | BROILER NOZZLE | 1 | NL-R | 1 | |
| 10 | DUCT NOZZLE | 1 | NL-P | 1 | |
| 11 | GRID NOZZLE | 1 | NL-G | 1 | |
| 12 | RANGEL NOZZLE | 2 | NL-R2 | 2 | |

PIPING

All Pipe 3/8 SCH 40 Black Pipe
System per UL300



System connected
TO BUILDING
FIRE ALARM