

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 0010460
Insp Area: 2

Site Address: 1427 CARROUSEL LN SAC
Parcel No: 017-0073-009

Sub-Type: RES
Housing (Y/N): N

CONTRACTOR
SACRAMENTO VALLEY ROOFING
4028 CALIFORNIA AV
CARMICHAEL CA 95608

OWNER
ELLIS ALBERT
1427 CARROUSEL LN
SACRAMENTO CA 95822


ARCHITECT

Nature of Work: REROOF T/O RESHT 40 SQ COMP

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class C License Number 546460 Date 9-7-00 Contractor Signature 

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00):

_____, I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)


_____, I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

_____, I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 9-7-00 Applicant/Agent Signature 


WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

_____, I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

DT I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE FUND Policy Number 229-00-0014409 Exp Date 01/01/2001

_____, (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 9-7-00 Applicant Signature 

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

PERMIT NO.
0810460

CITY OF SACRAMENTO
1231 I ST. ROOM 200
BUILDING INSPECTIONS DIVISION

AREA NO.
2

WHEN CORRECTIONS HAVE BEEN MADE CALL 264-5191 FOR REINSPECTION OF WORK.

JOB LOCATION 1427 Carrousel Lane

INSPECTION REQUESTED I.P. Job already complete 10:45AM

THE UNDERSIGNED BUILDING PLUMBING MECHANICAL ELECTRICAL
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE
FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

Please put permit where it can be reached

① Sacramento City Requires an IN Progress inspection. Please be prepared to remove some roofing to check the deck if not called for on your NEXT JOB.

② A/C condensate line shall be blocked & strapped.

③ Bottom ridge unit on all hips shall be doubled.

④ Shingles above A/C duct flange shall be doubled.

⑤ Seal top of 3" soil pipe where counter cone does not return in to pipe.

⑥ Nails are not penetrating the double laminate as required by the shingle manufacturer.

INSPECTOR Gene Calaya DATE 9/26/05

BUILDING INSPECTIONS 264-5716

INSPECTOR'S COPY

PERMIT NO.
00-10460

CITY OF SACRAMENTO
1231 I ST. ROOM 200
BUILDING INSPECTIONS DIVISION

AREA NO.
22

WHEN CORRECTIONS HAVE BEEN MADE, CALL 264-5191 FOR REINSPECTION OF WORK.

JOB LOCATION 1477 CAROUSEL

INSPECTION REQUESTED REPAIRS - 3RD TIME.

THE UNDERSIGNED BUILDING PLUMBING MECHANICAL ELECTRICAL
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

- See Previous 2 correction notices

- Nails not penetrating - Double layer
of sheetrock, NOT High, & First &
Last nail with 1" or close to edge

not - 4x6's in
Do of record next time A
75% rework fee will be
charged.

INSPECTOR

[Signature]

DATE 10/27/00

BUILDING INSPECTIONS 264-5716

INSPECTOR'S COPY

PERMIT NO.
0016460

AREA NO.
2

CITY OF SACRAMENTO
1231 I ST. ROOM 200
BUILDING INSPECTIONS DIVISION

WHEN CORRECTIONS HAVE BEEN MADE, CALL 264-5191 FOR REINSPECTION OF WORK.

JOB LOCATION 1427 Lamwood

INSPECTION REQUESTED 1 and 2

THE UNDERSIGNED BUILDING PLUMBING MECHANICAL ELECTRICAL
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

1 Refer to item # 2 previous correction notice - condensation line to be blocked (with pressure treated in foundation grade adjacent lumber) and strapping every 6'.
2 Refer to item # 6 previous correction notice - Nails not protruding double laminated area (nail line) Re-nail all shingles through double laminated area. 15' and 474 nail within 1" of edge.

INSPECTOR Charles Morrison DATE 10/3/00

BUILDING INSPECTIONS 264-5716
INSPECTOR'S COPY

PERMIT NO.
0010460

AREA NO.
2R

CITY OF SACRAMENTO
2101 ARENA BLVD. #200
BUILDING INSPECTIONS DIVISION

WHEN CORRECTIONS HAVE BEEN MADE, CALL 264-5191 FOR REINSPECTION OF WORK.

JOB LOCATION 1427 CARBUSEE LN

INSPECTION REQUESTED Roof Final No Call

THE UNDERSIGNED BUILDING PLUMBING MECHANICAL ELECTRICAL
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

CITY RECORDS SHOW THAT PERMIT ISSUED

9-7-00 WAS NOT FINALIZED BY CORRECTIONS
ISSUED 9-21-00, 10-3-00, & 10-27-00 WERE BOWS
OWNER OR CONTRACTOR SHALL CALL FOR
FINAL INSPECTION TO OBTAIN PERMIT

808-5258

INSPECTOR Kyle Caluya DATE 1/2/04

BUILDING INSPECTIONS 808-5716
INSPECTOR'S COPY