

**BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD**

**TYPE VII BUILDINGS**

<b>PERMIT NO.</b> <i>23140</i>	<b>LOCATION</b>		<i>23140</i>	
<b>DATE</b> <i>8/17/30</i>	<b>PURPOSE</b> <i>Rep. Roof on 2nd Floor</i>	<b>ROOMS</b>	<b>APTS.</b>	
<b>ZONE</b>	<b>OWNER</b> <i>Van Walbeek</i>	<b>PHONE</b>		
	<b>ARCH'T</b>			
	<b>CONT'R</b> <i>W. J. Laune</i>			
	<b>VAL.</b> <i>40-</i>	<b>STORIES</b>	<b>SIZE</b>	

FOUNDATION	STORY	BSMT	1	2	3	ROOF		
Ex Wall	Jolts						Chimneys	Cement Tests
	Beams and Girders						Fire Place	
Int Wall	Studs and Columns						Gas Water Heater	
	Bridging Fire Stops						Heater Closet	
Piers	Fire Escape Stand Pipes						Furnace	Window Courts
	Metal Lath						Boiler Room	
	Stairs						Elevator Shaft	

DATE	CONDITION OF WORK—REMARKS
3/11/30	Inspected repairs being made to front porch & steps.
	Found 2 <sup>nd</sup> Story Porch Joists affected by "TERMITES".
	Notified Contractor to remove all timbers affected Said he would do so. <i>W. Campbell</i>
	<p>COMPLETED AND O.K.</p> <p style="text-align: right;">INSPECTOR</p>