

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 9907918
Insp Area: 2

Site Address: 4450 LINERAS WY SAC
Parcel No: 119-0323-001

Sub-Type: RES
Housing (Y/N): N

CONTRACTOR
CAPITAL ROOFING CO INC
6501 FLORIN PERKINS RD
SACRAMENTO CA 95828

OWNER
SMALL SAMUEL EDWARD
4450 LINERAS WY
SACRAMENTO CA 95823

ARCHITECT

Nature of Work: REROOF 30 SQ

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class C-29 License Number 2120934 Date 7/20/99 Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00):

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code). The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code). The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: _____
Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 7/20/99 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE FUND Policy Number 1465924-98 Exp Date 10/01/1999

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 7/20/99 Applicant Signature [Signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

Openings through the panels for vents, etc., must be adequately weatherproofed as described in this section, and supported by additional blocking or roof framing as necessary.

2.6 Roof Covering Classification:

Decra roofing panels installed in accordance with Section 2.5 are recognized as a Class A roof covering under Section 1504 of the 1994 *Uniform Building Code*™. Under the 1996 Accumulative Supplement the roof covering is considered non-combustible.

2.7 Reroofing Application:

2.7.1 General: When the old roof covering is completely removed, all conditions noted in Sections 2.1 through 2.6 shall apply. The existing structure must be inspected as set forth in Appendix Chapter 15 of the *Uniform Building Code*.

Decra steel roofing panels may also be installed over existing wood shake, wood shingle, asphalt shingle, or built-up roofs, provided the roof slope complies with Section 2.2. When a Decra steel panel roofing assembly is installed over an existing classified roof covering, the classification remains unchanged. When a Decra steel panel roofing system is installed over wood shingle or shake roofs, the entire roof surface must be covered with mineral fiber, glass fiber, gypsum sheathing or other approved materials in accordance with Section 1516.3 of the code, and firestopped in accordance with Table A-15-A of the UBC Appendix.

2.7.2 Installation Requirements for Reroofing: Class C:

Wood shake and wood shingle ridge and hip caps must be removed, and the existing roof covering cut back flush with the fascia or barge cover. Nominal 1 by 4 wood counterbattens are installed parallel to the framing (perpendicular to the eaves) at a maximum spacing of 24 inches (610 mm). Counterbattens are securely fastened to framing members using nails of sufficient length to penetrate 1 inch (25.4 mm) into the framing member or through minimum 3/4-inch-thick (19.1 mm) sheathing. Nail spacing is 12 inches (305 mm) on center. The diamond point of the nail must be fully exposed on the underside of the sheathing. Care should be taken to avoid splitting the battens and counterbattens. Nominal 2 by 2 battens are spaced 14 1/2 inches (368 mm) on center for Decra Tiles, and spaced 12 5/8 inches (321 mm) on center for Decra Shake and Decra Slate, and are nailed to the counterbattens using 16d common nails or equivalent. The panels are fastened to the battens in the same manner as shown in Section 2.5. New flashings are installed over and around all existing valleys, vents and chimneys in accordance with local code requirements. The valley used in reroofing must be as shown in Figure 1.

When the Decra steel panel roofing system is installed over wood shingle or shake roofs, 1 1/2-inch-thick (38 mm) fiberglass insulation is installed over the existing wood roof, between the 2 by 2 battens, to comply with the requirements of Section 1516.3 and Table A-15-A of the UBC Appendix. See Figure 4 for Class 'C' Roofing Assembly. All exposed wood

prior to application of the 1 1/2-inch-thick (38 mm) fiberglass insulation. The cap sheet functions as a fire-re- and may also be used to satisfy the underlay- ment of Section 2.3. Additionally, when the Dec roofing system is installed over wood shingle o 1 1/2-inch-thick (38 mm) insulation is installed b by 2 battens and over the surface of the cap sh comply with the requirements of Section 151 A-15-A of the UBC Appendix.

As an alternative to using mineral-surfaced sheet for Class B installations, an underlayme thick (38 mm) foil-faced fiberglass batt insulat quality control agency which has an ICBO ES c tion report, may be installed with the foil face (51 mm) headlaps over the existing roof surfa installation of the battening system. The 1 1/2-inch-thick (38 mm) foil-faced fiberglass wood shingle or shake roofs satisfies the r Section 1516.3 and Table A-15-A of the UBC Figure 4 for Class 'B' Roofing Assembly.

2.7.4 Installation Requirements for Reroofing:

Installation shall be as set forth in Section 2.7. lows: a layer of minimum 1/2-inch-thick (12.7 mm) resistant core gypsum sheathing complying with Section 1516.3 and Table A-15-A of the UBC Appendix. The gypsum sheathing joints must be staggered. When the Decra Roofing system is installed over wood shingle or shake roof, the space between the wood roof and the 1/2-inch-thick (12.7 mm) sheathing, and the space between the gypsum sheathing and the new roof covering, must be firestopped with mineral fiber, or gypsum sheathing, with a maximum contained area of 100 square feet per linear foot. See Table A-15-A of the UBC Appendix. See Figure 4 for Class 'B' Roofing Assembly.

2.8 Structural Diaphragm:

The Decra panel roofing systems may be used as roof diaphragms when constructed as follows: over an existing wood shake roof is acceptable if the shakes are in nailable condition, with all shakes fastened in accordance with Table 15-B-2 of the UBC Appendix. If the shakes are installed on nominal 1 by 6 wood framing, they must be nailed to framing as specified in the code. If the shakes are installed over solid sheathing, 1 by 4 counterbattens are installed over framing 24 inches (610 mm) on center, secured with nails at 10 inches (254 mm) on center. The nails must be long enough for the diamond point of the nail to be fully exposed through the sheathing. Nails must be minimum 16d. If the shakes are installed over 4 spaced sheathing nailed to the framing in accordance with the code, 1 by 4 counterbattens aligne

150 pounds per square