

CITY OF SACRAMENTO

Permit No: 0200195

1231 I Street, Sacramento, CA 95814

Insp Area: 2
Thos Bros: 358 B1

Site Address: 8560 DERLIN WY SAC

Parcel No: 117-1160-014

Sub-Type: REP
Housing (Y/N): N

CONTRACTOR

DUARTE CONSTRUCTION
6060 KING RD
LOOMIS 95650

OWNER

JOHN ROBINSON
8560 DERLIN WY
SACRAMENTO CA 95823

ARCHITECT

Nature of Work: FIRE DAMAGE REPAIR

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class 3588 License Number 335288 Date 1/7/02 Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature [Signature]

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 1/7/02 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier: STATE FUND Policy Number: 208981 Exp Date: 01/01/2002

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 1/7/02 Applicant Signature [Signature]

WARNING: FAILURE TO SECURE WORKERS COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

Sacramento Fire Department - Incident Report

Incident No : 010053341 Call# : 1119706 Date: 11/14/01 Time: 16:21
Address : 8560 DERLIN WY
Type : 11 BUILDING FIRE
Action Taken: 16 VENTILATION
Property : 1-2 FAMILY RESIDENTIAL: SINGLE FAMILY
UBC : DWELLINGS AND LODGING HOUSES

Weather : 65 Degrees / Cloudy
Resources : 1 Engine, 1 Truck
1 Other Apparatus

Fire Casualties : None

Fire Damage : Confined to structure of origin
Smoke Damage : Confined to structure of origin
Property Loss : \$25,000 Contents Loss : \$25,000
Property Value : \$215,000 Contents Value: \$50,000

Area of Origin : Dining area Level: A01

Caused by : No equipment involved
Form of Heat : Candle, taper
Ignition Factor : Heat source too close to combustibles
Type of Material : Flexible foam plastics
Form of Material : Upholstered sofa, chair, vehicle seats
Type of Material : Flexible foam plastics
Form of Material : Magazine, newspaper, writing paper
Smoke Travel : Opening in construction
Other Factors : Wall combustible
Extinguished by : Water carried on first in unit
Structure Type : Building with one specific property use
Structure Status : In use
Occupied
Construction Type: Type V - Wood Frame
Roof Type : Tile
Number of Stories: 2

Detector Type : Smoke detector - photoelectric
Power : Hard wire w/battery backup
Performance : Detector operated but not a factor in discovery
Reason Failed : No failure

Extinguishing Sys: No extinguishing system

Report Author : F353

LEVEL 1

