

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD
TYPE BUILDINGS

PERMIT NO. 8241	LOCATION 2401 Q St		
DATE 7/16/31	PURPOSE Install Pr Garage	PHONES	
ZONE M-1	OWNER W. H. Adams		
	ARCH'T		
	CONT-R		

VAL. 150-	STORIES	ROOMS	APTS.	SIZE
---------------------	----------------	--------------	--------------	-------------

Light Shafts		Elevator Shafts	
Vent Shafts		Boiler Rooms	
Owner's Inspector		Sprinkler System	
Lath		Gas Vents	
Fire Escapes		Chimneys	
Stand Pipes		Skylights	

DATE	CONDITION OF WORK-REMARKS
7/2/31	<p>Made Partial Insp. of Repairs to Dolly notified Owner to cut wood lath away around thumble and provide metal lath instead. Owner wanted to use cov. iron for Ori. barge to be installed under dolly under the Permit. Told him metal lath & plaster, walls & ceiling, required for same under dolly. A W Campbell</p>
COMPLETE AND O.K.	INSPECTOR