

| | | | | |
|---------------------------|--------------|--|-------|---|
| Lt. 505 | | BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD | | \$33.50 |
| Golf Course Village #8 | | TYPE BUILDINGS | | R-76 F-852-853 R-70 F-842-843 |
| PERMIT NO. D-7235 | LOCATION | 7416-Troon Way | A-5 | |
| DATE Nov. 4, 60 | PURPOSE | Dwlg. & att. gar. | I-1 | |
| ZONE R-1 | OWNER | Darby Development Co | | |
| | ARCH'T | GA 15379 | | |
| | CONT'R | Contempo Inc. Joe Rohrer 2336-66th A. | | |
| VAL. \$11,500. | STORIES 1 | ROOMS 6 | APTS. | gar. 483 ^{SIZE} 1,150 sq. ft. |
| INSP. | DATE | INSPECTOR | | |
| FORM | 1-4-61 | Jones | | |
| JOIST | 2-16-61 | Barbato | | |
| FRAME | 4-18-61 | Barbato | | |
| LATH | 4-27-61 | Jones | | |
| FINAL | 7.31.61 | Berry | | |

| DATE | SPECIAL CONDITIONS OF WORK—REMARKS |
|---------|---|
| 1-3-61 | Not ready for form insp. Backlogs |
| 2-7-61 | Not ready for joint insp. Backlogs |
| 4-11-61 | P.T Not Ready for frame Backlogs |
| 7-13-61 | P.T Not Ready & no flashing at roof turn of fire place no Backing fire wall garage |
| | |
| | |
| | |
| | |
| | |
| | <p data-bbox="270 847 390 891">COMPLETE AND OK</p> <p data-bbox="1078 868 1205 891">INSPECTOR</p> |