



CITY OF SACRAMENTO

www.cityofsacramento.org
 Help Line: 1-916-808-5656 OR 1-866-EZ-PERMIT
 Inspection Request: 1-916-808-7622

Downtown Permit Center
 New City Hall
 915 I Street, 3rd Floor
 Sacramento, CA 95814

North Permit Center
 2101 Arena Blvd., Suite 200
 Sacramento, CA 95834

Permit No. 0616685
 Date Applied 10/24/2006
 Type Commercial
 Subtype Remodel
 Category Office

Permit Address 7300 FOLSOM BL
 SACRAMENTO CA
 Site Location SUITE # 200

Parcel No. 07902220160000

Owner 2800 PICO ASSOCIATESLLC
 PO BOX 39
 APTOS, CA

Valuation \$ 25,000.00

Fee Items	# of Each	Amount
Permit--Building-Com	1	\$484.00
Plan Ck--Building Com	1	\$85.00
Strong Motion	1	\$5.25
City Business Oper Tax	1	\$10.00
Bldg-Technology Surcharg	1	\$22.76
General Plan Surcharge	1	\$14.75
Total		\$621.76

PAID
CITY OF SACRAMENTO
NOV 16 2006
NEIGHBORHOODS PLANNING
AND DEVELOPMENT SERVICES

LICENSED CONTRACTOR'S DECLARATION

I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code, and my license is in full force and effect.

License Class: B License Number: 839353
 Date: 11/16/06 Contractor: Icon Contract Const. Inc

OWNER-BUILDER DECLARATIONS

I hereby affirm that I am exempt from the Contractor's License Law (C.L.L.) for the following reason (Sec. 7031.5 B&P Code: Any city or county which requires a permit to construct, alter, improve, demolish or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he/she is licensed pursuant to the provisions of C.L.L. Chapter 9 (commencing with Sec.7000) of Division 3 of the B&P Code) or that he/she is exempt there from and the basis for the alleged exemption. Any violation of Sec. 7031.5 by any applicant for a permit subjects the applicant to civil penalty of not more than five hundred dollars (\$500):

I, as owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044 B&P Code: The C.L.L. does not apply to an owner of property who builds or improves thereon, and who does such work himself or through his own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractor(s) to construct the project (Sec. 7044, B&P Code: The C.L.L. does not apply to an owner of property who holds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the C.L.L.)

I am exempt under Sec. _____ B & P.C. for this reason:

Date: _____ Owner: _____

WORKERS COMPENSATION DECLARATION

I hereby affirm that I have a certificate of consent to self-insure, or a Certificate of Worker's Compensation Insurance, or a certified copy thereof (Sec 3800, Labor Code).

Policy Number: _____ Company: _____

_____ Certified copy is hereby furnished.

_____ Certified copy is filed with the city building inspection department or city _____ department.

Date: 11/16/06 Applicant: [Signature]

I certify that I have read this application and state that the above information is correct. I agree to comply with all city and county ordinances and state laws relating to construction. I hereby authorize representatives of this city to enter upon the above mentioned property for inspection purposes.

Date: 11/16/06 Applicant or Agent: [Signature]

Description of Work:
 2409 SF OFFICE REMODEL NO CHANGE OF USE

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

7300 Folsom B/#0616685 PGL

Buc Heating & AC Air Balance Report

Job Name	HoLIVE
Date	12-19-06
Tech	BVL
System	PACIENTS WETS
Instrument	Flow Hood

Area Served	Outlet No.	Outlet Size	Adj. Values	Design CFM	Preliminary CFM	Preliminary CFM	Final CFM	Notes
Stairway	1	12			532		532	
	2	12			485		485	
	3	12			543		543	
↓	1	14			(1560)		-759	
	2	14			-676		-676	
	051				125		125	
Lobby	1	8			216		216	
	2	8			139		139	
	3	8			151		151	
Lobby	4	8			47		47	
	5	8			169		169	
	6	8			243		243	
↓	7	8			144		144	
	8	8			232		232	
	9	8			122		122	
open office	1	10			(1468)		-223	
	2	12			-283		-283	
	3	16			-560		-560	
054				402		402		
					(1468)			

Buc Heating & AC Air Balance Report

Job Name	Hocue
Date	12-14-06
Tech	BUC
System	PHEWLE
Instrument	Flow Head

Area Served	Outlet No.	Outlet Size	Adj. Values	Design CFM	Preliminary CFM	Preliminary CFM	Final CFM	Notes
Office	1	12			321		321	
	2	8			321		321	
	3	10			127		127	
	4	10			350		350	
	5	8			162		162	
					<u>1281</u>			
	1	10			-216		-216	
	2	8			-172		-172	
	3	16			-612		-612	
	054				281		281	
					<u>1281</u>			
Conference	1	16			428		428	
	2	8			231		231	
Server	3	8			371		371	
	4	3			324		324	
					<u>1854</u>			
					-664		-664	
		14			-941		-941	
		16			#644		-644	
	05A				<u>1854</u>			

AC-4

AC-3

Buc Heating & AC Air Balance Report

Job Name	MTC
Date	12-14-06
Tech	Buc
System	PATRICK
Instrument	Flow Hood

Area Served	Outlet No.	Outlet Size	Adj. Values	Design CFM	Preliminary CFM	Preliminary CFM	Final CFM	Notes
OFF OFFICE	1	16			732		732	
	2	16			944		944	
	3	8			271		271	
	4	8			48		48	
Burr	5	10			180		180	
	6	8			140		140	
	7	8			127		127	
OFFICE	8	6			97		97	

VAV'S AT UNIT NEED METAL ACCOUNTS FOR CORRECTION