

CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 0519907

Insp Area: 4

Thos Bros: 276J1

Site Address: 4420 DUCKHORN DR SAC St: #200

Parcel No: 225-0080-051

SUITE 200

Sub-Type: TI

Housing (Y/N): N

CONTRACTOR

VAN HOUTEN - OLAFSSON BUILDERS
2048 BROOK MAR DR
EL DORADO HILLS CA 95762

OWNER

REVERSE EXCHANGE PROPERTIES
5101 FLORIN PERKINS RD
SACRAMENTO, CA 95826

ARCHITECT

Nature of Work: SUITE 200 - 1ST TIME TI FOR "BURGER PHYSICAL THERAPY"; 2588 SF; NON-SPRINKLERED

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name

Lender's Address

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class License Number 866777 Date 1-11-06 Contractor Signature

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. B & PC for this reason:

Date Owner Signature

PAID CITY OF SACRAMENTO

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvement.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and herby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date Applicant/Agent Signature

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier NO EMPLOYEES Policy Number Exp Date

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 01-11-06 Applicant Signature

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

CITY OF SACRAMENTO

CERTIFICATE OF OCCUPANCY

For Information Contact (916) 808-5716

Building Address: 4420 DUCKHORN DR., SUITE #201 Permit No.: 0519907
Building Use: OFFICE DBA: BURGER PHYSICAL THERAPY Occupancy: B
Building Owner: REVERSE EXCHANGE PROPERTIES Construction Type: VN
Owner Address: SACRAMENTO, CALIF 95826 Sprinkled? Yes No
Portion of Building Occupied: ENTIRE, SUITE #201 Area: 2588 Sq. Ft.
Date: 05/02/2006 By: James Peddy Sign: CARL HEFNER
(Print) Sign ASSISTANT BUILDING OFFICIAL

[Finaled By: MJJ, RLB, GDS, JS, MJG]

This Certificate, issued pursuant to the requirements of Section 109 of the Uniform Building Code, certifies that at time of issuance the described portion of the building has been inspected for compliance with the Uniform Building Code, as adopted per Title 15 of the Sacramento City Code for the group and division of occupancy and use for which the proposed occupancy is classified. Issuance of this certificate shall not be construed as an approval of a violation of any Codes, or Federal, State and City Laws or Ordinances. Certificates presuming to give authority to such violation shall not be valid. This certificate shall be posted in a conspicuous place on the premises and shall not be removed except by the Chief Building Official. No changes shall be made in the character of occupancy or use without approval of the Chief Building Official.

POST IN A CONSPICUOUS PLACE

CITY OF SACRAMENTO

30 DAY TEMPORARY

Certificate of Occupancy

For Information Contact (916) 808-5716

Building Address: 4420 DUCKHORN DRIVE SUITE #201 Permit No.: 0519907
Building Use: OFFICE DBA: BURGER PHYSICAL THERAPY Occupancy: B
Building Owner: REVERSE EXCHANGE PROPERTIES Construction Type: VN
Owner Address: SACRAMENTO, CALIF 95826 Sprinkled? Yes No
Portion of Building Occupied: ENTIRE, SUITE #200 Area: 2588 Sq. Ft.

Specific purpose for temporary occupancy and/or conditions/limitations of temporary occupancy:

04/21/2006 *Nicholas R. Burkholder* CARL HEFNER

Date: By: (Print) Sign ASSISTANT BUILDING OFFICIAL

[TCO approvals: MJ, WZG, JT, JS, MJG]

CBC 109.4 TEMPORARY CERTIFICATE

If the Chief Building Official finds that no substantial hazard will result from occupancy of any building or portion thereof before the same is completed, a temporary Certificate of Occupancy may be issued for the use of a portion or portions of a building or structure prior to the completion for the entire building or structure.

POST IN A CONSPICUOUS PLACE

AIR BALANCE COVER SHEET

April 21, 2006

PROJECT:

Burger Rehab
4420 Duckhorn
Sacramento, CA 95834

CONTRACTOR:

VanHouten-Olafsson Builders
2048 Brook Mar Drive
El Dorado Hills, Ca 95762

HVAC SYSTEM REPORT

4/19/2006

FAN NAMEPLATE DATA

MANUFACTURER Carrier
 MODEL 50HJQ006-521
 TYPE H.P. Pack
 SIZE 5Ton
 SERIAL NUMBER 0906G30491

FAN PULLEY DATA

DIAMETER 3
 SHAFT 3/4
 ADJ/FIXED Fixed

MOTOR NAMEPLATE DATA

MANUFACTURER
 VOLTS/PHASE 208/3
 HORSEPOWER
 FULL LOADS AMPS 5.8
 RPM 1725

MOTOR PULLEY DATA

DIAMETER 3
 SHAFT 3/4
 ADJ/FIXED adjustable
 BELT NO. & SIZE A40

CONDENSING UNIT DATA

MANUFACTURER
 MODEL
 TONNAGE
 SERIAL NUMBER

FAN	DESIGN	ACTUAL
TOTAL CFM	2000	2319
RETURN AIR CFM	1830	2152
OUTSIDE AIR CFM	170	167
FAN SPEED	1725	
STATIC PRESSURE +	0.3	0.3
STATIC PRESSURE -	0.2	0.2
TOTAL STATIC PRESSURE	0.5	0.5
FILTER STATIC PRESSURE		
MOTOR		
AMPS	5.8	5.8
VOLTS	208	208
HORSEPOWER		
MOTOR SPEED	1725	1725

PROJECT

Berger Rehab

SYSTEM

A/C #1

READINGS BY

Brett Hopkins

JOB NUMBER

05K5128

FIELD FORMS AVAILABLE:

- Duct Traverse Report
- System Diagram
- Exhaust Fan Report
- Pulley Calculations

Temperature In 70
 Temperature Out 50
 Drop/Rise 20

DIFFUSERS AND GRILLS

Room	Outlet Number	Code	Size	Required CFM	Final CFM	% Of Design
	1		10	200	275	
	2		8	150	201	
	3		8	150	194	
	4		10	200	200	
	5		8	150	159	
	6		8	150	242	
	7		8	150	198	
	8		8	150	255	
	9		8	150	349	
	10		8	150	246	
	1					
	2					

REMARKS:

2003 NCI, INC.

Clarke & Rush Mechanical, Inc.

HVAC SYSTEM REPORT

4/21/2006

FAN NAMEPLATE DATA

MANUFACTURER Carrier
 MODEL 50HJQ006-521
 TYPE H.P. Pack
 SIZE 5Ton
 SERIAL NUMBER 0706G30580

FAN PULLEY DATA

DIAMETER 3
 SHAFT 3/4
 ADJ/FIXED fixed

MOTOR NAMEPLATE DATA

MANUFACTURER
 VOLTS/PHASE 208/3
 HORSEPOWER
 FULL LOADS AMPS 5.8
 RPM

MOTOR PULLEY DATA

DIAMETER 3
 SHAFT 3/4
 ADJ/FIXED Adjustable
 BELT NO. & SIZE A40

CONDENSING UNIT DATA

MANUFACTURER
 MODEL
 TONNAGE
 SERIAL NUMBER

FAN	DESIGN	ACTUAL
TOTAL CFM	2000	2260
RETURN AIR CFM	1830	1910
OUTSIDE AIR CFM	170	350
FAN SPEED	1725	
STATIC PRESSURE +	0.3	0.3
STATIC PRESSURE -	0.3	0.3
TOTAL STATIC PRESSURE	0.6	0.6
FILTER STATIC PRESSURE		
MOTOR		
AMPS	5.6	5.6
VOLTS	208	208
HORSEPOWER		
MOTOR SPEED		

FIELD FORMS AVAILABLE:

- Duct Traverse Report
 - System Diagram
 - Exhaust Fan Report
 - Pulley Calculations
- Temperature In 70
 Temperature Out 50
 Drop/Rise 20

DIFFUSERS AND GRILLS

Room	Outlet Number	Code	Size	Required CFM	Test 1	Final CFM	% Of Design
	1		8	150		147	
	2		8	150		140	
	3		8	150		148	
	4		8	150		152	
	5		8	200		210	
	6		10	200		198	
	7		10	250		235	
	8		6	50		49	
	9		6	50		47	
	10		10	250		243	
	1						

REMARKS:

2003 NCI, INC.

Clarke & Rush Mechanical, Inc.

PROJECT

Berger Rehab

SYSTEM

A/C #2

READINGS BY

Brett Hopkins

JOB NUMBER

05K5128

HVAC SYSTEM REPORT

4/19/2006

FAN NAMEPLATE DATA

MANUFACTURER Carrier
 MODEL 50HJQ006-521
 TYPE H.P. Pack
 SIZE 5Ton
 SERIAL NUMBER 0706G30581

FAN PULLEY DATA

DIAMETER 3
 SHAFT 3/4
 ADJ/FIXED Fixed

MOTOR NAMEPLATE DATA

MANUFACTURER
 VOLTS/PHASE 208/3
 HORSEPOWER
 FULL LOADS AMPS 5.8
 RPM 1725

MOTOR PULLEY DATA

DIAMETER 3
 SHAFT 1/2
 ADJ/FIXED Adjustable
 BELT NO. & SIZE A40

CONDENSING UNIT DATA

MANUFACTURER
 MODEL
 TONNAGE
 SERIAL NUMBER

FAN	DESIGN	ACTUAL
TOTAL CFM	2000	2256
RETURN AIR CFM	1830	1977
OUTSIDE AIR CFM	170	279
FAN SPEED	1725	
STATIC PRESSURE +	0.3	0.3
STATIC PRESSURE -	0.3	0.3
TOTAL STATIC PRESSURE	0.6	0.6
FILTER STATIC PRESSURE		
MOTOR		
AMPS	5.8	5.8
VOLTS	208	208
HORSEPOWER		
MOTOR SPEED		

PROJECT
Berger Rehab

SYSTEM
A/C #3

READINGS BY
Brett Hopkins

JOB NUMBER
05K5128

FIELD FORMS AVAILABLE:
 Duct Traverse Report
 System Diagram
 Exhaust Fan Report
 Pulley Calculations
 Temperature In 70
 Temperature Out 50
 Drop/Rise 20

DIFFUSERS AND GRILLS

Room	Outlet Number	Code	Size	Required CFM	Final CFM	% Of Design
	1		6	100	137	
	2		6	100	565	
	3		10	200	599	
	4		10	250	325	
	5		10	250	445	
	6		10	250	385	
	7		10	250	185	

REMARKS:

HVAC SYSTEM REPORT

4/19/2006

FAN NAMEPLATE DATA

MANUFACTURER Carrier
 MODEL 50HJD007-521
 TYPE H.P. Pack
 SIZE 6Ton
 SERIAL NUMBER 4405G40488

FAN PULLEY DATA

DIAMETER 3
 SHAFT 3/4

ADJ/FIXED Fixed

MOTOR NAMEPLATE DATA

MANUFACTURER
 VOLTS/PHASE 208/3
 HORSEPOWER
 FULL LOADS AMPS 5.8
 RPM 1725

MOTOR PULLEY DATA

DIAMETER 3
 SHAFT 3/4
 ADJ/FIXED Adjustable
 BELT NO. & SIZE A40

CONDENSING UNIT DATA

MANUFACTURER
 MODEL
 TONNAGE
 SERIAL NUMBER

FAN DESIGN ACTUAL

TOTAL CFM	2400	2506
RETURN AIR CFM	2130	2231
OUTSIDE AIR CFM	270	275
FAN SPEED	1725	1725
STATIC PRESSURE +	0.3	0.3
STATIC PRESSURE -	0.3	0.3
TOTAL STATIC PRESSURE	0.6	0.6
FILTER STATIC PRESSURE		

MOTOR

AMPS	5.8	5.5
VOLTS	208	208
HORSEPOWER		
MOTOR SPEED		

FIELD FORMS AVAILABLE:

- Duct Traverse Report
- System Diagram
- Exhaust Fan Report
- Pulley Calculations

Temperature In 70
 Temperature Out 50
 Drop/Rise 20

PROJECT

Berger Rehab

SYSTEM

A/C #4

READINGS BY

Brett Hopkins

JOB NUMBER

05K5128

DIFFUSERS AND GRILLS

Room	Outlet Number	Code	Size	Required CFM	Final CFM	% Of Design
	1		10	200	413	
	2		10	300	368	
	3		10	200	434	
	4		10	300	547	
	5		10	200	384	
	6		10	200	560	
	7		10	300		
	1			1065	1107	
	2			1065	1324	

REMARKS:

2003 NCI, INC.

Clarke & Rush Mechanical, Inc.