

CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 0200398

Insp Area: 1

Thos Bros: 297 D5

Site Address: 1220 S ST SAC

Parcel No: 009-0082-007 A,B,C,

Sub-Type: REM

Housing (Y/N): N

CONTRACTOR

BUZZ OATES CONSTRUCTION
8615 ELDER CREEK RD
SACRAMENTO CA 95828

OWNER

OATS/BENNING
8615 ELDER CREEK
SACRAMENTO CA 95828

ARCHITECT

Nature of Work: INTERIOR REMODEL 3 SPEC OFFICES ,A,B,& C.

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name Lender's Address

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class 0 License Number 796201 Date 1-11-02 Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractor's License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractor's License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractor's License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractor's License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractor's License Law).

I am exempt under Sec. B & PC for this reason:

Date Owner Signature

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 1-11-02 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations: I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

yes I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:


Carrier STATE FUND Policy Number 1625130 Exp Date 01/01/2003

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 1-11-02 Applicant Signature [Signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.



BUZZ OATES
AIR CONDITIONING, INC.

JOB NO. 1564

SECTION _____ PAGE 1

FAN & OUTLET TEST DATA

LOCATION SPEC OFFICE - 1220 S STREET SYSTEM AC 7

MOTOR NAMEPLATE DATA

MFG _____ FR _____
 HP _____ V _____ FLA _____
 PH _____ SF _____ RPM _____
 SHEAVE DATA: DIRECT DRIVE _____
 DIA _____ SHAFT _____
 ADJ _____ FIXED _____

FAN NAMEPLATE DATA

MFG YORK
 MODEL D1NH030N03625
 TYPE _____
 SIZE _____
 SHEAVE DATA:
 DIA _____ SHAFT _____ HUB _____
 BELTS _____
 STARTER _____ SIZE _____
 HEATERS _____


DATA ITEM	TEST 1	TEST 2	TEST 3
VOLTS			
AMPS			
BHP			
FAN RPM			
SP -			
SP +			
TSP ESP			
FILTER SP			
CFM TOTAL	1180	1085	
CFM RA	1000	900	
CFM OA	180	185	

FAN DESIGN DATA

TSP _____
 CFM 1000 ESP _____ RPM _____ BHP _____

ROOM	OPENING			FACTOR	DESIGN		TEST 1		TEST 2		TEST 3	
	NO.	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
	1	D	10x10			250		300		275		
	2	D	10x10			250		300		280		
	3	D	10x10			250		300		270		
	4	D	10x10			250		280		260		
	5	R	22x22			860		1000		900		

REMARKS: _____



BUZZ OATES
AIR CONDITIONING, INC.

FAN & OUTLET TEST DATA

LOCATION SPEC OFFICE - 1220 S STREET SYSTEM AC 8

MOTOR NAMEPLATE DATA
 MFG _____ FR _____
 HP _____ V _____ FLA _____
 PH _____ SF _____ RPM _____
 SHEAVE DATA: DIRECT DRIVE
 DIA _____ SHAFT _____
 ADJ _____ FIXED _____

FAN NAMEPLATE DATA
 MFG YORK
 MODEL DINH024N03606
 TYPE NLKM119361
 SIZE _____
 SHEAVE DATA:
 DIA _____ SHAFT _____ HUB _____
 BELTS _____
 STARTER _____ SIZE _____
 HEATERS _____


DATA ITEM	TEST 1	TEST 2	TEST 3
VOLTS			
AMPS			
BHP			
FAN RPM			
SP -			
SP +			
TSP ESP			
FILTER SP			
CFM TOTAL	950	860	
CFM RA	980	730	
CFM OA		130	

FAN DESIGN DATA

CFM 820 TSP _____ ESP _____ RPM _____ BHP _____

ROOM	OPENING			FACTOR	DESIGN		TEST 1		TEST 2		TEST 3	
	NO.	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
	6	D	12x12			410		465		440		
	7	D	12x12			410		485		420		
	8	R	22x22			720		980		730		

REMARKS: _____



BUZZ OATES
AIR CONDITIONING, INC.

JOB NO. 1564

SECTION PAGE 3

FAN & OUTLET TEST DATA

LOCATION SPEC OFFICE - 1220 S STREET

SYSTEM AC 9

MOTOR NAMEPLATE DATA

MFG _____ FR _____
HP _____ V _____ FLA _____
PH _____ SF _____ RPM _____
SHEAVE DATA: DIRECT DRIVE
DIA _____ SHAFT _____
ADJ _____ FIXED _____

FAN NAMEPLATE DATA

MFG YORK
MODEL DINHO36N03625
TYPE NBLMO12932
SIZE _____
SHEAVE DATA:
DIA _____ SHAFT _____ HUB _____
BELTS _____
STARTER _____ SIZE _____
HEATERS _____

DATA ITEM	TEST 1	TEST 2	TEST 3
VOLTS			
AMPS			
BHP			
FAN RPM			
SP -			
SP +			
TSP ESP			
FILTER SP			
CFM TOTAL	1300	1255	
CFM RA	1295	1025	
CFM OA	5	130	

FAN DESIGN DATA

CFM 1260 TSP _____
ESP _____ RPM _____ BHP _____

ROOM	OPENING			FACTOR	DESIGN		TEST 1		TEST 2		TEST 3	
	NO.	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
	9	D	10x10			315		300		310		
	10	D	10x10			315		300		315		
	11	D	10x10			315		280		310		
	12	D	10x10			315		420		320		
	13	R				285		270		285		
	14	R				836		1025		840		

REMARKS: