

Changed from Brick Veneer to Stucco R.H. Richter

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE VII BUILDINGS

PERMIT NO. 4854	LOCATION 15 Fair Park	2537 Sun Lane	
DATE	PURPOSE To Build 11. 90 sq. ft. garage	ROOMS 5	APTS. 1
OWNER Mrs. G.M. Beach	PHONE 3401-33		
ISSUED JUL 27 1929 SACRAMENTO BUILDING DIVISION	ADJUT. H.B. Bondsall		
	CONTR. J.D. Hornum	15284	
	4501	STORIES 1	SIZE 35 x 47 - 22

FOUNDATION	STORY	BSMT	1	2	3	ROOF	Chimneys	Cement Tests
Ex Wall	Joints							
Int Wall	Beams and Girders						Fire Place	
	Studs and Columns						Gas Water Heater	
Elera	Bridging						Heater Closet	
	Fire Stops						Furnace	Window Courts
	Fire Escape						Boiler Room	
	Stand Pipes						Elevator Shaft	
	Metal Lath							
	Stairs							

Changed from Brick Cement & Wood. P.H. Richter

DATE	CONDITION OF WORK—REMARKS
7/2/29	1 st N.S.P. Forms in place OK P.H. Richter
8/19/29	2 nd N.S.P. Frame in place OK P.H. Richter
8/21/29	3 rd N.S.P. Ext Lath in place OK P.H. Richter
8/24/29	3 rd N.S.P. Int Lath " " " P.H. Richter
1/21/30	4 th N.S.P. House Completed OK A.W. Campbell
	ISSUED CERTIFICATE OF OCCUPANCY #854
	Street cleaned up OK A.W. Campbell
	Above Certificate held up metal lintel installed through center of garage for under support of roof and screen put in
	Fence below floor and in roof studs installed to-day OK
1/21/30	COMPLETED AND O. K. <i>A.W. Campbell</i> INSPECTOR