

**BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD**

**TYPE VII BUILDINGS**

<b>PERMIT NO.</b> 3335	<b>LOCATION</b> 11 Kullerick Ter 2181 Miller Ave		
<b>DATE</b> 9/12/44	<b>PURPOSE</b> Fr. Res	<b>ROOMS</b> 2	<b>APTS.</b> 1
<b>ZONE</b>	<b>OWNER</b> J Semoni 2181 Miller		<b>PHONE</b>
	<b>ARCH'T</b>		
	<b>CONT'R</b>		
	<b>VAL.</b> 250	<b>STORIES</b>	<b>SIZE</b>

FOUNDATION	STORY	BSMT	1	2	3	ROOF	Chimneys	Cement Tests
Ex Wall	Jolsts							
	Beams and Girders						Fire Place	
Int Wall	Studs and Columns						Gas Water Heater	
	Bridging Fire Stops						Heater Closet	
Piers	Fire Escape Stand. Pipes						Furnace	Window Courts
	Metal Lath						Boiler Room	
	Stairs						Elevator Shaft	

DATE	CONDITION OF WORK—REMARKS
10/17/28	1 <sup>st</sup> /INSP. Forms for 2 Place Dolly (rear) OK H.W. Campbell
10/17/28	2 <sup>nd</sup> /INSP. Passage " " " " OK H.W. Campbell
10/25/28	Plasterboard walls & ceilings OK H.W. Campbell
12/18/28	Inspected outside Patent Chimney. Notified owner & put on another length on top. as chimney is too low. Said he would do it. H.W. Campbell
12/19/28	Said Metal man pleased. said he would add 1 more length to above chimney. Otherwise house completed except painting which owner will do at his spare time
	<p style="text-align: center;">COMPLETED AND O. K.</p> <p style="text-align: center;">H.W. Campbell</p> <p style="text-align: right;">INSPECTOR</p>