

Q 201 7114-116

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$10.00

TYPE BUILDINGS

| | | | | | |
|----------------------|----------|--------------------------------|-----------|-----------------|-------------------|
| PERMIT NO. F-5044 | LOCATION | 2060 - Railroad Avenue Drive. | | | A-6 |
| DATE Aug 11-66 | PURPOSE | Const. office partns. in whse. | | | |
| | OWNER | Oates & Benvenuti 6700-Folsom | | | |
| ZONE M-1 | ARCH'T | | | | |
| | CONTR | A-A Bldrs. 6700-Folsom | | | |
| VAL \$1,000. | STORIES | ROOMS | APTS. | SIZE | |
| INSP. | DATE | BLDG. TYPE | III-no hr | OCCUPANCY GROUP | F-2 PHONE (O) (C) |
| FORM | | | | | |
| JOIST | | | | | |
| FRAME | 8-17-66 | Miller | | | |
| SHEET ROCK | | | | | |
| FINAL | 8-27-67 | Peebles | | | |

201

ent

| DATE | SPECIAL CONDITIONS OF WORK — REMARKS |
|--------------------|--|
| 1-20-67 | P.T. Frame - no approved plans Court |
| 1-11-67 | P.T. Frame - many corrections Rials |
| 1-18-67 | P.T. Frame - Studs must be 16" O.C. 5/8" S.P. |
| | Required - Rials |
| 1-20-67 | Separation wall between school Bldg and floor covering li. H. Rials |
| 1-20-67 | P.T. S.P. - Studs must be 16" O.C. 5/8" S.P. Required. Rials |
| | |
| | |
| | |
| COMPLETE AND OK | INSPECTOR |