

CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 0114520

Insp Area: 3

Thos Bros: 317 H4

Sub-Type: HSG

Housing (Y/N): Y

Site Address: 5048 48TH ST SAC

Parcel No: 022-0136-003

CONTRACTOR

OWNER

LARRY ABEND

ARCHITECT

65536

Nature of Work: MINOR REPAIRS TO SINGLE FAMILY DWELLING

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class _____ License Number _____ Date _____ Contractor Signature _____

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

X I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

____ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

____ I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature *Larry Abend*

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

X Date *11-9-01* Applicant/Agent Signature *Larry Abend*

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

____ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

____ I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier

Policy Number

Exp Date

X (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

X Date *11-9-02* Applicant Signature *Larry Abend*

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

CityCode
Case Information Report
H000009752

January 24, 2002
Page 2 of 6

Case Report

Violations

Violation: Other

Status: Closed

Comments: THIS IS NOT A COMPLETE LIST. INSPECTOR DID NOT HAVE ACCESS TO INTERIOR. OTHER ITEMS MIGHT BE DISCOVERED THAT WILL NEED TO BE CORRECTED ONCE INSPECTIONS START. A PERMIT WILL BE REQUIRED FOR THE REPAIRS.

Violations

Violation: Attractive Nuisance. 8.100.230 (2)

Status: Closed

Comments: NEIGHBOR STATES THAT PEOPLE GAINING ACCESS TO THIS DWELLING THROUGH THE FRONT WINDOW.

Violation: General dilapidation or improper maintenance of the building. 8.100.560 (M)

Status: Closed

Comments: THE DWELLING IS SHOWING SOME SIGNS OF DIFFERED MAINTENANCE IN A FEW LOCATIONS.

Violation: Deteriorated or ineffective waterproofing of exterior walls, roof, foundation or floors including broken windows or doors. 8.100.620 (B)

Status: Closed

Comments: HOLE IN STUCCO NEAR FRONT ENTRY ALLOWING WATER INTRUSION. BROKEN FRONT WINDOW.

Violation: Exposed conductors, wire joints or energized equipment. 8.100.610

Status: Closed

Comments: NM CABLE EXPOSED AT BACK OF DWELLING AND RUNNING ACROSS THE GROUND TO SHED. EXPOSED WIRING AND OPEN SPLICES IN SHED.