

**CITY OF SACRAMENTO**  
1231 I Street, Sacramento, CA 95814

**Permit No: 0200230**  
**Insp Area: 2**  
Thos Bros:  
**Sub-Type: COM**  
**Housing (Y/N): N**

**Site Address: 5607 FREEPORT BL SAC**  
Parcel No: PARUNKN000

CONTRACTOR  
PARSONS ROOFING  
6740 FRUITRIDGE RD  
SAC CA 95820

OWNER  
JACK AKABORI  
1349 GAGLE WAY  
SACRAMENTO CA 95831

ARCHITECT

**Nature of Work: REROOF T/O 85 SQ INSTALL HOT ASPHALT BUR**

**CONSTRUCTION LENDING AGENCY :** I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name \_\_\_\_\_ Lender's Address \_\_\_\_\_


**LICENSED CONTRACTORS DECLARATION:** I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class \_\_\_\_\_ License Number 191647 Date \_\_\_\_\_ Contractor Signature \_\_\_\_\_


**OWNER-BUILDER DECLARATION:** I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

\_\_\_\_ I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)


\_\_\_\_ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044 Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

\_\_\_\_ I am exempt under Sec. \_\_\_\_\_ B & PC for this reason: \_\_\_\_\_  
✓ Date 1-7-02 Owner Signature 


**IN ISSUING THIS BUILDING PERMIT,** the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.  
✓ Date 1-9-02 Applicant/Agent Signature 

**WORKER'S COMPENSATION DECLARATION:** I hereby affirm under penalty of perjury one of the following declarations:  
\_\_\_\_ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

✓  I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE FUND Policy Number 285-02 UNIT 0001700 Exp Date 01/01/2003

\_\_\_\_ (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.  
✓ Date 1-9-02 Applicant Signature 

**WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.**

**THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.**

PERMIT NO. 0200230

CITY OF SACRAMENTO  
1231 I ST. ROOM 200  
BUILDING INSPECTIONS DIVISION

AREA NO. 2C

WHEN CORRECTIONS HAVE BEEN MADE, CALL 264-5191 FOR REINSPECTION OF WORK.

JOB LOCATION 5607 → Fireport Blvd - Page 1 of 3

INSPECTION REQUESTED Roof Final - Strip Wall

THE UNDERSIGNED  BUILDING  PLUMBING  MECHANICAL  ELECTRICAL  
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

13 Provide approved connection of electrical  
vaccuums.

14 Condensate line to terminate into drain pan.

15 Electrical line at West end < by brick wall >  
shall be proper terminate and supported  
against falls.

16 Tall round cooler at end of bldg. to have  
green flex line extended to nearest drain.

17 Four inch heat exhaust "B" vent shall have  
combustibles removed. < Fishband > Use storm  
collar of metal.

18 Electrical flex line on swamp cooler shall  
be attached to unit within 12" of entry  
into junction box.

INSPECTOR E. Clarys DATE 5/17/02

BUILDING INSPECTIONS 264-5716

INSPECTOR'S COPY

PERMIT NO.  
0200230

AREA NO.  
2C

CITY OF SACRAMENTO  
1231 I ST. ROOM 200  
BUILDING INSPECTIONS DIVISION

WHEN CORRECTIONS HAVE BEEN MADE, CALL 264-5191 FOR REINSPECTION OF WORK.

JOB LOCATION S607 Everport Blvd.

INSPECTION REQUESTED Roof Final 2 OF 3

THE UNDERSIGNED  BUILDING  PLUMBING  MECHANICAL  ELECTRICAL  
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

7) Swamp cooler to be leveled to prevent water spillage onto roof deck

8) Flexible raceway attached to swamp cooler to be supported off the roof deck.

9) Oval heat flues: front oval shall extend through the base flashing. Back oval near a touching gas line is damage. Replace damaged section.

10) Electrical raceways to be support at 4'-0"

11) Round 4" heat exhaust near back wall touching large 3" gas line: Remove combustibles from around flue, Felt's

12) Tall oval heat exhaust: Remove asphalt off

INSPECTOR E. Calver DATE 5/17/02

BUILDING INSPECTIONS 264-5716

INSPECTOR'S COPY

PERMIT NO. 0200230

CITY OF SACRAMENTO  
1231 I ST. ROOM 200  
BUILDING INSPECTIONS DIVISION

AREA NO. 2C

WHEN CORRECTIONS HAVE BEEN MADE, CALL 264-5191 FOR REINSPECTION OF WORK.

JOB LOCATION 5607 Fireport Blvd.

INSPECTION REQUESTED Roof Final 3 of 3

THE UNDERSIGNED  BUILDING  PLUMBING  MECHANICAL  ELECTRICAL  
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

13 Inspector stopped inspection...  
Too many items to list...  
Complete All detail work  
and re-call.  
Inspector will not give a  
punch list of items that  
should be complete at final.

INSPECTOR E. Collins DATE 5/17/02

BUILDING INSPECTIONS 264-5716

INSPECTOR'S COPY

PERMIT NO.  
0200230

CITY OF SACRAMENTO  
1231 I ST., ROOM 200  
BUILDING INSPECTIONS DIVISION

AREA NO.  
22

WHEN CORRECTIONS HAVE BEEN MADE, CALL 264-5191 FOR REINSPECTION OF WORK.

JOB LOCATION 5607 Flemons Blvd.

INSPECTION REQUESTED Roof in Progress  
THE UNDERSIGNED  BUILDING  PLUMBING  MECHANICAL  ELECTRICAL  
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

- ① Water Header Vent Pipe at Back of Building shall extend 12" above roof with listed pipe.
- ② 2" Soil Stack Vent shall extend up 6" with correct plumbing hardware

INSPECTOR Kyle Calvey DATE 5/9/02  
BUILDING INSPECTIONS 264-5716

INSPECTOR'S COPY