

②136 7539-544

| | | | | |
|----------------|---|--|-----------------|--------------------------------|
| Lot 94 | | BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD | | \$46.00 |
| Southfield #1 | | TYPE BUILDINGS | | ②164 779 |
| PERMIT NO. | - | | | |
| E-9997 | LOCATION 7569 - Tamoshanter Way | | A-5 | |
| DATE | PURPOSE Const. dwlg & att. gar. (Plan #9) | | | |
| Mar 22-65 | OWNER Grenz Const. Co. 4699-24th Street | | | |
| ZONE | ARCH'T | | | |
| R-1 | CONTR Owner 452-5931 | | | |
| VAL. \$12,600. | STORIES 1 | ROOMS 6 | APTS. | 484-gar. SIZE 1,256 sq. ft. |
| INSP. | DATE | BLDG. TYPE | OCCUPANCY GROUP | PHONE (O) (C) |
| FORM | 3-24-65 | Mr. Pellow | | |
| JOIST | 4-1-65 | G. Jansen | | |
| FRAME | 4-30-65 | Mr. Pellow | | |
| SHEET ROCK | 5-6-65 | Mr. Pellow | | |
| FINAL | 7-12-65 | Perlo | | |

| DATE | SPECIAL CONDITIONS OF WORK — REMARKS |
|---------|---|
| 3-30-65 | Membrane O.K. Fuller |
| 4-28-65 | Pt. of frame sliding glass must be tempered <i>Roller</i> |
| 4-2-65 | Pt. of frame - Sliding glass - Minimum |
| | clear height not tempered Fuller |
| 1-2-65 | Pt. of frame - Sliding glass in |
| | minimum - same Rule |
| 7-9-65 | Pt. of frame - Sliding glass not in Rule |
| | |
| | |
| | <div style="display: flex; justify-content: space-between;"> COMPLETE AND OK INSPECTOR </div> |