

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 0519957
Insp Area: 4
Thos Bros: 298A1

Site Address: 1455 RESPONSE RD SAC
Parcel No: 277-0287-003 SUITE 140

Sub-Type: REM
Housing (Y/N): N

CONTRACTOR
BROWNING CONSTRUCTION INC
9050 RANCHVIEW CT
SACRAMENTO CA 95624

OWNER
SCHOOLS FINL CREDIT UNION
PO BOX 194610
SAN FRANCISCO, CO 94119

ARCHITECT

Nature of Work: SUITE 140 - INTERIOR REMODEL FOR "THE JOHN STEWART CO."; 2480 SF; NON-SPRINKLERED

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect

X License Class B License Number 461321 Date 12/27/05 Contractor Signature David B...

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: _____
Date _____ Owner Signature _____

PAYED
CITY OF SACRAMENTO
DEC 27 2005

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 12/27/05 Applicant/Agent Signature David B...

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

DB I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE FUND Policy Number 713016444-2004 Exp Date 10/01/2006

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 12/27/05 Applicant Signature David B...

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.



INDOOR
ENVIRONMENTAL
SERVICES

AIR BALANCE REPORT

Job Name: JOHN STEWART Job # 2010385

Date 1/13/06

Tech: ART & BERNIE Air Hood: Analog #1
 Analog Digital #1
 Strtridge #1

Page 1 OF 3

UNIT	OUTLET	NO.	TYPE	SIZE	TOR	TEST 1		TEST 2		TEST 3	
						FPM	CFM	FPM	CFM	FPM	CFM
A-20		1	CEILING	8	80	100	180	110	100		
		2		10		265	170	270	250		
		3		10		220	220	250	210		
		4		10		235	270	230	260		
		5		10		220	240	240	200		
		6		10		215	270	220	200		
		7		10		220	230	210	200		
		8		10		210	290	210	190		
		9		10		215	140	240	200		
		10		12		205	260	230	190		
		11		12		205	220	240	190		
		12		8		210	120	140	210		
						2650	2610	2550	2400		

REMARKS

CARRIER
50420085-621
4505820352

MATERIAL



INDOOR
ENVIRONMENTAL
SERVICES

AIR BALANCE REPORT

Job Name: 1455 RESPONSE 3-1 Job # 200395

Date 1/9-1/10/06

Tech: BERNIE & ART Air Hood: Analog #1
 Digital #1
 Strtridge #1

Page 2 OF 3

UNIT	OUTLET NO.	TYPE	SIZE	VECTOR	TEST 1		TEST 2		TEST 3	
					FPM	CFM	FPM	CFM	FPM	CFM
<u>AC-3</u>	<u>1</u>	<u>CD</u>	<u>8"</u>		<u>125</u>	<u>90</u>	<u>110</u>	<u>120</u>		
	<u>2</u>		<u>10"</u>		<u>275</u>	<u>280</u>	<u>290</u>	<u>250</u>		
	<u>3</u>		<u>10"</u>		<u>275</u>	<u>110</u>	<u>120</u>	<u>260</u>		
	<u>4</u>		<u>8"</u>		<u>100</u>	<u>130</u>	<u>80</u>	<u>90</u>		
	<u>5</u>		<u>8"</u>		<u>150</u>	<u>100</u>	<u>110</u>	<u>140</u>		
	<u>6</u>		<u>8"</u>		<u>150</u>	<u>100</u>	<u>110</u>	<u>135</u>		
	<u>7</u>		<u>8"</u>		<u>150</u>	<u>110</u>	<u>110</u>	<u>135</u>		
					<u>1225</u>	<u>930</u>	<u>930</u>	<u>1130</u>		

REMARKS

CHANGED FAN MOTOR SPEED FROM LOW TO HIGH SPEED TO INCREASE AIR FLOW. STILL HAD LOW AIR FLOW. CHECK EXTERNAL STATIC TO FIND LARGE STATIC DROP DUE TO PLUGGED FILTER. LET JOHN KNOW FILTER NEEDS TO BE REPLACED (20X25X1 PLEATED). AMPED OUT MOTOR LOW 1.2 AMP TO HIGH 1.8 AMPS.

CAR REER
505X-042-611AD
2005F21408

MATERIAL



INDOOR
ENVIRONMENTAL
SERVICES

AIR BALANCE REPORT

Job Name: 1455 RESPONSE S-M Job # 20 0385

Date 1/9 - 1/10/06

Tech: BERNIE ANDERSON Air Hood: Analog #1
 Digital #1
 Strtridge #1

Page 3 OF 3

UNIT	OUTLET	NO.	TYPE	DIA.	MATERIAL	TEST 1		TEST 2		TEST 3	
						FPM	GFM	FPM	GFM	FPM	GFM
<u>AL-24</u>		<u>1</u>	<u>CD</u>	<u>10"</u>		<u>300</u>	<u>250</u>	<u>280</u>	<u>310</u>		
		<u>2</u>		<u>10"</u>		<u>300</u>	<u>240</u>	<u>280</u>	<u>310</u>		
		<u>3</u>		<u>10"</u>		<u>375</u>	<u>270</u>	<u>310</u>	<u>350</u>		
		<u>4</u>		<u>10"</u>		<u>310</u>	<u>290</u>	<u>320</u>	<u>310</u>		
		<u>5</u>		<u>10"</u>		<u>210</u>	<u>240</u>	<u>280</u>	<u>190</u>		
		<u>6</u>		<u>10"</u>		<u>210</u>	<u>240</u>	<u>310</u>	<u>190</u>		
		<u>7</u>		<u>10"</u>		<u>250</u>	<u>220</u>	<u>250</u>	<u>230</u>		
		<u>8</u>		<u>10"</u>		<u>250</u>	<u>220</u>	<u>250</u>	<u>230</u>		
		<u>9</u>		<u>12"</u>	<u>2 in PVC</u>	<u>320</u>	<u>160</u>	<u>190</u>	<u>290</u>		
		<u>10</u>		<u>12"</u>		<u>220</u>	<u>190</u>	<u>220</u>	<u>220</u>		
		<u>11</u>		<u>8"</u>		<u>120</u>	<u>50</u>	<u>100</u>	<u>100</u>		
		<u>12</u>		<u>8"</u>		<u>120</u>	<u>60</u>	<u>100</u>	<u>100</u>		
						<u>2985</u>	<u>2430</u>	<u>2890</u>	<u>3060</u>		

REMARKS

INCREASED AIR FLOW BY ADJUSTING SHW TO
CRANK MOTOR AND FLOW FROM 2.9 AMPS TO 3.4 AMPS
CARRIER

5045 0008-621

4505120883

MATERIAL