

CITY OF SACRAMENTO

Permit No: 0507112

1231 I Street, Sacramento, CA 95814

Insp Area: 2

Site Address: 5710 35TH ST SAC

Thos Bros:

Parcel No: 026-0011-093

Sub-Type: NCOM

Housing (Y/N): N

CONTRACTOR

**OWNER BUILDER
RAMIREZ CHARLES & LORRAINE A
P.O. BOX 189340 95818**

OWNER

**RAMIREZ CHARLES & LORRAINE A
P.O. BOX 189340
SACRAMENTO, CA 95818**

ARCHITECT

Nature of Work: NEW 9,000 SF WAREHOUSE 1,040 SF OFFICE.

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class _____ License Number C000005935 Date _____ Contractor Signature _____

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

**CITY OF SACRAMENTO
NEIGHBORHOODS PLANNING
AND DEVELOPMENT SERVICES
JAN 13 2006**

I am exempt under Sec. _____ B & PC for this reason: _____

Date 1-13-06 Owner Signature

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 1-3-06 Applicant/Agent Signature

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier _____ Policy Number _____ Exp Date _____

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date _____ Applicant Signature _____

WARNING: FAILURE TO SECURE WORKERS COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.



CITY OF SACRAMENTO

www.cityofsacramento.org

Help Line: 1-916-808-5656 OR 1-866-EZ-PERMIT
Inspection: 1-916-808-7622

Downtown Permit Center
1231 I Street, Suite 200
Sacramento, CA 95814

North Permit Center
2101 Arena Blvd., Suite 200
Sacramento, CA 95834

OWNER BUILDER VERIFICATION

1. Check one below - I or my immediate family (parent, spouse, or child) will perform:

- A - [X] all the work authorized by this permit.
B - [] a portion of the work.
C - [] none of the work.

If B or C is checked, complete 2 or 3 below.

2. A State licensed contractor (*) will be hired to do:

[] all of the authorized work.

PAID
CITY OF SACRAMENTO

JAN 13 2006

[] NEIGHBORHOOD PLANNING AND DEVELOPMENT SERVICES

Name _____ Phone _____

Address _____

Type of Work _____

Name _____ Phone _____

Address _____

Type of Work _____

Name _____ Phone _____

Address _____

Type of Work _____

Name _____ Phone _____

Address _____

Type of Work _____

3. [] I will utilize unlicensed person(s) other than my immediate family to perform all or portions of the authorized work. A Certificate of Workers Compensation must be on file at this office.

I declare under penalty of perjury that the above is true and correct. I have read and understand the owner-builder information on the reverse side of this form.

Signed: Property Owner Carlos L. Ramirez (Printed name) [Signature] (Signature)

Date 1-13-06 Case No. _____ Permit No. _____

Job Address 5710 35th St So, Ca 95824

Note: * Information regarding unknown contractors or change in subcontractors shall be submitted to the Building Inspection field office.

MM

0507112



Environmental • Geotechnical • Special Inspections • Materials Testing

TERRASEARCH INC.

SERVING NORTHERN CALIFORNIA SINCE 1969

September 5, 2007

Project Number: 11218.S

Mr. Bob Newton
Newton Associates, General Contractors-Engineers
P.O. Box 160273
Sacramento, Ca 95816

SAN JOSE
322 Fiercy Road
San Jose, CA 95138
Phone: (408) 362-4920
Fax: (408) 362-4926

LIVERMORE
257 Wright Brothers Ave.
Livermore, CA 94551
Phone: (925) 243-6662
Fax: (925) 243-6663

SACRAMENTO
4200 N. Freeway Blvd.
Suite 2
Sacramento, CA 95834
Phone: (916) 564-7809
Fax: (916) 564-7672

OAKLAND
7700 Edgewater Drive
Suite 842
Oakland, CA 94621
Phone: (510) 633-1332
Fax: (408) 362-4926

FRESNO
4339 N. Golden State Blvd.
Suite 103
Fresno, CA 93722
Phone: (559) 271-0773
Fax: (559) 271-0763

WEBSITE
www.terrasearchinc.com

E-MAIL
info@terrasearchinc.com

Subject: **FINAL REPORT OF SPECIAL INSPECTION SERVICES**
5785 36th Street
Sacramento, Ca

Dear Mr. Newton:

At your request, **TERRASEARCH, INC.** has provided testing and inspection services on the above referenced site. The following inspections provided are in accordance with the Uniform Building Code, section 1701 as required by the City of Sacramento. The testing was performed on 8/17/06 and 8/18/06. It is understood that no other work on these lots requiring special inspection services was needed or required.

The scope of services performed included:

- Proofload Testing on 3/4" Diameter A325 Bolts per Structural Engineer requirements as noted on approved plans.

The observations were performed by personnel under the general supervision of a registered civil engineer. Based upon the observations performed and our substantiating reports, it is our professional judgment that the observed work was performed to the best of our knowledge in accordance with the on site approved project plans and specifications, relevant revisions and the applicable workmanship provisions of the Uniform Building Code.

We trust that the information provided herewith will satisfy your present needs. Should you require additional information or have any questions, please contact our office.

Respectfully submitted,
Terrasearch, Inc.


Johan A. Jacobsen, P.E.
Sacramento Engineering Manager

For Inspection thru

Permit #: **0507112**

Location: 026-0011-093
 DBA: RAMIREZ CHARLES & LORRAINE A
 P.O. BOX 189340
 SACRAMENTO, CA 95818
 916-551-1800

Owner: RAMIREZ CHARLES & LORRAINE A
 P.O. BOX 189340
 SACRAMENTO, CA 95818
 916-551-1800

Contractor: OWNER BUILDER
 RAMIREZ CHARLES & LORRAINE A
 P.O. BOX 189340
 SACRAMENTO, CA 95818
 916-551-1800

JOB DESCRIPTION: NEW 9,000 SF WAREHOUSE 1,040 SF OFFICE.

BLDG Y MECH Y PLBG Y ELEC Y SITE Y FIRE Y COMB

CONDITIONS:
 Cond: 101

FRJ - Sprinkler Monitoring
 Entry: 12/20/2005 By: GAL Action: NOTE DEFERRED
 Cond: 200

I - Overheads - Plans
 Entry: 12/20/2005 By: GAL Action: NOTE DEFERRED
 Cond: 201

FRJ - Fire Sprinkler U/G
 Cond: 207

FRJ - Fire Extinguishers
 Cond: 701

FRJ - Knox Box
 Cond: X1.12

SPI - Bolts installed in concrete
 Cond: X1.20

SPI - High strength bolting
 provisions of Section 3700 of the Labor Code. I shall forthwith comply with those provisions.

Date: _____ Applicant: _____
 (Signature)

WARNING: FAILURE TO SECURE WORKERS' COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEES.

TOTAL FEES \$

INSPECTION	INSPECTION	INSPECTOR	DATE
B10 FOUNDATION FORMS	1/0	D. P. [Signature]	6-13-06
E60/B11 UFER GROUND			6-23-06
B12 CONCRETE SLAB FORMS			6-16-06
P40 PLUMB. UNDERFLOOR/SLAB			
M30 MECH/UNDERFLOOR/SLAB			
E61 ELECT. UNDERGROUND			
E62 ELECT. CONDUIT-SLAB			
B13 DO NOT COVER UNTIL INSTALLATION ABOVE HAS BEEN SIGNED			
FLOOR JOISTS OR GIRDERS			
B14 DO NOT INSTALL SUB FLOOR UNTIL ABOVE HAS BEEN SIGNED			
INSULATION/WALL/FLOOR			6-4-07
P41 TOP PLUMBING			3/19/07
M31 TOP MECHANICAL/WALL/CEIL.			5/17/07
E63 ROUGH ELECTRICAL/WALL/CEIL.			5-18-07
B19 FRAME			10-31-06
B17 ROOF PLYWOOD NAIL, COMM. & APTS.			
B18 EXTERIOR LATH/SIDING			
B22 DO NOT COVER UNTIL INSTALLATION ABOVE HAS BEEN SIGNED			
INT. LATH OR WALL BD. NAILING			10-20-07
E66 DO NOT TAPE PLASTER OR TOP UNTIL ABOVE HAS BEEN SIGNED			
P43 SERVICE UNDERGRD CONDUIT			12/5/06
P42 WATER SERVICE			3-7-06
P46 SPRINKLER SYSTEM			
P47 GAS TEST			
E68 TEMP. GAS			
E67 TEMP. POWER #	4848A		1-5-07
SWIMMING POOLS ONLY			
P47 GAS TEST			
P51 PLUMBING PRE-GUNITE			
P52 PLUMBING PRE-DECK			
E70 ELECTRICAL PRE-GUNITE			
E71 ELECTRICAL PRE-DECK			
E72 ELECTRICAL UNDERGRD			
DO NOT COVER UNTIL INSTALLATION ABOVE HAS BEEN SIGNED			
ENERGY COMPLIANCE CERTIFICATE TO BE ON FILE PRIOR TO FINAL APPROVAL.			
DATE: _____ SIGNED: _____			
FINAL APPROVALS			
B29 BUILDING	9-6-07	[Signature]	
E79 ELECTRICAL		[Signature]	
P59 PLUMBING		[Signature]	
M39 MECHANICAL		[Signature]	
F94 FIRE		[Signature]	
S92 SITE		[Signature]	

INSPECTION REQ'D PRIOR TO SIGNOFF
 2087223

PA. OK 10
 12-27-06

1-10-07

1-10-07

1-10-07

1-10-07

1-10-07

1-10-07

DO NOT OCCUPY BUILDING UNTIL ALL OF THE ABOVE HAVE BEEN SIGNED AND CERTIFICATE OF OCCUPANCY ISSUED
 THIS CARD TO BE POSTED ON JOB AT ALL TIMES UNTIL FINAL APPROVAL.

POSTED IN A CONSPICUOUS PLACE!

SACRAMENTO CITY FIRE DEPARTMENT
2101 ARENA BLVD., STE 200
SACRAMENTO, CA 95834

POSTED IN A CONSPICUOUS PLACE!

PERMIT

977-7702

F.D.

Rebecca

24 HOUR
MINIMUM

INSPECTION SERVICES
24 HOUR INSPECTIONS REQUEST LINE CALL (916) 808-1643
MINIMUM OF 48 HOURS NOTICE REQUIRED FOR INSPECTIONS / APPOINTMENTS

CALL (916) 808-1643
INSPECTIONS / APPOINTMENTS

PERMIT
SCOPE OF
ADDRESS
JOB NAME
CONTRACT

PERMIT 05 07116 CHECKED BY GFL DATE 12/28/08
SCOPE OF WORK Warehouse
ADDRESS 5710 35th St / 10th Ave
JOB NAME Warehouse
CONTRACT Owner/Bld. PHONE 916-551-1800

DATE 12/28/08
10th Ave
16-551-1800

1) Do not
sign
2) All
hy
co

- NOTE:
- 1) Do not cover walls or ceiling or bury piping until the following items are signed off.
 - 2) An all weather (paved) emergency access roadway and operating fire hydrants shall be provided prior to any combustible storage or construction on site.

the following items are
day and operating fire
ible storage or

SITE

INSPECTIONS	INITIALS	DATE
Underground Fire Mains/Visual (Class 200)	<u>MCM/2236</u>	<u>08-27-07</u>
Hydrostatic test of Fire Main (Class 200)	<u>MCM/2236</u>	<u>08-22-07</u>
Flushing of Fire Main (Class 200)	<u>GFL</u>	<u>9/24/07</u>
Access/Fire Lane/Stripping		
Gates/Fence/Knox		
Above ground tank		

INITIALS	DATE
<u>MCM</u>	<u>11-26-08</u>
<u>WT</u>	<u>12-26-08</u>

See other side

FIRE & LIFE SAFETY

INSPECTIONS	INITIALS	DATE
Fire Doors		
Smoke Venting		
High Piled Stock		
Flammable liquids		
Hazardous Materials		
Special Hazards		
Posted signs for occupant load		

INITIALS	DATE

EQUIPMENT

INSPECTIONS	INITIALS	DATE
Fire Sprinkler System Piping/Visual	<u>MCM</u>	<u>8-31-07</u>
Fire Sprinkler Hydrostatic Test	<u>MCM</u>	<u>8-31-07</u>
Standpipes		
Fire Alarms		
Fire Sprinkler Monitoring System		
Fire Alarm Monitoring System		
Kitchen Hood & Duct System		
Special Extinguishing System		
Fire Extinguishers	<u>MCM/2236</u>	<u>08-22-07</u>
Fire Pumps		

INITIALS	DATE

5755

SPECIAL REQUIREMENTS

INITIALS	DATE

INITIALS	DATE

FINAL APPROVAL

Fire Department Approval [Signature] 8-31-07

Department may result in the issuance of
permises.

NOTICE: Failure to comply with an order of the Fire Department may result in the issuance of
a citation and/or discontinued use of the building or premises.

ORIGINAL CARD TO BE POSTED AT THE WORK SITE

KEEP THIS CARD FOR REFERENCE—THIS IS YOUR RECORD OF FIELD INSPECTIONS

There is a \$25.00 fee for replacement/lost cards

ED AT THE WORK SITE

R RECORD OF FIELD INSPECTIONS

placement/lost cards

Permit #

CITY FIRE DEPARTMENT
ARENA BLVD., STE 200
SACRAMENTO, CA 95834

FIRE DEPARTMENT
AVENUE, STE 200
SACRAMENTO, CA 95834

F.D.
Mark
Rebecca

INSPECTION SERVICES
 24 HOUR INSPECTIONS REQUEST LINE CALL (916) 808-1643
MINIMUM OF 48 HOURS NOTICE REQUIRED FOR INSPECTIONS / APPOINTMENTS

SERVICES
 24 HOUR INSPECTIONS REQUEST LINE CALL (916) 808-1643
MINIMUM OF 48 HOURS NOTICE REQUIRED FOR INSPECTIONS / APPOINTMENTS

PERMIT# 0709214 CHECKED BY LCE DATE 12/24/06
 SCOPE OF WORK Fire Sprinkler Maint.
 ADDRESS 5755 35th St.
 JOB NAME _____
 CONTRACTOR _____ PHONE _____

BY GAL DATE 12/28/06
house / office
SF / office
 PHONE 916-551-1800

- NOTE:**
- 1) Do not cover walls or ceiling or bury piping until the following items are signed off.
 - 2) An all weather (paved) emergency access roadway and operating fire hydrants shall be provided prior to any combustible storage or construction on site.

- NOTE:**
- 1) Do not cover walls or ceiling or bury piping until the following items are signed off.
 - 2) An all weather (paved) emergency access roadway and operating fire hydrants shall be provided prior to any combustible storage or construction on site.

SITE

INSPECTIONS	INITIALS	DATE
Underground Fire Mains/Visual (Class 200)	201	
Hydrostatic test of Fire Main (Class 200)	201	
Flushing of Fire Main (Class 200)	201	
Access/Fire Lane/Striping	701	
Gates/Fences/Knox	701	
Above ground tank	600	

SITE

INSPECTIONS	INITIALS	DATE
Underground Fire Mains/Visual (Class 200)	201	12-26-06
Hydrostatic test of Fire Main (Class 200)	201	12-26-06
Flushing of Fire Main (Class 200)	201	
Access/Fire Lane/Striping	701	
Gates/Fences/Knox	701	
Above ground tank	600	

see other side

FIRE & LIFE SAFETY

INSPECTIONS	INITIALS	DATE
Fire Doors		
Smoke Venting		
High Piled Stock		
Flammable liquids		
Hazardous Materials		
Special Hazards		
Posted signs for occupant load		

FIRE & LIFE SAFETY

INSPECTIONS	INITIALS	DATE
Fire Doors		
Smoke Venting		
High Piled Stock		
Flammable liquids		
Hazardous Materials		
Special Hazards		
Posted signs for occupant load		

EQUIPMENT

INSPECTIONS	INITIALS	DATE
Fire Sprinkler System Piping/Visual	200	
Fire Sprinkler Hydrostatic Test	200	
Standpipes	200	
Fire Alarms	100	
Fire Sprinkler Monitoring System	101	12/24/06
Fire Alarm Monitoring System	102	
Kitchen Hood & Duct System	311	
Special Extinguishing System	308	
Fire Extinguishers	194	
Fire Pumps	202	

EQUIPMENT

INSPECTIONS	INITIALS	DATE
Fire Sprinkler System Piping/Visual	200	
Fire Sprinkler Hydrostatic Test	200	
Standpipes	200	
Fire Alarms	100	
Fire Sprinkler Monitoring System	101	
Fire Alarm Monitoring System	102	
Kitchen Hood & Duct System	311	
Special Extinguishing System	308	
Fire Extinguishers	194	
Fire Pumps	202	

5755

SPECIAL REQUIREMENTS

INSPECTIONS	INITIALS	DATE

SPECIAL REQUIREMENTS

INSPECTIONS	INITIALS	DATE

FINAL APPROVAL
 Fire Department Approval 12/28/06 08-22-07

FINAL APPROVAL
 Fire Department Approval _____

NOTICE: Failure to comply with an order of the Fire Department may result in the issuance of a citation and/or discontinued use of the building or premises.

NOTICE: Failure to comply with an order of the Fire Department may result in the issuance of a citation and/or discontinued use of the building or premises.

ORIGINAL CARD TO BE POSTED AT THE WORK SITE

ORIGINAL CARD TO BE POSTED AT THE WORK SITE

KEEP THIS CARD FOR REFERENCE-THIS IS YOUR RECORD OF FIELD INSPECTIONS

KEEP THIS CARD FOR REFERENCE-THIS IS YOUR RECORD OF FIELD INSPECTIONS

There is a \$25.00 fee for replacement/lost cards

There is a \$25.00 fee for replacement/lost cards

Permit #

CITY OF SACRAMENTO

CERTIFICATE OF OCCUPANCY

For Information Contact (916) 808-5716

Building Address:	5755 35TH ST	Permit No:	0507112
Site Location:		Occupancy:	S-2,B
Building Use:	Industrial	Construction Type:	V-N
Building Owner:	RAMIREZ CHARLES & LORRAINE A	Sprinkled?	No
		Area (sqft):	10040

Portion of Building Occupied: Entire

Exception(s): None

09/06/2007

Brian Krinke 

Carl Hefner

Date

By: (Print)

(Sign)

ASSISTANT BUILDING OFFICIAL

This Certificate, issued pursuant to the requirements of Section 109 of the Uniform Building Code, certifies that at time of issuance the described portion of the building has been inspected for compliance with the Uniform Building Code, as adopted per Title 15 of the Sacramento City Code for the group and division of occupancy and use for which the proposed occupancy is classified. Issuance of this certificate shall not be construed as an approval of the violation of any Codes, or Federal, State and City Laws or Ordinances. Certificates presuming to give authority to such violation shall not be valid. This certificate shall be posted in a conspicuous place on the premises and shall not be removed except by the Chief Building Official. No changes shall be made in the character of occupancy or use without approval of the Chief Building Official.

POST IN A CONSPICUOUS PLACE

CIRCO System Balance, Inc.

Contractor License #624117

AIR - HYDRONIC - TEMPERATURE - SOUND - SYSTEM SURVEY

4100 FLORIN-PERKINS RD.

SACRAMENTO, CA. 95826

(916) 387-5100

FAX (916) 387-5101

AUGUST 23, 2007

807-146-B1

AIR BALANCE REPORT

JOHNNY TOWING & BODY

5755 35TH STREET

SACRAMENTO, CALIFORNIA

Permit # 0507112

CONTRACTOR: OWNER

ENGINEER: ROBERT NEWTON

TEST PERFORMED BY: ALTON HARDIN

INDEPENDENT BALANCING SINCE 1963

TABLE OF CONTENTS

SECTION	DESCRIPTION
1.	REMARKS CONCERNING BALANCING PROCEDURES
2.	OFFICE DATA

INDEPENDENT BALANCING SINCE 1963

CIRCO System Balance, Inc.

SB JOB# 146
 SECTION 2 PAGE 1
 DATE August 23, 2007

FAN & OUTLET TEST SHEET

AREA SERVED OFFICE UNIT -

MOTOR NAMEPLATE DATA

MFG - FR -
 HP - V 230 FLA 4.3
 PH 1 SF - RPM -

DATA	TEST 1	TEST 2	TEST 3
VOLTS	-	218.2	
AMPS	-	4.3	
B.H.P.	-	-	
SPEED	LOW	HIGH	
S.P. -	-	0.22	
S.P. +	-	1.00	
T.S.P.	-	1.22	
FILTER S.P.	-	-	
CFM TOTAL	-	-	
CFM R.A.	-	-	
CFM O.A.	-	-	

FAN NAMEPLATE DATA

MFG CARRIER
 MODEL # 48XZ030060311
 TYPE DWDI, FC
 SIZE -

FAN DESIGN DATA

CFM - SP - RPM - BHP -
 MIN. O.A. -

ROOM	OPENING			FACTOR	DESIGN		TEST 1		TEST 2		TEST 3	
	NO.	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
OFFICE	1	CSD	12x6					100	150			160
OFFICE	2	CSD	12x6					160	225			300
OFFICE	3	CSD	12x6					50	85			100
TOILET	4	CSD	12x6					30	90			30
								---	---			---
								340	550			590
		RAG	20x24					390	520			380
		OSA						0	30			2100

REMARKS: _____

CIRCO System Balance, Inc.

SB JOB# 146
 SECTION 2 PAGE 2
 DATE August 23, 2007

FAN & OUTLET TEST SHEET

AREA SERVED RECEPTION UNIT -

MOTOR NAMEPLATE DATA

MFG - FR -
 HP - V 230 FLA 2.0
 PH 1 SF - RPM -

DATA	TEST 1	TEST 2	TEST 3
VOLTS	-	216.3	
AMPS	-	1.7	
B.H.P.	-	-	
SPEED	LOW	HIGH	
S.P. -	-	0.20	
S.P. +	-	0.72	
T.S.P.	-	-	
FILTER S.P.	-	-	
CFM TOTAL	-	-	
CFM R.A.	-	-	
CFM O.A.	-	-	

FAN NAMEPLATE DATA

MFG CARRIER
 MODEL # 48SD-030060301
 TYPE DWDI, FC
 SIZE -

FAN DESIGN DATA

CFM - SP - RPM - BHP -
 MIN. O.A. -

ROOM	OPENING			FACTOR	DESIGN		TEST 1		TEST 2		TEST 3	
	NO.	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
RECEPTION	1	CSD	12x6					180		220		250
RECEPTION	2	CSD	12x6					120		165		180
RECEPTION	3	CSD	12x6					100		120		160
TOILET	4	CSD	12x6					-		50		40
								---		---		---
								-		555		630
		RAG	20x24					450		570		440
		OSA						0		0		190

REMARKS: _____