

CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 0311655

Insp Area: 4
Thos Bros: 277 B5

Site Address: 2833 AZEVEDO DR SAC
Parcel No: 225-0624-001

Sub-Type: RES
Housing (Y/N): N

CONTRACTOR
VALLEY CONSTRUCTION
PO BOX 1164
FAIR OAKS, CA 95628

OWNER
GUTIERREZ MARIA
SACRAMENTO CA
95834-8571

ARCHITECT

Nature of Work: REROOF T/O RESHT SNGL STRY 20 SQ INSTALL 30YR DIM LAM COMP

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class C39 License Number 674523 Date 8/07/03 Contractor Signature George Vargas

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

PAID
CITY OF SACRAMENTO
AUG 07 2003
CENTER

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvements to be constructed do not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 8/07/03 Applicant/Agent Signature George Vargas

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE FUND Policy Number 229-0022752 Exp Date 01/01/2004

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 8/07/03 Applicant Signature George Vargas

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

Pacific Consulting Engineers

2150 Bell Ave., Suite 145 • Sacramento, CA 95838 • (916) 564-6028 • Fax: (916) 564-6029

August 6, 2003

Jorge Vasquez
Valley Construction

RE: Re-roof at 1/2 of Duplex at 2833 Azavedo, Sacramento, CA
This inspection and letter is our Job # 03-1056.

Per your request, I performed a visual inspection of existing roof framing at the aforementioned residence. The purpose was to determine if the existing roof framing is acceptable to support a light weight tile (6 psf max installed weight) instead of the existing wood shake.

The residence is a 1/2 of a one story duplex with standard living area and an attached garage. Attachment #1 shows a sketch of the roof plan with approximate dimensions.

The existing roof framing was in good condition and consisted of Wood shake over felt over 1x skip sheathing over pre-fabricated trusses spaced at 24" c.c.. The existing top chords on the trusses were 2x4 #2 DF. The maximum span of the truss top chords was 6'-6".

Attachment 1 is a sketch of the roof plan and shows the approximate dimensions of the exterior walls of the house. Attachment 2 contains the calculations regarding the dead load to the top chord of the trusses and the maximum allowable span of the existing 2x4 top chords.

It is my understanding that during the re-roof process, the existing shake and felt will be removed, then a layer of 7/16" or 15/32" APA rated, 24/16, sheathing will be placed over the 1x skip sheathing, 30# felt will be placed, and then the light weight tile (6.0 psf maximum installed weight) will be placed per the manufactures instructions.

Thus, it is my professional opinion that it is acceptable if all layers of the existing roof coverings and felt are removed, plywood (osb) is placed, new 30# felt placed, and then re-roofed with a light weight tile with an installed weight of 6 psf or less.


If you have any questions or need further clarification on these matters please feel free to contact me at

(916) 564-6028
City of Sacramento

Sincerely,
AUG 12 2003

NORTH PERMIT
CENTER

Jeffrey E. Hofmann, P.E.



CITY OF SACRAMENTO
NORTH PERMIT
CENTER

AUG 12 2003

RECEIVED


CITY OF SACRAMENTO

Area 4

0311655

Handwritten notes: "OK", "Rosa", "SJS"

No. 937 811E
Engineer's Computation Pad



SKETCH OF ROOF (1/2 OF DUPLEX - 2833 AZAVERO)

SCALE 1" = 10'



EXISTING ROOF: WOOD SHAKE over 1x SKIP over TRUSSES @ 24" cc

NEW ROOF: LT WT TILE (6.3 P/SF) over 7/16" SITS over 1x SKIP over TRUSSES @ 24" cc.

JCH

8/6/03

REROOF @

2833 AZAVEDO

03-1056

ATTACH 2/2

DETERMINE NEW DEAD LOAD TO TRUSS TOP CHORDS10.0 PSF = TOTAL DEAD LOAD

6.0 PSF = LIGHT WT TILE, (6 PSF INSTALLED WT)

0.3 PSF = 30# FELT

1.13 PSF = 7/16" SHTG - New

1.25 PSF = (E) 1x SKIP SHTG OR 3/8" SHTG

0.65 PSF = 2x4 (TOP CHORD) @ 24" CC.

0.5 PSF = MISC

L, WT OF NEW ROOF CONFIGURATION IS W/IN
NORMAL DESIGN WEIGHT FOR ROOF
- EXISTING FRAMING IS ACCEPTABLE

CHECK MAX SPAN OF (E) 2x4 TRUSS TOP CHORD

NOTE: HOUSE BUILT PRIOR TO 1994 UBC THUS OLDER
WOOD ALLOWABLE STRESSES APPLICABLE.

#2DF $\rightarrow F_v = 95 \text{ PSI}$ $f_b = 1450 \text{ PSI (RCP)}$ $E = 1.7 \times 10^6 \text{ PSI}$ 2x4 $\rightarrow A = 5.25 \text{ IN}^2$ $S_x = 3.06 \text{ IN}^3$ $I = 5.36 \text{ IN}^4$

ACTUAL MAX SPAN OF TOP CHORD = 6'-6"

WTL = 2'(16+10 PSP) = 52 PLF

SHEAR $V_{ALL} = \frac{5.25 \text{ IN}^2 (95) (1.25)}{1.5} = 416 \#$

$$L_{MAX} = \frac{2(416)}{2'(16+10)} = 16' = L_{MAX} (SHR)$$

BENDING $M_{ALL} = \frac{3.06 \text{ IN}^3 (1450 \text{ PSI}) (1.25)}{12} = 462 \text{ Lb-ft}$

$$L_{MAX} = \sqrt{\frac{8(462)}{52}} = 8'-5" = L_{MAX} (BEND)$$



DEFLECTION: $\Delta_{ALL} = \frac{L}{180}$ $\Delta_{ALL} = \frac{L}{240}$ (NO CEILING ATTACHMENT)

(TOTAL LOAD CONTROL)

$$\Delta_{ALL} = \frac{L(12)}{180} = \frac{5(52)(L)^4 (1728)}{384 (1.7 \times 10^6) (5.36)}$$

$$L_{MAX} = \sqrt[3]{\frac{12(384) (1.7 \times 10^6) (5.36)}{180(5)(52)(1728)}} = 8.03' = L_{MAX} (DEF)$$

∴ ALLOWABLE MAX SPAN OF 8' EXCEEDS MAXIMUM ACTUAL
SPAN OF 6'-6"



Mission San Juan • LMC 8404




Mission San Diego (brushed) • LMC 8645b



Mission Santa Barbara (brushed) • LMC 8403b



Mission Santa Cruz • LMC 8402



Mission Carmel (brushed) • LMC 8807b

Capistrano Tile Series

Camino Real Specifications



Tiles per 100 sq ft. with 3" headlap	88.5
Approximate installed weight field tile per 100 sq ft.	570

CITY OF SACRAMENTO
NORTH PERMIT
CENTER

AUG 12 2005 Camino Real Collection from EAGLE ROOFING PRODUCTS

RECEIVED

allows you to enjoy the beauty of Southwestern styling with the durability and affordability of concrete. Echoing the architecture of the early Spanish missions, this Southwestern style tile collection boasts two distinctly different looks. A smooth surface and a textured brushed surface. The brushed colors are truly reminiscent of old world buildings. Our time tested techniques have allowed us to create an authentic, rustic appearance.

0311655

ROOFING QUESTIONNAIRE

Applicant's name: Valley Construction Phone: 984-1058
Project Address: 2833 AZEVEDO DR 225-0624-001

Please check the appropriate boxes. Only check a box if it accurately and completely describes your proposed work, otherwise leave boxes blank.

1. ROOFING TYPE

a. The existing roofing material is composition shingle, wood shake or shingle, tile or metal. The new roofing material shall be:

Existing Proposed

- | | | |
|-------------------------------------|-------------------------------------|--|
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | 30 year laminated dimensional composition |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | wood shake or shingle |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | tile |
| <input type="checkbox"/> | <input type="checkbox"/> | metal that simulates one of the above listed materials |

b. The existing roofing material is built up, foam or membrane with a roof pitch of 2:12 or less. The new roofing material shall be:

Existing Proposed

- | | | |
|--------------------------|--------------------------|----------|
| <input type="checkbox"/> | <input type="checkbox"/> | Built up |
| <input type="checkbox"/> | <input type="checkbox"/> | Foam |
| <input type="checkbox"/> | <input type="checkbox"/> | Membrane |

2. GUTTERS

a. The existing gutters are fascia gutters.

- There is no change proposed to existing gutters.
- New fascia gutters shall be provided.
- Gutters shall be repaired and/or replaced to match existing.

b. The existing gutters are Ogee gutters.

- There is no change proposed to existing gutters.
- New Ogee gutters shall be provided.
- Gutters shall be repaired and/or replaced to match existing.

c. There are no existing gutters.

- No new gutters are proposed.
- New Ogee gutters shall be provided.

3. RAFTER TAILS

a. There are no exposed rafter tails.

b. There are exposed rafter tails.

- There is no change or cutting proposed to existing rafter tails.
- Rafter tails shall be repaired and replaced to match existing.

By signing below, the applicant certifies that this form accurately describes the proposed work.

Applicant's signature: [Signature]

Date: 8/9/03

For City Staff use only

Counter Staff [Signature]

- In a DR District Meets DR criteria? Yes No (route to DR staff)
- In a P area or listed (route to P staff)
- Not in DR/P area

EXPANDED NORTH