

CITY OF SACRAMENTO

Permit No: 0309935

1231 I Street, Sacramento, CA 95814

Insp Area: 4

Thos Bros: 277 G7

Site Address: 200 SOUTHGATE RD SAC

Sub-Type: RES

Parcel No: 275-0173-001

2030 EDGEWATER RD (DUPLEX)

Housing (Y/N):

N

CONTRACTOR

MONARCH ROOFING INC
8250 ALPINE AV #H
SACRAMENTO, CA 95831

OWNER

CHRISTIE WILLIAM M
1927
SACRAMENTO CA 95814

ARCHITECT

Nature of Work: TEAR OFF WOOD SHAKE, INSTALL THERMOSHEATHING & HAT CHANNEL, REROOF W/EAGLE LITE TILE (45 SQ'S)

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class C39 License Number 806787 Date 7-7-03 Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovesentitled property for inspection purposes.

Date 7-7-03 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier AU INSURANCE SERVICE Policy Number 005-00012565 Exp Date 01/01/2004

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 7-7-03 Applicant Signature [Signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

PAID
CITY OF SACRAMENTO
JUL 07 2003
NORTH PERMIT

Christi

Paul Zacher - Structural Engineers, Inc
4701 Lakeside Way
Fair Oaks, CA 95628

TEL: 916.961.3960
FAX: 916.961.6552


R

July 3, 2003

ISSUED
City of Sacramento

Monarch Roofing
8250 Alpine Avenue, Suite H
Sacramento, CA 95826
TEL: (916) 978-3182
FAX: (916) 452-5140

JUL 07 2003
NORTH PERMIT
CENTER



Attn.: Mr. Neal Weber,

re: Job 2003200: CHRISTI

Subject: Structural Investigation Report of the Roof for the Residence located at 2030 Edgewater Road/
200 Southgate, Sacramento, CA 95815.

As requested by Mr. Neal Weber, this is a report to determine what needs should be addressed to correct any structural deficiencies of the roof. Paul Zacher visited the site July 3, 2003. The investigation was made to determine the existing condition of the structure. All information, data and analysis contained within this report are based on the 1997 Uniform Building Code with 2001 CBC Title 24 Amendments.

The following is based on visual observations with no subsurface investigation being made.

DESCRIPTION:

Type of Facility: Residence.
Year Built: Estimated 1980's vintage.
Occupancy: Residential.
No. of Stories: Two.
Dimensions: Approximately 3000 square feet.



This set of plans and specifications must be kept on the job at all times and it is unlawful to make any changes or alterations from the same without written permission from the Building Inspection Division.

The approval of this plan and specification SHALL NOT be held to permit or approve a violation of any City Ordinance or State Law.

CONSTRUCTION:

Roof:

The roof covering will consist of a Light Weight Concrete Tile over a batten system. The roof structure is conventionally framed with 2x8 rafters spaced at 16" and 24" on center except for the vaulted ceiling areas. The vaulted ceiling is constructed of 2x8 rafters spaced at 16" on center supported at the ridge by a 6x beam.

CONCLUSIONS:

Roof:

The roof structure currently lacks sufficient structural capacity for the applied live and dead loads. See "Recommendations" for location and repair of the roof structure up to the required capacity.

P
R
E
P
A
R
E
D
B
Y
P
A
U
L
Z
A
C
H
E
R
S
E
P
T
E
M
B
E
R
2
0
0
3

O.P.C. REVIEW
x THO 7/7/03
THESE PLANS SUBJECT TO FIELD APPROVALS

Christi



Paul Zacher - Structural Engineers, Inc
4701 Lakeside Way
Fair Oaks, CA 95628

TEL: 916.961.3960
FAX: 916.961.6552

RECOMMENDATIONS:

If any of the following recommendations do not correspond to actual field conditions, the engineer of record shall be notified for further investigation and evaluation before continuing work.

Roof Structure:

1. Scab a 1 3/4" x 11 1/4" LVL to the existing header. See details 1 and 2.


It shall be noted that small hairline cracking may occur at exterior stucco and interior gypboard finished walls that are load bearing or distributing roof strut loads. These cracks are a natural occurrence as the existing structure re-distributes the new roof weight. They are cosmetic in nature and are not an indication of a structural hazard or failure.

It shall be noted that some deflection of the rafters may be evident after installation of the tile. The existing roof framing has deflected but this may not be readily evident due to the uneven nature of the existing roofing material. Concrete tile is a very consistent and uniform product and when installed in an even plane, even small deflections can become apparent. This is only a cosmetic issue and not a structural concern.

The inspection consisted of visual observation only, made solely to determine the structural capacity of the existing roof. Analysis does not determine any effects on the overall structure under lateral forces or effects on the foundation unless specifically noted in the calculations and in this document. No warranties, expressed or implied, are made or intended in conjunction with this report. The inspection was made only to the portions that were accessible. The specific items noted were those that were observable and there may be defects that are not observable, or are hidden by architectural and structural materials.

If you have any questions on the above, do not hesitate to call.

Sincerely,


Paul Zacher, P.E., S.E.
file

DESIGN LOADING:

Roof Pitch 6 in 12
Pitch Adjustment Factor 1.12

LOCATION: ROOF BATTEN SYTEM

<u>MATERIAL</u>	<u>WEIGHT</u>	
Light Weight Tile	7.30	psf
Roofing felt	0.30	psf
1x4 skip sht'g	1.09	psf
Batten system	0.50	psf
2x8 rafters @ 24" oc	<u>1.32</u>	psf
Load	10.5	psf
Roof Pitch Adjustment	<u>1.24</u>	psf
Total Load	11.8	psf

LOCATION: VAULT BATTEN SYSTEM

<u>MATERIAL</u>	<u>WEIGHT</u>	
Light Weight Tile	7.30	psf
Roofing felt	0.30	psf
Batten system	0.50	psf
1x4 skip sht'g	1.09	psf
2x8 rafters @ 16" oc	1.99	psf
Batt/blown insul	0.50	psf
1/2" Gypboard	<u>2.50</u>	psf
Load	14.2	psf
Roof Pitch Adjustment	<u>1.67</u>	psf
Total Load	15.9	psf

Job #: 0m.200

Date: 7/2/0m


LOADING:

B0 F10R

$Dr = 11.8 \text{ pLF} \times 20 = 236 \text{ pLF}$ $2 \times 8'' \times 2$

$Lr = 16.0 \text{ } \dots = 32 \text{ } \dots$

236/32




B1 F10R

$Dr = 11.8 \text{ pLF} \times 4/3 = 157 \text{ pLF}$ $2 \times 8'' \times 2$

$Lr = 16.0 \text{ } \dots = 21.3 \text{ } \dots$

157/21.3




B1 VAVLI

$Dr = 15.9 \text{ pLF} \times 4/3 = 212 \text{ pLF}$ $2 \times 8'' \times 2$

$Lr = 16.0 \text{ } \dots = 21.3 \text{ } \dots$

212/21.3




B1

$Dr = 15.9 \text{ pLF} \times 12' = 199 \text{ pLF}$ $6 \times 14'' \times 1$

$Lr = 16.0 \text{ } \dots = 200 \text{ } \dots$

199/200




B2

$Dr = 15.9 \text{ pLF} \times 14' = 221 \text{ pLF}$ $6 \times 12'' \times 1$

$Lr = 16.0 \text{ } \dots = 232 \text{ } \dots$

231/232




B2

$Dr = 11.8 \text{ pLF} \times 3' = 35 \text{ pLF}$ $4 \times 12'' \times 1$

$Lr = 16.0 \text{ } \dots = 48 \text{ } \dots$

35/48




B4

$Dr = 11.8 \text{ pLF} \times 9' = 106 \text{ pLF}$ $4 \times 14'' \times 2$

$Lr = 16.0 \text{ } \dots = 144 \text{ } \dots + 13/4 \times 11 \times 8 \text{ LVL}$

106/144



Paul Zacher - Structural Engr's
 4701 Lakeside Way
 Fair Oaks, CA 95628
 TEL: (916) 961-3960
 FAX: (916) 961-6552

Title :
 Dsgnr:
 Description :
 Scope :

Job #
 Date: 1:29PM, 3 JUL 03

Rev: 560100
 User: KW-0602844, Ver 5.6.1, 25-Oct-2002
 (c)1983-2002 ENERCALC Engineering Software

Timber Beam & Joist

c:\paulpk and assoc\test ecw\Calculations

Description RAFTERS AND BEAMS


Timber Member Information		Calculations are designed to 1997 NDS and 1997 UBC Requirements						
		rafter	rafter	vault	B1	B2	B3	B4
		2x8	2x8	2x8	6x14	6x12	4x12	4x12#2 + 1
Timber Section		2x8	2x8	2x8	6x14	6x12	4x12	4x12#2 + 1
Beam Width	in	1.500	1.500	1.500	5.500	5.500	3.500	5.250
Beam Depth	in	7.250	7.250	7.250	13.500	11.500	11.250	11.250
Le: Unbraced Length	ft	0.00	0.00	0.00	0.00	2.00	2.00	0.00
Timber Grade		Douglas Fir - Larch	Douglas Fir - Larch	Douglas Fir - Larch	Douglas Fir - Larch	Douglas Fir - Larch	Douglas Fir - Larch	Custom, DF#2 + LVL
Fb - Basic Allow	psi	875.0	875.0	875.0	1,350.0	1,350.0	1,000.0	1,450.0
Fv - Basic Allow	psi	95.0	95.0	95.0	85.0	85.0	95.0	158.0
Elastic Modulus	ksi	1,600.0	1,600.0	1,600.0	1,600.0	1,600.0	1,700.0	1,666.7
Load Duration Factor		1.250	1.250	1.250	1.250	1.250	1.250	1.250
Member Type		Sawn	Sawn	Sawn	Sawn	Sawn	Sawn	Manuf/Pine
Repetitive Status		Repetitive	Repetitive	Repetitive	No	No	No	No

Center Span Data								
		rafter	rafter	vault	B1	B2	B3	B4
Span	ft	15.25	18.25	15.75	20.00	13.00	15.50	16.00
Dead Load	#/ft	23.60	15.70	21.20	199.00	231.00	35.00	106.00
Live Load	#/ft	32.00	21.30	21.30	200.00	232.00	48.00	144.00

Results		Ratio =	0.9779	0.9320	0.7973	0.8604	0.5751	0.2960	0.4783
Mmax @ Center	in-k		19.40	18.48	15.81	239.40	117.37	29.91	96.00
@ X =	ft		7.62	9.12	7.87	10.00	6.50	7.75	8.00
f _b : Actual	psi		1,476.0	1,406.7	1,203.4	1,433.0	968.2	405.1	866.9
F _b : Allowable	psi		1,509.4	1,509.4	1,509.4	1,665.6	1,683.5	1,368.8	1,812.5
			Bending OK	Bending OK	Bending OK	Bending OK	Bending OK	Bending OK	Bending OK
f _v : Actual	psi		54.3	43.6	42.8	71.6	61.1	21.6	45.1
F _v : Allowable	psi		118.8	118.8	118.8	106.3	106.3	118.8	197.5
			Shear OK	Shear OK	Shear OK	Shear OK	Shear OK	Shear OK	Shear OK

Reactions									
		rafter	rafter	vault	B1	B2	B3	B4	
@ Left End	DL	lbs	179.95	143.26	166.95	1,990.00	1,501.50	271.25	848.00
	LL	lbs	244.00	194.36	167.74	2,000.00	1,508.00	372.00	1,152.00
	Max. DL+LL	lbs	423.95	337.62	334.69	3,990.00	3,009.50	643.25	2,000.00
@ Right End	DL	lbs	179.95	143.26	166.95	1,990.00	1,501.50	271.25	848.00
	LL	lbs	244.00	194.36	167.74	2,000.00	1,508.00	372.00	1,152.00
	Max. DL+LL	lbs	423.95	337.62	334.69	3,990.00	3,009.50	643.25	2,000.00

Deflections		Ratio OK	Deflection OK	Deflection OK	Deflection OK	Deflection OK	Deflection OK	Deflection OK
Center DL Defl	in	-0.377	-0.514	-0.385	-0.397	-0.133	-0.064	-0.151
L/Defl Ratio		485.7	426.0	490.8	604.5	1,172.1	2,889.0	1,275.3
Center LL Defl	in	-0.511	-0.698	-0.387	-0.399	-0.134	-0.088	-0.205
L/Defl Ratio		358.2	314.0	488.5	601.4	1,167.0	2,106.5	938.8
Center Total Defl	in	-0.888	-1.212	-0.772	-0.796	-0.267	-0.153	-0.355
Location	ft	7.625	9.125	7.875	10.000	6.500	7.750	8.000
L/Defl Ratio		206.1	180.7	244.8	301.5	584.8	1,218.2	540.7



FRAMING NOTES:

1. Scab a 1 3/4" x 11 1/4" LVL to the existing 4x14 beam. See detail 2.

Notes:


- A. This is a reroof project. The new roofing material shall be a Light Weight Concrete Tile. The tile shall weigh less than or equal to 7.3 psf.
- B. All rafters are 2x8 DF#2 and hips and valleys are 2x10 DF#2 unless otherwise noted.
- C. All existing rafter, hips, valleys, rafter ties, and purlins are braced per UBC Section 2320.1 "Roof and Ceiling Framing" unless otherwise shown.
- D. All structural wood members that were observed appear to be in sound condition and without structural defect.




ROOF PLAN - CHRISTI

Not to Scale





ELEVATION



SECTION




2

HEADER DETAIL

scale: 1 1/2" = 1'-0"

7

FLASHING DETAIL @ WALL



FLASHING

PRESSURE SENSITIVE TAPE

2\"/>

HAT CHANNEL

EXIST WALL FINISH

EXIST WALL LITE

EXIST SKIP SNTG.

EXIST PARTIAL DECK
RAIP CHOP

