

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE VII BUILDINGS

PERMIT NO. 555A	LOCATION 700 SAN ANTONIO WAY		
DATE 11/18/29	PURPOSE Install E.C. BASEMENT and Build EXT. DICKS Chimney	ROOMS	APTS.
ZONE 2-Family Dist	OWNER A. H. SMITH	PHONE	
	ARCH'T		
	CONT'R OWNER		
	VAL. 125⁰⁰	STORIES	SIZE

FOUNDATION	STORY	BSMT	1	2	3	ROOF			
EX WALL	Jolts						Chimneys		Cement Tests
	Beams and Girders						Fire Place		
Int Wall	Studs and Columns						Gas Water Heater		
	Bridging Fire Stops						Heater Closet		
Piers	Fire Escape Stand Pipes						Furnace		Window Courts
	Metal Lath						Boiler Room		
	Stairs						Elevator Shaft		

DATE	CONDITION OF WORK—REMARKS
11/25/29	Inspected forms for excavated basement under near part of driveway.
	Also inspected exterior fireplace chimney.
	Brockman advised to make same with Ex 8
	Flue - T. C. lined. Notified him he could not use
	same for Wood & Coal furnace. Changed same to
	Ex 12 as required by Bldg. Code. OK. Al Campbell
	<p data-bbox="338 837 491 881">COMPLETED AND O.K.</p> <p data-bbox="1169 864 1307 884">INSPECTOR</p>