

R-219 - F-373 - 383

Blk. 10		BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD			\$170.00
Parcel 11		TYPE BUILDINGS			
N. Sact. Sub. #2		<i>R-219 F-373-275-Sub</i>			
PERMIT NO. F-7752	LOCATION	1576 - Silica Avenue		A-6	
DATE June 28-67	PURPOSE	Const. office & whse bldg. for sign co.			
ZONE M-1	OWNER	Pacific Neon 909-Fee Drive			
	ARCH'T	Rickey & Brooks 2636-Fulton Ave.			
	CONTR	Lance Const. 4093-Bridge St., F.O.			
VAL. \$67,000.	STORIES	ROOMS	APTS.	1625-2nd fl. SIZE 8,000 sq. ft.	
INSP.	DATE	BLDG. TYPE III-no hr.	OCCUPANCY GROUP F-2	PHONE (O) (C) 961-1290	
FORM	<i>7-11-67</i>	<i>Barbato's main bldg 5721-67 clark P.O.</i>			
JOIST					
FRAME	<i>11-3-67</i>	<i>Barbato's</i>			
SHEET ROCK	<i>11-29-67</i>	<i>Barbato's 11-30-67 Barbato's</i>			
FINAL	<i>7-23-68</i>	<i>C. Johnson int 4-3-68 bc</i>			

DATE	SPECIAL CONDITIONS OF WORK — REMARKS	
7-14-67	Plt slab - not ready	Barbato
7-23-67	Plt 6 panels	Salamone
7-31-67	Plt 6 panels	Barbato
8-3-67	Plt all panels	Barbato
8-15-67	Don't pass any inspections until	
	cleared by engineer	
8-24-67	Plt slab - not ready	Salamone Barbato
8-25-67	Plt tell us	
9-13-67	Plt columns	
9-29-67	Plt east-west wall on 7 <sup>th</sup>	
10-9-67	Left note to call. Check fuel Certificate	
10-18-67	COMPLETE 4' x 9' BO AND OK	Barbato INSPECTOR
11-2-67	Plt west wall - now structure	



Blk. 10		BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD			\$170.00
Parcel 11		TYPE BUILDINGS			Card #2
N. Sacto. Sub #2					
PERMIT NO.					
F-7752	LOCATION	1576 - Silica Avenue A-6			
DATE	PURPOSE	Const. office & Whse bldg. for sign co.			
June 28-67	OWNER	Pacific Neon 909 - Fee Drive			
ZONE	ARCH'T	Rickey & Brooks 2636 - Fulton Avenue			
M-1	CONT'R	Lance Const. 4093-Bridge St. F.O.			
VAL.	STORIES	ROOMS	APTS.	SIZE	
INSP.	DATE	BLDG. TYPE	OCCUPANCY GROUP	PHONE (O) (C)	
FORM					
JOIST					
FRAME					
SHEET ROCK					
FINAL					

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
1-8-67	Mc roof nail Barbrots
1-8-68	Pt Column steel must be bed @ 12" o.c. Chapin
1-11-68	Pt 7 mil. Plant planters. Roof water must connect to storm sewer. Provide permanent address. Label bottles Chapin
5-3-68	Letter sent SF 5-24-68 Chapin
5-28-68	working on 2nd protection of columns SF 6-11-68 Chapin
1-11-68	Roof matter does not drain to roof. (covered) will correct SF 6-15-68 Chapin
	COMPLETE AND OK
	INSPECTOR

