

CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 0304250

Insp Area: 1

Thos Bros: 297 J4

Site Address: 4901 D ST SAC

Parcel No: 004-0201-028

Sub-Type: NSFR

Housing (Y/N): N

CONTRACTOR

PAUL MENARD ASSOCIATES  
PO BOX 1005  
CARMICHEAL CA 95609

OWNER

IMBERI WAYNE & LEONE BARBARA A  
4901 D ST  
SACRAMENTO CA 95819

ARCHITECT

Nature of Work: RES NEW 2ND STRY ADDITION W/1ST FLR REBUILD

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name \_\_\_\_\_ Lender's Address \_\_\_\_\_

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

X License Class B License Number 638300 X Date 5/19/03 X Contractor Signature Michael...

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. \_\_\_\_\_ B & PC for this reason: \_\_\_\_\_  
Date \_\_\_\_\_ Owner Signature \_\_\_\_\_

PAID  
CITY OF SACRAMENTO  
MAY 19 2003

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

X Date 5/19/03 X Applicant/Agent Signature Michael...

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE FUND Policy Number 692-01 UNIT 0002567 Exp Date 10/01/2003

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

X Date 5/19/03 X Applicant Signature Michael...

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

City of Sacramento Planning Division  
**PLANNING REVIEW FOR BUILDING PERMIT SUBMITTAL**

ADDRESS: 4901 D Street	APN: 004-0201-028
DRPB AREA / PUD / SPD: NA	ZONING: R1
EXISTING LAND USE: SFR	
PROPOSED USE: 2 <sup>nd</sup> floor addition, 1 <sup>st</sup> floor living addition, new front & rear porch	
<p><u>PLANNING STAFF WILL CHECK ONE OR MORE OF THE ITEMS BELOW:</u></p> <p><input type="checkbox"/> Planning review is NOT required.</p> <p><input type="checkbox"/> Use is NOT allowed; applicant CANNOT submit for plan check.</p> <p><input type="checkbox"/> Requires APPLICATION(s):    PC            ZA            IR            ER            DR            PB</p> <p style="padding-left: 40px;">Required Planning application must be submitted <i>before</i> project can be submitted for plan check.</p> <p><input type="checkbox"/> Application(s) IN PROGRESS:</p> <p style="padding-left: 40px;">Applicant may submit for concurrent building permit plan check, at applicant's risk. DO NOT issue building permit prior to end of 10 day appeal period following approval. Building permit must conform to approved plans and comply with all conditions of approval.</p> <hr/> <p><input type="checkbox"/> Application(s) COMPLETED:</p> <p style="padding-left: 40px;">Building permit must conform to approved plans and comply with all conditions of approval.</p> <p><input type="checkbox"/> OK to submit for plan check. Plan checker(s) shall confirm compliance with Zoning Ordinance requirements and all applicable development standards <i>prior to issuance</i> of building permit.</p> <p><input checked="" type="checkbox"/> Meets setback &amp; lot coverage requirements as shown on site plan provided.</p> <p><input checked="" type="checkbox"/> Plans to be submitted have been stamped by Planning counter staff.</p> <p><input type="checkbox"/> Route to SITE for plan check and inspection.</p> <p><input type="checkbox"/> Preliminary review ONLY; <b>must be confirmed</b> at the time of building permit submittal.</p>	
<p>COMMENTS: Lot Area 6150 – Existing House 1243, Garage 414, New porches &amp; 1<sup>st</sup> fl living 588 = 2245</p> <p>Lot Coverage = 36%</p> <p style="text-align: center; font-size: 1.5em; font-family: cursive;">L. Hay</p>	
DATE: 4/1/03	BY: Linda Hay

**Certification of Compliance**  
School District Development

**Part I—To be completed by the APPLICANT**

Owner's Name/Address PARRERA LOPEZ  
Project Address 1101 D STREET  
Parcel Number 09-0001-000 Lot No. \_\_\_\_\_  
Subdivision Name \_\_\_\_\_ No. of Units \_\_\_\_\_  
Applicant's Signature [Signature] Title ARCHITECT  
Phone No. (716) 459-7116 Date 5/14/03

**Notice to Applicant:** Pursuant to Government Code Section 66020(d), this will serve to notify you that the 90-day approval period in which you may protest the fees or other payment identified above will begin to run on the date in which the building or installation permit for this project is issued or on which they are paid to the district(s) or to another public entity authorized to collect them on behalf of the district(s), whichever is earlier.

**Part II—To be completed by the BUILDING DEPARTMENT**

Plan Identification Number 0304250  
Building Type (check one)  Residential  Apartment/Condominium  Commercial/Industrial  
Square Feet of Chargeable Building Area 2498  
Signature/Title [Signature] Date 4-24-03

**Part III—To be completed by the SCHOOL DISTRICT**

School District 0000 Certificate No. 1001  
 Exempt Comments \_\_\_\_\_  
Residential/Apartment/etc. \_\_\_\_\_ Square ft. x \$ \_\_\_\_\_ = \$ \_\_\_\_\_  
Commercial/Industrial \_\_\_\_\_ Square ft. x \$ \_\_\_\_\_ = \$ \_\_\_\_\_  
Total fees collected..... = \$ \_\_\_\_\_

*This certification covers only the amount of square footage indicated above. Any additions or corrections to the square footage for this project will require an amendment to the Certificate of Compliance.*

*As the authorized school official, I hereby certify that the requirements of Government Code Section 65995 and any other authorized requirements have been complied with by the above signed applicant.*

Signature [Signature] Date 5/14/03



CAPITOL ENGINEERING LABORATORIES, INC.

631 Commerce Drive, Suite #200 • Roseville, California 95678 • (916) 786-2488

JOB REPORT

PAGE: \_\_\_\_\_

PROJECT NAME: Menard Misc.

FILE NO. 5191

INSPECTOR: J. Rele

DATE: 6-16-03

PERSONS CONTACTED: Michael DERN

PERMIT #: \_\_\_\_\_

REFERENCE DOCUMENTS: PLANS

WEATHER: \_\_\_\_\_

SERVICE PROVIDED: CONCRETE (INSP/SAMPLE ONLY/PU)  MASONRY  WELDING (SHOP/FIELD)  SOILS

OTHER  EPOXY SET ANCHORS

Witness cleaning of predrilled holes - 7" Embedment - And  
EPOXY SET INSTALLATION of EIGHT HD'S AND 24 - 5/8"  $\phi$   
ANCHOR BOLTS. SIX 5/8"  $\phi$  HD'S AND TWO 3/4"  $\phi$  HD'S WERE  
~~USED~~ - installed, 3/4"  $\phi$  HD'S WERE installed because holes drilled AT  
N.E. Shear wall were too large for 5/8"  $\phi$  bolts.  
SIMPSON-STRONG-TIE epoxy was used with expiration dates  
of 7/2004 and 8/2004.

COMPLIANCE OF WORK: OK

ATTACHMENTS: \_\_\_\_\_

EQUIPMENT/SUPPLIES USED: \_\_\_\_\_

NEXT VISIT: Will call

REMARKS: \_\_\_\_\_

REVIEWED BY: \_\_\_\_\_ DATE: \_\_\_\_\_