

**CITY OF SACRAMENTO**

**1231 I Street, Sacramento, CA 95814**

**Permit No: 0008423**

**Insp Area: 4**

**Site Address: 10 OPUS CR SAC**

Parcel No: 225-1360-035

LOT 35 GATEWAY W 5

Sub-Type: NSFR

Housing (Y/N): N

**CONTRACTOR**

BEAZER HOMES  
3009 DOUGLAS BL #150  
ROSEVILLE CA 95661

**OWNER**

**ARCHITECT**

**Nature of Work: NSFR MP1872 7 RMS**

**CONSTRUCTION LENDING AGENCY:** I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name \_\_\_\_\_ Lender's Address \_\_\_\_\_

**LICENSED CONTRACTORS DECLARATION:** I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class B License Number 724191 Date 8/1/00 Contractor Signature Sheuy VanMaen

**OWNER-BUILDER DECLARATION:** I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00):

\_\_\_\_ I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code). The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

\_\_\_\_ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code). The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. \_\_\_\_\_ B & PC for this reason: \_\_\_\_\_  
Date \_\_\_\_\_ Owner Signature \_\_\_\_\_

**IN ISSUING THIS BUILDING PERMIT,** the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the above mentioned property for inspection purposes.  
Date 8/1/00 Applicant/Agent Signature Sheuy VanMaen

**WORKER'S COMPENSATION DECLARATION:** I hereby affirm under penalty of perjury one of the following declarations:  
I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.


I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:  
Carrier LIBERTY MUTUAL INS CO. Policy Number WA2-651-004147-080 Exp Date 4/1/2001

\_\_\_\_ (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation law of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall comply with those provisions.  
Date 8/1/00 Applicant Signature Sheuy VanMaen


**WARNING - FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION. DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.**

**THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.**

THIS PLOT PLAN IS NOT FOR SALES PURPOSES. THIS PLOT PLAN IS FOR THE PURPOSES OF INDICATING COMPLIANCE WITH ZONING SET BACKS, GENERAL DRAINAGE DIRECTION, AND APPROXIMATE UTILITY CONNECTION. ALL OTHER DATA SHOWN HEREON IS CONCEPTUAL. THIS PLOT PLAN DOES NOT REFLECT AS-BUILT CONDITION, RETAINING WALL ARE OPTIONAL AND MAY OR MAY NOT BE CONSTRUCTED.



STEMMLER DRIVE



RETAINING/APPROVAL	
DATE	INITIALS
✓	
✓	JD
✓	AW

☐ = UTILITY SERVICE BOX

LOT COVERAGE = 32.1%

**PLOT PLAN**  
**LOT 35**  
 GATEWAY WEST VILLAGE NO.5  
 FOR  
 BEAZER HOMES  
 CITY OF SACRAMENTO CALIFORNIA

**WOOD-RODGER INC.**

DATE: JULY2000	DRAWN: D.P.B.	CHECKED: JDH 7-15-00	PROJECT NO: 1031.017
-------------------	------------------	----------------------------	-------------------------

## RESIDENTIAL BUILDING PERMIT APPLICATION

New Construction    
  Addition    
  Remodels    
  Other

Project Address: 10 Opus Circle    
 Assessor Parcel # 225-13635

**OWNER INFORMATION:**

Legal Property Owner: Beazer Homes     Phone # 773 3888  
 Owner Address: 3009 Douglas Blvd #150     City Roseville     State CA     Zip 95661

**CONTRACTOR INFORMATION:**

Contractor: Beazer Homes     Lic. # 724191     Phone # 773 3888     Fax # 773 0425

**PROJECT INFORMATION:**

Land Use Zone _____	Occupancy Group _____	Construction Type _____	Fed Code _____
No. of stories: <u>1</u>	No. of rooms: _____	Street width: _____	
1 <sup>st</sup> Floor Area <u>1872</u>	2 <sup>nd</sup> Floor Area <u>0</u>	Basement <u>0</u>	Roof Material _____

AREA IN SQUARE FOOT OF:	EXISTING	NEW
Dwelling/Living	_____	<u>1872</u>
Garage/Storage	_____	<u>68</u>
Decks/Balconies	_____	<u>0</u>
Carports	_____	<u>0</u>

SCOPE OF WORK: NEW SFD Lot 35

**FOR OFFICE USE ONLY**

- |   |   |  |
|---|---|--|
| <input type="checkbox"/> Information above complete | <input type="checkbox"/> AR Flood Waiver required             | <input type="checkbox"/> Planning Approval                   |
| <input type="checkbox"/> Violation files checked    | <input type="checkbox"/> Flood Elevation Certificate Required | <input type="checkbox"/> Design Review Approval              |
| <input type="checkbox"/> Standard setbacks          | <input type="checkbox"/> Water Development Infill Area        | <input type="checkbox"/> Special Fee Districts Apply : _____ |
| <input type="checkbox"/> County Sewer               |   |  |

**NEW STRUCTURES & ADDITIONS**

◆ THE FOLLOWING MUST BE PROVIDED IN ORDER TO SUBMIT FOR PLAN REVIEW

- |   |   |
|---|---|
| <input type="checkbox"/> 2 COMPLETE PLANS, LEGIBLE & DRAWN TO SCALE   | ◆ Plans to include: site plan, floor plan, elevations, roof/ceiling plan, foundation and structural framing details, and structural calculations for non-conforming structures. |
| <input type="checkbox"/> 3 SETS IF PROJECT IS IN A DESIGN REVIEW AREA |   |
| <input type="checkbox"/> Title 24 Energy Compliance documentation     | <input type="checkbox"/> 11" x 17" copy of floor plan for County Assessor   |
| <input type="checkbox"/> Grading and Erosion Control Questionnaire    | <input type="checkbox"/> Plan Review Fees   |

Date: \_\_\_\_\_ Received by: (staff) \_\_\_\_\_

ACTIVITY/PERMIT #

# CERTIFICATION OF INSULATION

PART I GENERAL	ADDRESS: <b>BEHNER HOMES</b>		INSULATION CONTRACTOR:			
	LOT # <b>355</b>		<input checked="" type="checkbox"/> P.O. BOX 854, WEST SACRAMENTO, CA 95691 LIC. #202026 <input type="checkbox"/> 1309 MELODY ROAD, MARYSVILLE, CA 95901 LIC. #202026 <input type="checkbox"/> P.O. BOX 9651, FRESNO, CA 93793-9651 LIC. #202026 <input type="checkbox"/> P.O. BOX 1631, RENO, NV 89505 LIC. #10675 <input type="checkbox"/> 3326 A PONDEROSA WAY, LAS VEGAS, NV 89118 LIC. #10675			
10 Opus Cir		DATE INSULATION COMPLETED: <b>11/30/00</b>				
PART II AREAS INSULATED	WALLS		CEILINGS		FLOORS	
	( SQUARE FEET )		( SQUARE FEET )		( SQUARE FEET )	
	TYPE OF INSULATION		TYPE OF INSULATION		TYPE OF INSULATION	
	MATERIAL <b>FIBERGLASS</b>		MATERIAL <b>FIBERGLASS</b>		MATERIAL <b>FIBERGLASS</b>	
	FORM <b>BATTS</b>		FORM <b>BATTS &amp; BLOW</b>		FORM <b>BATTS</b>	
	MANUFACTURER'S PRODUCT ID		MANUFACTURER'S PRODUCT ID		MANUFACTURER'S PRODUCT ID	
	MANUFACTURER		MANUFACTURER		MANUFACTURER	
	OCF		OCF		OCF	
	BAGS					
	R - VALUE INSTALLED	APPLIED THICKNESS	R - VALUE INSTALLED	APPLIED THICKNESS	MIN. INSTALLED WEIGHT PER SQUARE FOOT	R - VALUE INSTALLED
<b>R-13</b>	<b>3 5/8"</b>	<b>R-30</b>	<b>1 3/4"</b>			
KNEE WALLS IF R-VALUE IS OTHER THAN WALLS ABOVE						
MATERIAL <b>FIBERGLASS</b>		FORM <b>BATTS</b>		R VALUE		MANUFACTURER <b>OCF</b>
AIR INFILTRATION SEALANT						
MATERIAL <b>FOAM</b>				MANUFACTURER <b>W R GRACE</b>		
THIS IS TO CERTIFY THAT INSULATION AND/OR SEALANT HAS BEEN INSTALLED IN CONFORMANCE WITH APPLICABLE CODES AND MATERIAL STANDARDS AND REGULATIONS.						
SIGNATURE - INSULATION CONTRACTOR <i>[Signature]</i>				TITLE <b>MANAGER</b>		DATE <b>11-3-00</b>
SIGNATURE - GENERAL CONTRACTOR				TITLE		DATE
REMARKS						

20074



INSTALLATION CARD

Job Address:

*Beaver Homes  
Memories Lot # 8 5035  
10 Opus Cir SAC*

Stucco System Trade Name: KWIK KOTE  
Name Stucco Manufacturer: KWIK KOTE CORR.

ICBO Evaluation Service, Inc.  
Report No. 3607  
Date of Job Completion

Konvon Construction

Stucco Contractor  
Name: *John A. Konvon, III*  
Address: *P.O. Box 3077  
North Highlands, CA 95660*  
Telephone Number: *(916) 349-8191*  
Approved Catalogue Number as issued by the Stucco Manufacturer: *1*

This is to certify that the *Stucco* system on the building exterior at the above address had been installed in accordance with the evaluation report specified above and the manufacturer's instructions.

Signature of authorized representative of contractor:

Date

*9/20/2000*

**N**orman

**S**cheel

**S**tructural

**E**ngineer

**Sacramento**  
939 Sunrise Blvd. #123  
Citrus Heights, CA 95610  
(916) 726-0612  
(916) 726-3189 (fax)

**NORMAN SCHEEL**  
Structural Engineer  
mail: [norm@nsse.com](mailto:norm@nsse.com)

**ROBERT COON**  
Project Manager  
mail: [rob@nsse.com](mailto:rob@nsse.com)

**PAULO IBÁÑEZ**  
Project Manager  
mail: [paulo@nsse.com](mailto:paulo@nsse.com)

**TIM SLOAN**  
Project Manager  
mail: [tim@nsse.com](mailto:tim@nsse.com)

**CASANDRA COURTISETT**  
Design Engineer  
mail: [casandra@nsse.com](mailto:casandra@nsse.com)

**MARY PHUNG**  
Design Engineer  
mail: [mary@nsse.com](mailto:mary@nsse.com)

**STEVE COOKSEY**  
CAD Supervisor  
mail: [steve@nsse.com](mailto:steve@nsse.com)

**STACY MARLIN**  
Office Manager  
mail: [stacy@nsse.com](mailto:stacy@nsse.com)

**Davis**  
13 E Street Suite B  
Davis, CA 95616  
(307) 753-5300  
(307) 753-5380 (fax)

**TRACY HARRIS P.E.**  
Project Engineer  
mail: [tracy@nsse.com](mailto:tracy@nsse.com)

**DARRELL PEREIRA**  
Design Engineer  
mail: [darrell@nsse.com](mailto:darrell@nsse.com)

*Copy with file*

September 13, 2000

Beazer Homes  
3009 Douglas Blvd. Suite 150  
Roseville, CA 95661


**Re: Memories (Job #99112)  
Slab Reinforcement**

To Whom It May Concern:

This letter is to clarify that the 6x6/10x10 or 6x6/W1.4xW1.4 wire mesh is adequate if installed properly. The letter from Wallace Kuhl states that on future pours 6x6/W2.9xW2.9 wire mesh should be used to help insure proper placement in the slab. The wire mesh should be installed in the middle of the slab and is used for crack control only.

If you have any questions, please contact Rob Coon.

  
**NORMAN SCHEEL**  
**STRUCTURAL ENGINEER**





*Copy with file*

September 12, 2000

Mr. Rob Coon  
Norman Scheel Structural Engineer  
6939 Sunrise Boulevard, Suite 123  
Citrus Heights, California 95610

*Slab/Reinforcement*  
**GATEWAY WEST (MEMORIES)**  
Sacramento, California  
WKA No. 3895.15


\* Our geotechnical engineering report for the subject subdivision (WKA No. 3895.05, dated September 8, 1998) recommends minimum interior slab-on-grade reinforcement consisting of 6 x 6/W2.9 x W2.9 welded wire fabric or No. 4 rebar at 18-inch center each way. Welded wire fabric provides crack control and the heavier gage wire is recommended based on our experience that it is easier to control the location of the reinforcement in the slab. The lighter gage wire (6 x 6/W1.4 x W1.4) is more difficult to achieve proper location (vertically) in the slab. However, if properly located, it can provide the desired crack control, although this is highly dependent on the experience and care of the concrete contractor. *OK @ 09/14/00*

\* Due to concerns over proper location of the reinforcement in the slab, we recommend that the 6 x 6/W2.9 x W2.9 welded wire be used on future house slabs constructed in the subdivision. *In future houses @ 9/14/00*

Wallace-Kuhl & Associates, Inc.

*Stephen L.*

Stephen L. French  
Senior Engineer



SLF:dlr

Copies: (1) Beazer Homes

H:\wpdata\3895.15\091200\tralf.doc

*Cl: Gary Off.  
Roger Standa  
Jesse Burns  
Tony Jones  
Doraine W.*

*CITY OF SACRAMENTO*  
RECEIVED  
SEP 12 2000  
BEAZER HOMES

RECEIVED  
SEP 08 2000  
BEAZER HOMES