

APPLICATION FOR COMMERCIAL BUILDING PERMIT

CITY OF SACRAMENTO
 PLANNING & BUILDING DIVISION
 PERMIT SERVICES SECTION
 (916) 808-2534 FAX: (916) 808-7046

ACTIVITY # <u>0502051</u>	Insp. Area <u>3</u>
------------------------------	------------------------

Applicant MUST complete ALL Unshaded Areas

ADDRESS: 6501 Elder Creek Rd. Suite: _____

PARCEL #: 038-0210-062

<p style="text-align: center;">CONTACT</p> <p>Name: _____ Street Address: _____ City/State/Zip: _____ Phone: _____ E-Mail: _____</p>	<p style="text-align: center;">LICENSED CONTRACTOR Lic No. # <u>C10 482432</u></p> <p>Name: <u>Placer Electric</u> Street Address: <u>1406 Timpelo Dr.</u> City/State/Zip: <u>Citrus Heights CA 95621</u> Phone: <u>916 725 9999</u> E-Mail: _____</p>
<p style="text-align: center;">ARCHITECT/ENGINEER</p> <p>Name: _____ Street Address: _____ City/State/Zip: _____ Phone: _____ E-Mail: _____</p>	<p style="text-align: center;">OWNER</p> <p>Name: <u>Mercy Housing</u> Street Address: <u>6501 Elder Creek Rd.</u> City/State/Zip: <u>Sacramento, CA 95824</u> Phone: <u>916 383-8860</u> E-Mail: _____</p>

⇒ Will permittee have any employees on the jobsite? No Yes ⇒ Insurance Co.: ZURICH

⇒ WORKER'S COMPANSATION POLICY # 4376325-01 EXPROATION DATE: 9-30-05

NATURE OF WORK IN DETAIL: Remove and replace 6 meter section Panel

OCCUPANT/TENANT: _____ VALUATION: 5000.00

FLOOD STATUS:			S.C.A.T.								
JOB DISCIPTION			BLDG	SHELL	APT	TI ()	REM ()	SW	FIRE	ADD	OTH
INSPECTION DISCIPLINES			BLDG	MECH	PLUMB	ELEC		SITE	FIRE		
# Stories	1 st Flr Area	Total Area	Use Zone	Occp Group	Const type	Fire Req. Y / N		Fed Code	Vio. [H]	File [Quad]	
						SPR	ALARM				
B	L	P	M	<u>E</u>	F	S		D	PW	UTIL	

COMMENTS: _____

REGIONAL SANITATION FEES? Yes No HEALTH DEPARTMENT: Yes No

WATER FLOW TEST FOR NEW BUILDINGS OR ADDITIONS? Provided Faxed

36.31' X 42.37'

ISSUED



City of Sacramento

SUPPLIED WITH
ACPL CLOSING PLATE
(FOR UNDERGROUND
SERVICE) ORDER TYPE
A-L HUB SEPARATELY
(FOR OVERHEAD SERVICE)

TOP POSITION
OMITTED ON
5-GANG UNIT

TENANT CIRCUIT
BREAKER DOORS
(PADLOCKABLE)
COVER KNOCKOUT FOR
USE WITH UTILITY
BARREL LOCK (RINGLESS
DEVICES ONLY)

INDIVIDUAL METER
SOCKET COVERS,
RING TYPE (INCLUDES
SNAP TYPE ALUMINUM
SEALING RINGS) OR
RINGLESS STYLE
(SUPPLIED WITH
COVER SEALING
LATCHES)



7.28
1.85
(NITS)

SYMBOL	CONDUIT SIZE	HOLE DIAMETER	NO. OF HOLES
A	.50	.489	22
B	.75	.738	28
C	1.00	1.013	34
D	1.25	1.250	44
E	1.50	1.500	54
F	2.00	2.000	76
G	2.50	2.500	92
H	3.00	3.000	105
I	3.50	3.500	118
J	4.00	4.000	132

AMPERE RATING	CATALOG NUMBER	SPACED CIRCUIT BREAKER RATING (AMPS)	CIRCUIT BREAKER WIRE SIZE (AWG)
60	00280		#8-#2 AL/CU
70	00270		#8-#2 AL/CU
80	00280	10,000	#4-2/0 AL/CU
90	00280		#4-2/0 AL/CU
100	002100		#8-#2 AL/CU
125	002125		#8-#2 AL/CU
60	00260H		#8-#2 AL/CU
70	00270H		#8-#2 AL/CU
80	00280H	22,000	#4-2/0 AL/CU
90	00280H		#4-2/0 AL/CU
100	002100H		#8-#2 AL/CU
125	002125H		#8-#2 AL/CU
60	00R260		#8-#2 AL/CU
70	00R270		#8-#2 AL/CU
80	00R280	42,000	#4-2/0 AL/CU
90	00R280		#4-2/0 AL/CU
100	00R2100		#8-#2 AL/CU
125	00R2125		#8-#2 AL/CU

ALTERNATE MECHANICAL LUGS
WIRE SIZE CATALOG NO.
(1) 1/0-500 AWG/KCHIL OR NMLK250
(2) 1/0-250 PER PHASE
(3) 3/0-500 AWG/KCHIL PER PHASE NMLK500
(4) 2-500 AWG/KCHIL PER PHASE NMLK500

METER SOCKET COVER	NO. OF METERS	NO. OF JAWS	FACTORY INSTALLED MAIN BUS	CATALOG NUMBER	LINE LUG WIRE SIZES (AWG/KCHIL) PHASE AND NEUTRAL	PHASE	SEE CIRCUIT BREAKER WIRE SIZE	NEUTRAL SERVICE GROUND & EQUIPMENT GROUNDING
RINGLESS	6	5	NONE	MP85-125	(1) 1/0-600 OR (2) 1/0-250			2/0-1/4 CU, 2/0-1/2 AL
RINGLESS	5	5	NONE	MP85-125				
RINGLESS	4	4	NONE	MP85-125				
RINGLESS	3	3	NONE	MP85-125				
RINGLESS	2	2	NONE	MP85-125				
RINGLESS	1	1	NONE	MP85-125				

MP METER-PAK METERING EQUIPMENT
NEHA TYPE 38 ENCLOSURE
125A MAXIMUM TENANT CIRCUIT BREAKERS

REF. DWG. #2250

The approval of all Electrical Work
is subject to field inspections