

**NOTES** DO NOT COVER OR CONCEAL ANY BUILDING, ELECTRICAL, PLUMBING OR MECHANICAL WORK WITHOUT INSPECTOR'S SIGNATURE IN PROPER PLACE.

INSPECTION	INSPECTOR	DATE
1 FOUNDATION FORMS		
11 UFER GROUND		
12 CONCRETE SLAB FORMS		
13 PLUMB. UNDERFLOOR/SLAB		
14 MECH/UNDERFLOOR/SLAB		
15 ELECT. UNDERGROUND		
16 ELECT. CONDUIT-SLAB		
<b>DO NOT COVER UNTIL INSTALLATION ABOVE HAS BEEN SIGNED</b>		
3 FLOOR JOISTS OR GIRDERS		
<b>DO NOT INSTALL SUB FLOOR UNTIL ABOVE HAS BEEN SIGNED</b>		
15 INSULATION/WALL/FLOOR		
1 TOP PLUMBING		
1 TOP MECHANICAL/WALL/CEIL.		
3 ROUGH ELECTRICAL/WALL/CELL.		
9 FRAME		
7 ROOF PLYWOOD NAIL COMM. & APTS.		
8 EXTERIOR LATH/SIDING		
<b>DO NOT COVER UNTIL INSTALLATION ABOVE HAS BEEN SIGNED</b>		
INIT. LATH OR WALL BD. NAILING		
<b>DO NOT TAPE PLASTER OR TOP UNTIL ABOVE HAS BEEN SIGNED</b>		
6 SERVICE UNDERGRD CONDUIT		
3 SEWER SERVICE		
2 WATER SERVICE		
6 SPRINKLER SYSTEM		
<b>DO NOT COVER UNTIL INSTALLATION ABOVE HAS BEEN SIGNED</b>		
139 GAS TEST		
8 TEMP GAS ISSUED		
8 POWER POLE		
7 TEMP. POWER #		
<b>SWIMMING POOLS ONLY</b>		
7 GAS TEST		
1 PLUMBING PRE-GUNITE		
2 PLUMBING PRE-DECK		
0 ELECTRICAL PRE-GUNITE		
1 ELECTRICAL PRE-DECK		
2 ELECTRICAL UNDERGRD		
<b>DO NOT COVER UNTIL INSTALLATION ABOVE HAS BEEN SIGNED</b>		
ENERGY COMPLIANCE CERTIFICATE TO BE ON FILE PRIOR TO FINAL APPROVAL.		
DATE _____ SIGNED _____		
FINAL INSP. NO. _____		
BUILDING _____		
ELECTRICAL _____		
PLUMBING _____		
MECHANICAL _____		

DO NOT OCCUPY BUILDING UNTIL ALL OF THE ABOVE HAVE BEEN SIGNED AND CERTIFICATE OF OCCUPANCY ISSUED

FINAL APPROVALS  
*[Signature]*

BUILDING SITE ADDRESS: **1918-22-57.**

ASSESSOR PARCEL NO.	NAME OF APPLICANT	ADDRESS	COMMUNITY PLAN NO.	PHONE NO.
LICENSED CONTRACTOR	PROPERTY OWNER	ARCH. ENGR.	LICENSE NO.	
NO. OF STORIES	NO. OF ROOMS	ROOF COVERING	AREA 1ST FLOOR	TOTAL AREA
			GARAGE AREA	PATIO AREA
			USE ZONE	STREET WIDTH
THIS PERMIT IS FOR: <input checked="" type="radio"/> BUILDING <input type="radio"/> MECHANICAL <input type="radio"/> PLUMBING <input type="radio"/> ELECTRICAL <input type="radio"/> SITE <input type="radio"/> FIRE				
NATURE OF WORK IN DETAIL				
FLOOD STATUS ( ) SPECIAL CONDITIONS ATTACHMENTS:				
CITY OF SACRAMENTO INSPECTIONS 264-5191				
BUILDING INSPECTION DIVISION				
WORKER'S COMPENSATION DECLARATION				
I hereby affirm under penalty of perjury one of the following declarations:				
<input type="checkbox"/> I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.				
<input type="checkbox"/> I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:				
Carrier: _____				
Policy Number: _____				
<input type="checkbox"/> (This section need not be completed if the permit is for one hundred dollars (\$100) or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.				
Date	Applicant	(Signature)		
ISSUED BY:	VALUATION \$	1111		
DATE ISSUED	BUILDING PERMIT FEE \$			
	PLAN CHECK/PROC. FEE \$			
	S.M.L. FEE \$			
	CONST. EXCISE TAX \$			
	CITY BUS LICENSE \$			
	TECH. FEE \$			
	WATER DEV. FEE \$			
	CITY SEWER DEV. FEE \$			
	REG. SEWER FEE \$			
	RESIDENTIAL CONST. TAX \$			
TOTAL FEES	\$	1111.17		

PLAN CHECK NO. **114**

FED CODE 11  
 FIRE SP.  
 CONSTR. TYPE  
 OCCUP. GROUP

PERMIT NO.

97-138810R

CITY OF SACRAMENTO  
1231 I ST. ROOM 200  
BUILDING INSPECTIONS DIVISION

AREA NO.

1-1R

WHEN CORRECTIONS HAVE BEEN MADE, CALL **264-5191** FOR REINSPECTION OF WORK.

JOB LOCATION

1918 22nd Street

INSPECTION REQUESTED

Re roof

THE UNDERSIGNED  BUILDING  PLUMBING  MECHANICAL  ELECTRICAL  
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

F 08419

① Triples one leg Bolt at  
H/Ac stand

② Provide support as per code  
for the condensate line

③ Provide approved Flashing at  
the Chimney Flashing has been  
removed.

DATE: 12/22/97

DATE: 12/22/97

BUILDING INSPECTIONS 264 5716

INSPECTOR: [Signature]