

CITY OF SACRAMENTO

Permit No: 0115982

1231 I Street, Sacramento, CA 95814

Insp Area: 1
Thos Bros: 297 D4

Site Address: 1017 K ST SAC

Sub-Type: REP
Housing (Y/N): N

Parcel No: 006-0103-011

CONTRACTOR

OMARS ELECTRIC
3061 OAKWOOD RD
CAMRON PARK, CA 95682

OWNER

MCCLATCHY FAMILY TRUST
SACRAMENTO CA
95812

ARCHITECT

Nature of Work: INSTALL NEW PANEL A & NO NEW CIRCUITS EXCEPT FOR DOUBLE LOADED & RELOCATED BRANCH CIRCUITS FROM MAIN PANEL

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

X License Class C10 License Number 474072 Date 12/19/01 Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

X Date 12/19/01 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier EXEMPT Policy Number 0000000000 Exp Date _____

(This section need not be completed if the permit is for \$100 or less.) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

X Date 12/19/01 Applicant Signature [Signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.



THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

CREST CAFE ELECTRICAL

10F2

FILE COPY

4 #3/0 COPPER CABLES



2" X 6" Close Nipple

ISSUED
DEC 1 9 2001

EXISTING
MAIN
GROUND

#4 COPPER GROUND

Sacramento Building Division

GROUND

0115982

APPROVED PER 1996
 NATIONAL ELECTRICAL CODE
 SACRAMENTO
 T.L.M. 12-19-01
 ELECTRICAL DIVISION

1017 K Street

LOAD CALCULATION FOR 1017 'K' STREET

Non-continuous Load

Convenience Receptacle load $30 \times 180 = 5400 / 360 = 15\text{amps}$

Continuous Load

General Lighting $1351 \text{ sq. ft.} \times 2\text{va} = 2702$

Showroom Window $30' \times 200 = 6000$

Outside Signage 1200

9902 $1.25 = 12377.5 / 360 = 34\text{amps}$

<u>Equipment</u>	<u>Voltage</u>	<u>Watts</u>
Espresso Machine	220v	5,000
Coffee Grinder	110v	1,200
Upright Freezer	110v	1,500
Upright Refrigerator	110v	1,500
Refrigerator Deli Case	110v	1,500
Toaster	110v	1,200
Microwave Oven	110v	1,800
Microwave Oven	110v	1,800
Food Warmer	110v	1,500
Beverage Cooler	110v	1,200
Beverage Cooler	110v	1,200
Deli Slicer	110v	900
Counter Cooler Cabinet	110v	1,200
Food Display Warmer	110v	1,200
Ice Cream Freezer	224v	1,300
Ice Maker	110v	1,600
Soft Drink Dispenser	110v	1,200
Dish Washer	110v	1,600
Grill Hood Exhaust Fan	220v	900
Hot Water Heater	240v	11,208
TOTAL EQUIPMENT VAC		40,580 / 360 = 112.72amps
CONTINUOUS LOAD		9,902
NON-CONTINUOUS LOAD		5,400
TOTAL VAC		55,882 / 360 = 155.23amps

The approval of all
Electrical work is subject to field
inspections

NOTE: There are no new circuits being added. Eliminating the circuits with double loads by extending the existing panel.

1017 K Street

0115982