

CITY OF SACRAMENTO
1231 I Street, Sacramento, CA 95814

Permit No: 0008609
Insp Area: 4

Site Address: 2531 CAMPDEN WY SAC
Parcel No: 274-0470-001

Sub-Type: RES
Housing (Y/N):

CONTRACTOR
ANTONIO POOL SERVICE

OWNER
JOHN KEHRIOTIS
2531 CAMPDEN WY
SAC

ARCHITECT

Nature of Work: GUNITE POOL, SPA, DECKING

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class C-53 License Number 7311394 Date 7-31-00 Contractor Signature _____

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: _____

Date _____ Owner Signature _____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 7-31-00 Applicant/Agent Signature _____

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier _____ Policy Number _____ Exp Date _____

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 7-31-00 Applicant Signature _____

WARNING. FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.



NEIL O. ANDERSON & ASSOCIATES, INC.

GEOTECHNICAL • ENVIRONMENTAL • GROUNDWATER • INSPECTIONS • TESTING • LABORATORY SERVICES

CHICO (530) 891-6304
 STOCKTON (209) 472-1091
 RANCHO CORDOVA (916) 931-4455

CORPORATE OFFICE
 12 Houston Lane
 Lodi, California 95240
 (209) 367-3701
 FAX: (209) 333-8303

SACRAMENTO OFFICE
 4229 Northgate Boulevard, Suite 3
 Sacramento, California 95834
 (916) 929-9267
 FAX: (916) 929-9269

August 21, 2000
Job Number SI00-099

Dion Hawes
 Antonio Pools
 12783 Meiss Road
 Sloughhouse, CA 95683

Subject: Kehriotis Residence
 2531 Campden Avenue
 Sacramento, California

This report presents the results of the compaction and field density tests performed on the native fill placed in the trenches for the subject project. ASTM D1557 Compaction tests were conducted on samples of the native soil. The results of these tests are presented next.

Soil Description	Unit Weight (pcf)	Moisture Content (%)
Brown clayey silt	122.2	11.6

Date	Representative	Time	Mileage
8-4-00	D. Wruck	2 hours	19 miles

The field density tests were performed per ASTM D2922 and D3017. The results of the field density tests are presented next.

Date	Test	Dry Density (pcf)	Moisture Content (%)	Relative Compaction (%)	Location	Elevation
8-4-00	1	110.7	10.6		West end of trench	SG
8-4-00	2	109.6	10.7		East end of trench	SG
8-4-00	3	110.0	11.0		Center of trench	SG

1 1/2'-2' deep trench. 90% minimum relative compaction required. All tests **passing**.

August 21, 2000
Job Number SI00-099
Page 2

We have employed accepted engineering and testing procedures. However, we do not undertake the guarantee of construction nor do we relieve the contractor of his primary responsibility to produce a completed project conforming to the project plans and specifications.

NEIL O. ANDERSON & ASSOCIATES, INC.



Neil O. Anderson, President
Geotechnical Engineer 2245

NOA dp (SI00-099 fdc.wpd)

