

Q 201 7107-113

Lot 384

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD

\$67.00

Greenhaven #3

TYPE BUILDINGS

| | | | | | |
|----------------------|----------|---|--------------------|-------------------------|-------------------------------|
| PERMIT NO. F-5043 | | LOCATION 32 - Sunlit Circle | | A-3 | |
| DATE Aug 11-66 | | PURPOSE Const. dwlg. & att. gar. | | | |
| ZONE R-1 | | OWNER Ervin Gon 1720-0 St. | | | |
| | | ARCH'T | | | |
| | | CONTR Royal Monarch Dev. 4699-24th St. Rd. | | | |
| VAL. \$19,100. | | STORIES | ROOMS | APTS. | 430-gar. SIZE 1950 sq. ft. |
| INSP. | DATE | BLDG. TYPE | OCCUPANCY GROUP | PHONE (O) (C) | |
| FORM | 8-15-66 | Babalato | | | |
| JOIST | 8-24-66 | Babalato | | | |
| FRAME | 10/10/66 | Babalato | | | |
| SHEET ROCK | 10/17/66 | Babalato | | see permit 3-27-67 J.B. | |
| FINAL | 4-18-67 | Ervin | | | |

| DATE | SPECIAL CONDITIONS OF WORK — REMARKS |
|----------|---|
| 8-23-66 | Pt. Point 3" clearance (under) duct |
| | 10" (required) from top of girder to center |
| 10/7/66 | Pt. Home - No ad turns, card or plans |
| 10/14/66 | Pt - S.B. - 40 ft card - no plans |
| 12/16/66 | Pt. Final. Solid core door required hit to garage |
| 3-31-67 | Oldg. lockch |
| 4-11-67 | S.B. 4-18-67 |
| | |
| | COMPLETE AND OK |
| | INSPECTOR |

Barbato

Barbato

Barbato

Barbato

Chapin