

**BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD**

**TYPE BUILDINGS**

<b>PERMIT NO.</b> 9527	<b>LOCATION</b> 1301 Q St
<b>DATE</b> 5/31/37	<b>PURPOSE</b> Alterations & Repr.
<b>ZONE</b> Water Jan	<b>OWNER</b> Huckman Coleman
	<b>ARCH'T</b>
	<b>CONT-R</b> John F Reynolds

1301 Q St

PHONES

VAL.

150 -

STORIES

ROOMS

APTS.

SIZE

<b>Light Shafts</b>		<b>Elevator Shafts</b>	
<b>Vent Shafts</b>		<b>Boiler Rooms</b>	
<b>Owner's Inspector</b>		<b>Sprinkler System</b>	
<b>Lath</b>		<b>Gas Vents</b>	
<b>Fire Escapes</b>		<b>Chimneys</b>	
<b>Stand Pipes</b>		<b>Skylights</b>	

DATE	CONDITION OF WORK—REMARKS
5/20/37	Made Insp of Alterations & Repairs to
	2 Story Dwlg. Instructed Carpenter to install
	vents below first floor including porch
	Old house built only 1 step above walk
	& top of porch floor. O.K. A.W. Campbell
5/24/37	<p>COMPLETE AND O.K. <i>Alfred W. Campbell</i> INSPECTOR</p>