

Bill 7323

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$26.00

TYPE BUILDINGS

PERMIT NO. E-2703	LOCATION	1425 - Stoddard Street			A-4
DATE Nov. 16-62	PURPOSE	Repair fire damage to dwelling			
ZONE R-1	OWNER	Arthur Azevedo 5931-Wymore			
	ARCH'T				
	CONTR	J. E. Solem 2524-Tesla 482-0924			
VAL. \$1,200.		STORIES	ROOMS	APTS.	SIZE
INSP.	DATE	BLDG. TYPE		OCCUPANCY GROUP	
FORM					
JOIST					
FRAME	2-7-63	Crest			
SHEET ROCK	2-14-63	Baslyte			
FINAL	1-21-64	Crest			

DATE

SPECIAL CONDITIONS OF WORK — REMARKS

1-23-63	Pt. Rumore saw from gas well, same. Put water room to place. Cap and hole in ceiling must be closed off
1-30-63	Pt. Backing for 5' steel rock. Hole called for above. Hole in ceiling
2-4-63	not framed completely. Crossing wells made here of SR. Carbons
2-11-63	Pt. rails incorrect. Must be 46 c.c. must have 5' rock fast bearing wall. Carbons
10-16-63	Firewall incomplete. must cover paper panels with mud. 12-5-63 left after not to occupy well
12-5-63	inter gas firewall corrected
	COMPLETE AND OK
	INSPECTOR