

B140 7260-265

Lot 300 BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$64.00

Greenhaven 70 #2

TYPE BUILDINGS

|                |          |                       |                 |                                   |               |
|----------------|----------|-----------------------|-----------------|-----------------------------------|---------------|
| PERMIT NO.     |          | LOCATION              |                 | A-3                               |               |
| E-6648         |          | 79 - Shoreline Circle |                 |                                   |               |
| DATE           |          | PURPOSE               |                 | Const. dwelling & attached garage |               |
| Mar. 30-64     |          | OWNER                 |                 | R. M. Reeve 7073-Tamoshanter Way  |               |
| ZONE           |          | ARCH'T                |                 |                                   |               |
| R-1            |          | CONTR                 |                 | Stardust Homes Same GA 1-3232     |               |
| VAL. \$18,900. |          | STORIES               | ROOMS           | APTS.                             | 504-gar. SIZE |
|                |          | 1                     | 6               |                                   | 2,000 sq.ft.  |
| INSP.          | DATE     | BLDG. TYPE            | OCCUPANCY GROUP | PHONE (O) (C)                     |               |
| FORM           | 3-31-64  | Hammond               |                 |                                   |               |
| JOIST          | 11-21-64 | Hammond               |                 |                                   |               |
| FRAME          | 5-17-64  | Hammond               |                 |                                   |               |
| SHEET ROCK     | 5-21-64  | Hammond               |                 |                                   |               |
| FINAL          | 8-18-64  | E. Jensen             |                 |                                   |               |

| DATE    | SPECIAL CONDITIONS OF WORK — REMARKS  |
|---------|---|
| 4-17-64 | P.T. no address - no plans (Court)  |
| 4-20-64 | P.T. found joint not nailed - steel missing in fireplace pad - steel dowels missing in porch slab |
| 5-6-64  | P.T. 1x4 n/a on 2x6 joists E. Siding not installed <sup>Hammond</sup> E. Siding not in            |
| 5-7-64  | P.T. papers missing as behind re-ter table <sup>Hammond</sup>                                     |
| 5/15/64 | P.T. no card on job (Court)   |
|         | COMPLETE AND OK   |
|         | INSPECTOR   |

