

**CITY OF SACRAMENTO**

1231 I Street, Sacramento, CA 95814

Permit No: 0509255

Insp Area: 4

Thos Bros: 277H6

Site Address: 2326 DEL PASO BL SAC

Parcel No: 275-0052-002

Sub-Type: REM

Housing (Y/N): N

CONTRACTOR

OWNER

CALVARY CHRISTIAN CHURCH CENTER  
PO BOX 15010  
SACRAMENTO, CA 95851

ARCHITECT

Nature of Work: ADD ANSUL HOOD AND SINKS TO EXISTING KITCHEN

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name \_\_\_\_\_ Lender's Address \_\_\_\_\_

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class \_\_\_\_\_ License Number \_\_\_\_\_ Date \_\_\_\_\_ Contractor Signature \_\_\_\_\_

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. \_\_\_\_\_ B & PC for this reason: \_\_\_\_\_

Date 7/29/07 Owner Signature [Signature]

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

PAID  
CITY OF SACRAMENTO  
JUL 29 2007

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 7/29/07 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier \_\_\_\_\_ Policy Number \_\_\_\_\_ Exp Date \_\_\_\_\_

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 7/29/07 Applicant Signature [Signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

Full Demand Test

For determination of CFM/SP relationship

Date & By: 3-27/06

Design	Test #1		Test #2		Test #3	
	Ref. SP	CFM	Ref. SP	CFM	Ref. SP	CFM
under Full Demand	2/60	488	2300	2100		2170

Exhaust Fan

Fan: Captive Arc Hood Section: EX

Item: 1

Page: 1/1

Test Description		Design		Test # 1	Test # 2	Test #
		Plans	Submit		FINAL	
Fan	Manufacturer	<u>DAYTON</u>		<u>2300 CFM</u>	<u>2100 CFM</u>	<u>2170 CFM</u>
	Model Number	<u>7A624</u>				
	Type or Size	<u>20"</u>				
	Volume Control Type	<u>NA</u>				
Motor	Manufacturer	<u>DAYTON</u>				
	HP	RPM-hi	RPM-lo			
	Frame	Phase	SF			
	Volts	<u>120</u>				
	FLA	<u>5.8</u>				
	SFA					
Motor Sheave	Model or Size	<u>DAYTON</u>		<u>DIRECT DRIVE</u>		
	Bore or Bushing	<u>3"</u>				
	Adj. % of Max	<u>80%</u>				
Fan Sheave	Model or Size	<u>6"</u>				
	Bore or Bushing	<u>3/4"</u>				
Number Belts	Belt Size					
Centerline	% of Max Adj.					
Volume Control	Set Point	Indicated	Actual			
	Position					
Tested RPM	Motor					
	Fan					
Air Dist. Total	SAcfm	% des.				
	RAcfm	% SA				
Fan Air Flows	OAcfm	% SA				
	Discharge SP		ESP	TSP		
Suction SP		ESP	TSP			
Total Resistance		ESP	TSP			
ΔP's	Filter/ Cooling Coil					
Volts	T1-T2	T1-T3	T2-T3			
Voltage Corrected FLA						
Amps	T1	T2	T3			
Approximate BHP						
No Load Amps (if overloaded)						

Motor name plate  
valid location to test motor and fan RPM

# Test Equipment Detail

Application	Description	Manufacturer	Model	Current Cal	Cal Due
Air Velocity - Duct ✓	<b>DWYER ANEMOMETER 470</b>	<b>DWYER</b>	<b>470</b>		
Air Velocity - Fume Hood ✓					
Air Velocity - Registers ✓					
Air Volume - Registers					
Air Differential Pressure					
Duct Static Pressure ✓					
Air, Contact & Immersion Temperature					
Air Velocity - Pressure & Temperature	Thermo Anemometer	TSI	8385		
Duct Leak Testing	Calibrated Orifice Tube	United McGill	LTK-S		
Rotational Speed	Chronometric Tachometer	O. Zernickow	252		N/A
	Stroboscope Tachometer	Exttech	461830		
	Digital Tachometer	Pacer	DT3		
Electrical	Digital Clamp-on Volt / Amp Meter	Fluke	32		
	Digital Multi Meter	Fluke	29		
	Documenting Process Calibrator	Fluke	701		
Water Gage Pressure	Hydro Data Multimeter	Shortridge	HDM-150		
Water Differential Pressure					
Air, Contact & Immersion Temperature					
Air, Contact & Immersion Temperature	Multi-Temp	Shortridge	HDM-300		
Multi-Point Measurement			MT-44K		
Temperature Source	Dry Block Temperature Chamber	ThermaCal	18B-0-600		
Relative Humidity	Chilled Mirror Meter	General Eastern	M-4		
Measurement & Source	RH Chamber	General Eastern	C-1		
	Salt Bath Calibrator	Vaisala	HMC-11		
	Thin Film Capacitive RH Meter	Vaisala	HMC-20 / HMP20B		
Relative Humidity & Temperature	Thin Film Capacitive RH Meter	Vaisala	HM-34F		
PC Based Monitoring & Logging	Data Acquisition	National Instruments	SCXI-1100/1200 & LabView		
	Temp & Humidity Transmitters	Vaisala	HMD-20YB	N/A	N/A
	DP Transmitters	Mamac	PR-274-R2-mA		
Air Temperature Recorder	Digital Data Recorder	MicroLogger	32-98F		
Relative Humidity Recorder	Digital Data Recorder	MicroLogger	1H100-C		
Airborne Particle Counter (non-viable) w/ Temp & %RH	Laser Particle Counter	Met-One	Particle Counter: A2408 Particle Counter: A2408 Particle Counter: A2100B Particle Counter: A2100B T&RH Probe: 85A T&RH Probe: 85A T&RH Probe: 85 T&RH Probe: 85		
Airborne Particle Counter (Viable)	Viable Microbe Air Sampler	Biotest	RCS Centrifugal Air Sampler		
	Airflow Indicator	Biotest	940210		
	Anemometer	Biotest	940312		
DOP Filter Leak Testing	Photometer	Air Techniques	TDA-2E		
	Generator	Air Techniques	TDA-2G		
			TDA-4B	N/A	N/A
			TDA-5B		
			TDA-6A		
PSL Leak Testing	PSL Generator / DI Water Fogger	KimAir, Inc.	Challenger I		
		Cleanroom Sciences	µS-25K-1	N/A	N/A
		Sunbeam	KUH-15/694	N/A	N/A
	PSL Generator, Multi-Nozzle	KimAir, Inc.	Challenger II	N/A	N/A
	Particulate Dilution Chamber	MESA3	PDC-1		
Lighting Level (intensity)	Light Illumination Meter	Exttech	K81792		
Lighting Spectrum	Radiometer	UVP	UVX		
Sound Pressure Level	Sound Level Meter	Simpson	Meter 886, Filters 898, Calib 890		
Electromagnetic Interference (EMI)	Magnetic Field Test Kit	Holaday	3604		
Electric Space Charge	Ion Density Meter	Semtronics	EN160		
	Charge Plate Monitor	NiStat	210		
Electrical Grounding	Digital Safety Inspector	Ohmic	SI-100ND		
Floor Conductivity	Conductive Meter	Biddle	Mark IV		
Compressed Gas Properties	Compressed Gas Tester	Draeger	Aerotest # E1-1A001-E440		
Oil, Moisture, CO, CO <sub>2</sub> , NO, NO <sub>2</sub> , SO <sub>2</sub>				N/A	N/A
Compressed Gas Particulates	Particulate Sampling Chamber	MESA3	PSC-1	N/A	N/A
	Flowmeter 4-40 l/min	Dwyer	VFB-69-BV-CDS		
Compressed Gas Dew Point	Compressed Gas Dew Point Monitor	Hydrodynamics	8092		

# TRIMLINE SHEET METAL HEATING & AIR CONDITIONING

22515 CANYON WAY  
COLFAX, CA 95713  
PHONE (530)637-5156  
FAX (530)637-5156  
E-MAIL TRIMLINEHVAC@MSN.COM

DATE: 3/27/06  
TO: Saca Co.  
FROM: THE DESK OF JOHN PLATT

## MAKE up AIR - Supply

$$10' \times 16' = 120' \times 16' = 1920 \text{ cu} = \div 144 =$$

$$13.33 \text{ Sq FT.} = 146.16 \text{ CFM per Sq}$$

FT. Average = 146.6 ON Make

up perforated MAKE up OUTLET.

$$\text{Supply design} = 1944 \text{ CFM}$$

$$\text{Setting} = 1955 \text{ CFM}$$

## Exhaust

$$10' \times 20' = 200 \text{ cu in } \div 144 = 1.38 \text{ cu. FT}$$

$$1572 \text{ per Sq FT CFM} \times 1.38 = 2169.36$$

$$\text{Exhaust design} = 2160 \text{ CFM}$$

$$\text{Setting} = 2170 \text{ CFM}$$

Full Demand Test

For determination of CFM/SP relationship

Date & By: 3/27/06

Design	Test #1		Test #2		Test #3	
	CFM	Ref. SP	CFM	Ref. SP	CFM	Ref. SP
<u>1944</u>	<u>.062</u>		<u>1944</u>	<u>1955</u>		<u>1955</u>

under Full Demand

**Make-up Air Fan**

Fan: WILLIAMS

Section: \_\_\_\_\_ Item: 1

Page: 1/1

Test Description		Design		Test # 1	Test # 2	Test #
		Plans	Submit		FINAL	
Fan	Manufacturer	<u>WILLIAMS</u>		<u>2200</u>	<u>1955</u>	<u>1955 CFM</u>
	Model Number	<u>45000</u>				<u>.062</u>
	Type or Size	<u>20"</u>				
	Volume Control Type	<u>1/2"</u>				
Motor	Manufacturer	<u>DAYTON</u>				
	HP	<u>3/4</u>				
	RPM-hi	<u>11</u>				
	RPM-lo					
	Frame	<u>120</u>				
	Phase	<u>6.8</u>				
	SFA					
Motor Sheave	Model or Size	<u>4"</u>	<u>200 - DIRECT DRIVE</u>			
	Bore or Bushing	<u>4"</u>				
	Adj. % of Max	<u>2"</u>				
Fan Sheave	Model or Size	<u>1 1/2"</u>				
	Bore or Bushing	<u>3/4"</u>				
Number Belts	Belt Size					
Centerline	% of Max Adj.					
Volume Control	Set Point	Indicated	Actual			
		Position				
Tested RPM	Motor					
	Fan					
Air Dist. Total	SAcfm	% des.				
Fan Air Flows	SAcfm	% des.				
	RAcfm	% SA				
	OAcfm	% SA				
Discharge SP	ESP	TSP				
Suction SP	ESP	TSP				
Total Resistance	ESP	TSP				
ΔP's	Filter/ Cooling Coil					
Volts	T1-T2	T1-T3	T2-T3			
Voltage Corrected FLA						
Amps	T1	T2	T3			
Approximate BHP						
No Load Amps (if overloaded)						

Motor name plate

valid location to test motor and fan RPM