

R231 F-258-2599

## BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD

\$37.00

## TYPE BUILDINGS

R234 F305

PERMIT NO. F-9295	LOCATION 1900 - S Street A-2			
DATE 1-8-68	PURPOSE	Const. office partitions in bldg. shell		
ZONE	OWNER	Oates, Jennings, & Benvenuti 6700 Fols		
	ARCH'T	Leo McGlade sacramento		
	CONT'R	Owner same		
VAL. \$10,000.	STORIES	ROOMS	APTS.	SIZE
INSP.	DATE	BLDG. TYPE	OCCUPANCY GROUP	PHONE (O) (C)
FORM				
JOIST				
FRAME				
SHEET ROCK				
FINAL	2-12-68	Chapman		Est

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
2-6-68	RT SR on, partly taped
	No space insp. Approx. 1/2
2-7-68	RT no fire dampers in duct work
	penetration for wall toilet vent ducts
	dist. in. RT fire alarm. Sect. Supervisor of
	office area getting hung ceiling (Chapin)
2-6-68	RT final inspection on fire dampers.
	Installation SF 3-13-68 C. Chapman
	COMPLETE AND OK
	INSPECTOR