

|                      |  |  |       |                               |                   |
|----------------------|--|--|-------|-------------------------------|-------------------|
| Lot 568              |  | BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD |       |                               | A-62<br>E-486-487 |
| Willow "ancho#4      |  | <b>TYPE BUILDINGS</b>                              |       | \$31.00                       | R-44<br>E-16-22   |
| PERMIT NO.<br>D-3899 | LOCATION 1950 Whitman Way A-5            |  |       |                               |                   |
| DATE<br>Nov. 4, 59   | PURPOSE Const. dwelling garage Plan#94-X |  |       |                               |                   |
| ZONE<br>-1           | OWNER Lawrence Associates 3020-V St.     |  |       |                               |                   |
|                      | ARCH'T                                   |  |       |                               |                   |
|                      | CONT'R Owner GI 1-7294                   |  |       |                               |                   |
| VAL. \$11,000.       | STORIES                                  | ROOMS<br>6   | APTS. | 483 Gar. SIZE<br>1131 Sq. ft. |                   |
| INSP.                | DATE                                     | INSPECTOR  |       |                               |                   |
| FORM                 | 12-2-59                                  | Berry  |       |                               |                   |
| JOIST                | 1-6-60                                   | Calloway   |       |                               |                   |
| FRAME                | 2-19-60                                  | Calloway   |       |                               |                   |
| LATH                 | 3-15-60                                  | Berry  |       |                               |                   |
| FINAL                | 5-2-60                                   | Jones  |       |                               |                   |

| DATE   | SPECIAL CONDITIONS OF WORK—REMARKS  |
|--------|---|
| 1-4-60 | P.T. re-nail head joint remove wood from under bldg. Calloway.  |
| 3-2-60 | P.T. re-nail garage fire wall with # 6. C.C. <sup>Benny</sup>   |
| 3-4-60 | P.T. Remove 1/2 S.R. from fire-wall. Calloway   |
|        |   |
|        |   |
|        |   |
|        |   |
|        |   |
|        | <div data-bbox="288 839 414 885" data-label="Text">COMPLETE AND OK</div> <div data-bbox="1121 865 1249 885" data-label="Text">INSPECTOR</div> |