

Lot 568 BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD *A-62* *E-486-487*

Willow "ancho#4 TYPE BUILDINGS \$31.00 *R-44* *E-16-22*

PERMIT NO. D-3899	LOCATION 1950 Whitman Way A-5
DATE Nov. 4, 59	PURPOSE Const. dwelling garage Plan#94-X
ZONE -1	OWNER Lawrence Associates 3020-V St.
	ARCH'T
	CONT'R Owner GI 1-7294

VAL. \$11,000.	STORIES	ROOMS 6	APTS.	483 Gar. SIZE 1131 Sq. ft.
----------------	---------	------------	-------	-------------------------------

INSP.	DATE	INSPECTOR
FORM	12-2-59	Berry
JOIST	1-6-60	Calloway
FRAME	2-19-60	Calloway
LATH	3-15-60	Berry
FINAL	5-2-60	Jones

DATE	SPECIAL CONDITIONS OF WORK—REMARKS
1-4-60	P.T. re-nail head joint remove wood from under bldg. Calloway.
3-2-60	P.T. re-nail garage fire wall with # 6. C.C. ^{Benny}
3-4-60	P.T. Remove 1/2 S.R. from fire-wall. Calloway
COMPLETE AND OK	INSPECTOR