

Q179 7504-509

Lot 2		BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD		\$40.00
Blk. 7		TYPE BUILDINGS		
North Sec. Sub. #8		<i>R209 F311-213 file</i>		
PERMIT NO.				
F-2092	LOCATION	2446 - Rio Linda Blvd.		A-6
DATE.	PURPOSE	Const. bldg. containing off. & workshop		
Oct 22-65	OWNER	V. Pacquin same /areas		
ZONE	ARCH'T	Leo McGlade 2011-Arden Way /Folsom		
C-2	CONTR	Duncan Const. 9818-Valley Pines Dr.-		
VAL \$11,000.		STORIES	ROOMS	APTS. SIZE
				1,837 sq. ft.
INSP.	DATE	BLDG. TYPE	V-no hr.	OCCUPANCY GROUP F-2
				PHONE (O) (C) YU8-2580
FORM	<i>10-27-65</i>	<i>Hammann</i>		
JOIST				
FRAME	<i>11-22-65</i>	<i>Loran</i>		
SHEET ROCK	<i>12-30-65</i>	<i>Loran</i>		
FINAL	<i>12/28/66</i>	<i>M. McCallum ent.</i>		

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
10-25-65	Pt Larson - Not ready Larsen
10-31-65	Pt Larson - Not ready Larsen
11-8-65	Pt Larson - Not ready Larsen
11-18-65	Red tag - Block wall not constructed correct Larsen
11-19-65	Bldg being cleaned & corrected by engineers. OK to proceed with work Larsen
12-1-65	Block wall finished & cells filled. Only two to 24" parapet wall on property line Larsen
12-17-65	Pt Larson - 3/8 plywood to roof on end wall in back 1/2 in wall. Correct. Insulation on road side done Larsen
12-29-65	Q.1. 210 - Not ready Larsen
1-19-66	Up to move in. Old office to be removed no final until complete Larsen
1/16/66	COMPLETE Pt final - down paid should AND OK go underground Calloway
1/25/66	downpaid not install SF 3 days INSPECTOR Calloway