

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT NO. <i>H-4788</i>	LOCATION <i>1416 - 9th St.</i>			
DATE <i>5/7/36</i>	PURPOSE <i>Remodel Store</i>			
ZONE	OWNER <i>Feldhusen Grocery Store</i>			
	ARCH'T. <i>Install Plastered Ceiling</i>			
	CONTR. <i>Morris & Russell</i>			
VAL. <i>1750⁰⁰</i>	STORIES <i>1</i>	ROOMS	APTS.	SIZE <i>3913-Build Code</i>
LIGHT SHAFTS		ELEVATOR SHAFTS		
VENT SHAFTS		BOILER ROOMS		
OWNER'S INSPECTOR		SPRINKLER SYSTEM		
LATH		GAS VENTS		
FIRE ESCAPES		CHIMNEYS		
STAND PIPES		SKYLIGHTS		

DATE	CONDITION OF WORK—REMARKS
5/12/36	2 ^{NO} /HSP. Partial Frame for installing 2" x 6" Ceiling Joists between heavy roof trusses In Unfinished Ceiling A.W. Campbell
5/18/36	2 ^{NO} /HSP. Frame North 1/2 of Bldg ^{including fireplace & part} A.W. Campbell
5/21/36	3 ^{NO} /HSP. Int. 3/8" Grip Lath Ceiling & Partitions A.W. Campbell
5/27/36	2 ^{NO} /HSP. Frame for S 1/2 of Bldg A.W. Campbell
5/27/36	3 ^{NO} /HSP. Int. 3/8" Grip Lath Wall & Ceiling A.W. Campbell Note Contractor will take out additional Permit & P.O. when other store is rented
	COMPLETE AND O. K. INSPECTOR