

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

R10-F588

TYPE BUILDINGS

M-24-13

PERMIT NO.

LOCATION

3409 - 2nd ave.

DATE

PURPOSE

Erect Shop Bldg.

OWNER

Thom

ZONE

ARCH'T.

CONTR.

Roth & Morris

VAL \$ 17000

STORIES

ROOMS

APTS.

SIZE

LIGHT
SHAFTSELEVATOR
SHAFTSVENT
SHAFTSBOILER
ROOMSOWNER'S
INSPECTORSPRINKLER
SYSTEM

LATH

GAS
VENTSFIRE
ESCAPES

CHIMNEYS

STAND
PIPES

SKYLIGHTS

DATE.	CONDITION OF WORK—REMARKS
8/22/50	Poured without Insp. - Steel place incorrectly and of wrong size O.E.P.
9/21/50	Wall Steel & Bond Beam Insp. (West Wall) O.E.P.
9/26/50	" " " " " " (East ") "
10/4/50	Bond Beam Insp. (N.E.) O.E.P.
11/29/50	Frame Insp. O.E. Buckins
	<div style="display: flex; justify-content: space-between;"> COMPLETE AND O. K. INSPECTOR </div>