

4



CITY OF SACRAMENTO

DEPARTMENT OF ENGINEERING

1915 H STREET SACRAMENTO, CALIFORNIA 95814
CITY HALL ROOM 207 TELEPHONE (916) 449-5281

R. H. PARKER
CITY ENGINEER
J. F. VAROZZA
ASSISTANT CITY ENGINEER

September 29, 1980

RECEIVED
CITY CLERK'S OFFICE
CITY OF SACRAMENTO
SEP 29 10 28 AM '80

MEMORANDUM

TO: Lorraine Magana, City Clerk
FROM: R. H. Parker, City Engineer
SUBJECT: Water Main Installation in Folsom Boulevard
West of Hornet

The City Engineer requests that Item No. 4 be removed from the September 30, 1980, agenda, as it has been determined the work will not be done at this time.

M. H. Johnson
for R. H. PARKER
City Engineer

FILED
By the City Council
Office of the City Clerk

with drawn

RHP:rh

SEP 30 1980



CITY OF SACRAMENTO

CITY MANAGER'S OFFICE
RECEIVED
SEP 24 1980

HARRY G. BEHRENS
MANAGER
ROBERT W. JOHNSTON
ASSISTANT MANAGER

DIVISION OF WATER AND SEWERS
827 10TH ST.
SUITE #201
SACRAMENTO, CALIFORNIA 95814
TELEPHONE (916) 449-5271

September 24, 1980

City Council
Sacramento, California

Honorable Members in Session:

SUBJECT: Water Main Installation in Folsom Boulevard West of Hornet

SUMMARY

The Division of Water & Sewers has prepared plans and specifications for the subject project. It is recommended that the plans and specifications be approved and the project be advertised for bid.

BACKGROUND

Development of the water distribution system along Folsom Boulevard has proceeded in stages with individual developers installing portions of the system along their frontage. This has resulted in several "dead end" water mains along Folsom Boulevard. The current developer will pay his share of this project based on a front footage percent of the contract amount. Adjacent parcels in this case already have service from a separate distribution main and private wells. There is no further development anticipated for these parcels and no reasonable expectation of these owners participating in any distribution main extension in the near future. A recommendation of award will not be made until the developer pays the City for his share of the project (72% of the cost).

The proposed project will provide a new tie to a major water transmission main. This will eliminate the "dead end" main situation at this location, enhance the system reliability in the general area, and improve fire protection for the area.

FINANCIAL

Sufficient funds are available for this project in the Water Distribution Capital Improvements Budget, 4-13-3030-1510-4820. The Engineer's estimate for the project is \$25,500,000.

RECOMMENDATION

It is recommended that the Council approve the plans and specifications and that bids be received on October 21, 1980.

Respectfully submitted,
Harry G. Behrens
Harry G. Behrens
Manager

Recommendation approved
Walter J. Silpe
Walter J. Silpe
City Manager

September 30, 1980
District #6