

R 152 P

R 151 7.336

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD

\$19.00

TYPE BUILDINGS

PERMIT NO. E-8270	LOCATION 311 - Nimitz <i>A-6 A-7</i>			
DATE Sep 2-64	PURPOSE Const. foundation for dwlg. move-in	OWNER Emil Schock 2038 - Bell St.		
ZONE R-1	ARCH'T	CONT'R Owner Same 925-4185		
VAL. \$3,400.	STORIES	ROOMS	APTS.	SIZE
INSP.	DATE	BLDG. TYPE	OCCUPANCY GROUP	PHONE (O) (C)
FORM	<i>11-3-64</i>	<i>Barbato</i>		
JOIST				
FRAME				
SHEET ROCK				
FINAL	<i>5-13-65</i>	<i>Barbato</i>		

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
10-21-64	Pt Postings not deep enough <i>Callaway</i>
10-23-64	Pt Postings full of water Gravel not 12" into ground <i>Postings</i>
12-1-64	Red Tag. No let down inspection <i>Subst</i>
5-10-65	Pt Final - Remain a top SR in gauge. WH vent doesn't clear SR <i>Chapin</i>
	COMPLETE AND OK
	INSPECTOR