

897-769-75

Lot 175

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD 58.00

TYPE BUILDINGS

Greenhaven Sub. #1

PERMIT NO. E-790	LOCATION 788 Parklin Ave.	A-3
DATE Mar. 13, 62	PURPOSE Const dwelling and att. garage	
ZONE R-1	OWNER Norman J. Magee 5317-19th Ave.	
	ARCH'T	
	CONTR Bob. Guro 5001-44th Street. GL 7-5142	

VAL. \$17,000	STORIES 1	ROOMS 7	APTS. 441 Gar.	SIZE 1800
---------------	--------------	------------	-------------------	--------------

INSP.	DATE	INSPECTOR
FORM	<i>3-16-62</i>	<i>James</i>
JOIST	<i>3-30-62</i>	<i>James</i>
FRAME	<i>5-1-62</i>	<i>Conrad</i>
LATH	<i>5-18-62</i>	<i>James</i>
FINAL	<i>7/10/62</i>	<i>Geo. Pich</i>

DATE	SPECIAL CONDITIONS OF WORK—REMARKS
	<p>pt frame. Block center joint and 4 B. 7. 1/2 solid 1/4 x 5 screws full 1/10. Flat blocking galv. studs 1/4 in. distance. Ripped ceiling for new wiring. Block across ends of mullion 5. 1/2 missing in blocks where mullion removed. No 1 x 4 ends on c. joint No solid blocking end of 2 x 8 c. joint. Furling rods removed. No 8 in high cut around screen frame from ceiling close hallway? No end in gal. area.</p>
5-15-62	<p>pt. st. Do. joints must be made with #6's Covert</p>
COMPLETE AND OK	INSPECTOR