

AIRTEX

Job No: E-11

Area Served: rent apt.

Date: 5-5-00

Page: 3 of 7

Unit No: V4VE

Room	Opening			Factor	Design		Test 1		Test 2		Test 3	
	No.	Type	Size		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
	5	S	15" x 15"			235		230	235	340		
	6	S	12" x 12"			20		230	230	230		
	7	S	12" x 12"			235		270	280	295		
	8	S	12" x 12"			235		275	280	220		
					500	1450		85	1085	1085		

Remarks: _____

AIRTEX

Job No: B-1-4

Area Served: Southwest office

Date: 3/20/00

Page: 4 of 7

Unit No: VAV-6

4.03 5.351

Room	Opening			Factor	MIN Design		Test 1		Test 2		MIN Test 3	
	No.	Type	Size		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
	9	S	12x2			225	530	325	195	75	235	
	10	S	12x2			225	535	325	235	75	240	
	11	S	12x2			225	235	145	220	75	235	
	12	S	12x2			225	275	175	260	70	225	
T					300	900	1575	925	910	285	935	

Remarks: _____

AIRTEX

Job No: E-64

Area Served: Storage, EM, Player Lounge, etc. in front

Date: 3/2/00

Page: 7 of 7

Unit No: 14V-7

5.73 V.C 4.3 3.5

Room	Opening			Factor	Design		Test 1		Test 2		Test 3	
	No.	Type	Size		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
	19	S	10x10			100		70		125		110
	20	S	10x10			155		200		160		165
	21	S	10x10			155		175		155		155
	22	S	10x10			200		300		220		220
-						185	315		745		660	190 650

Remarks:

AIRTEX

Job No: Eng 2
 Date: 4/5/00

Area Served: Suite 175
 Page: _____ of _____

Unit No: AC-8

Room	Opening			Factor	Design		Test 1		Test 2		Test 3	
	No.	Type	Size		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
			2 1/2' x 11.11	12	1277							
			2 1/2' x 11.11	13.5	1289							
	TOTAL					2576						
	TOTAL					2576						

Remarks: 45°F in a Suite 175, 10,000 CFM, 5035
CFM 1200 for Suite 175 (OSA measured at unit
is 2776. OSA for Suite 175 is 1388

MEMORANDUM

SACRAMENTO FIRE DEPARTMENT

TO: BUILDING DEPARTMENT

DATE: 3-31-00

FROM: Troy Malaspino
Fire Marshal

SUBJECT: FIRE SYSTEM INSPECTION

A final inspection of the newly installed fire system at:

777 CAMAR'S COMMONS

has been conducted by Inspector LEAVITT

on 3-31-00

00-00802

Permit Number

61524

Square Footage

REMODEL

Type of Inspection

The system is acceptable by this department.

R Woodman

By: Ross L. Woodman,
Fire Prevention Officer II

TI-532

F. D. Reference Number