1231 I Street, Sacramento, CA 95814 Insp Area: Thos Bros: Site Address: 3524 JUMILLA WY SAC Sub-Type: **NSFR** RIVERVIEW 2-4B LOT 11 Housing (Y/N): Parcel No: **ARCHITECT CONTRACTOR OWNER** BEAZER HOMES 3009 DOUGLAS BL #150 ROSEVILLE CA 95661 Nature of Work: NSFR MP1346 1 STORY 6 RMS CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C). Lender's Name Lender's Address LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect. Date 9 0) License Number 724191 Contractor Signature OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the conflactors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00); I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.) I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law). I am exempt under Sec. B & PC for this reason: Date Owner Signature IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements. I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and herby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes. __ Applicant/Agent Signature WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations: I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued. I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for

Permit No:

0111678

CITY OF SACRAMENTO

_____(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date

Applicant Signature

Policy Number WA2-651-004147-080

Exp Date

04/01/2002

which this permit is issued. My workers' compensation insurance carrier and policy number are:

LIBERTY MUTUAL INS CO.

Carrier

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

New Construction ■ Property ■ New Construction ■ Property ■ New Construction ■ Property ☐ Addition ☐ Remodels ☐ Other Project Address: 3504 Jumilla Way Assessor Parcel # OWNER INFORMATION: The Age of the Control Legal Property Owner: Beazer Homes Holdings Corp. Phone # 916-773-3888 Owner Address: 3009 Douglas Blvd. 150 CityRoseville State CA Zip 95661 CONTRACTOR INFORMATION: Contractor: Same as above Lic. # B724191 Phone # 773-3888 Fax#/73-0425 PROJECT INFORMATION: Land Use Zone Occupancy Group _____ Construction Type ____ Fed Code _____ No. of stories: / No. of rooms: Street width: Roof Material 14 Floor Area /323 2nd Floor Area & Basement EXISTING AREA IN SQUARE FOOT OF: NEW Dwelling/Living Garage/Storage Decks/Balconies Carports SCOPE OF WORK: Single Family Homes FOR OFFICE USE ONLY ☐ Information above complete AR Flood Waiver required O Planning Approval ☐ Violation files checked ☐ Flood Elevation Certificate Required ☐ Design Review Approval O Standard setbacks ☐ Water Development Infill Area ☐ Special Fee Districts Apply:_____ ☐ County Sewer **NEW STRUCTURES & ADDITIONS** THE FOLLOWING MUST BE PROVIDED IN ORDER TO SUBMIT FOR PLAN REVIEW □ 2 COMPLETE PLANS, LEGIBLE & DRAWN TO SCALE → Plans to include: site plan, floor plan, elevations. roof/chiling plan, foundation and structural framing O 3 SETS IF PROJECT IS IN A DESIGN REVIEW AREA details, and structural calculations for nonconforming structures. Title 24 Energy Compliance documentation 11" x 17" capy of floor plan for County Assessor Grading and Erosion Control Questionnaire O Plan Review Fees Received by: (staff) Date: _ ACTIVITY/PERMIT

residentlalapp (rev 3/09/99)

RESIDENTIAL BUILDING PERMIT APPLICATION

KwikKote

Stucco System

Installation Card

Job Name: CLASSIC COLLECTION/RIVERVIEW

Address: 3524 JUMILLA WAY

SACRAMENTO, CA

Lot #: 0004011

Stucco System Trade Name: KWIK KOTE

Stucco System Manufacturer: KWIK KOTE CORP.

ICBO Evaluation Service, Inc.

Report No. 3607

Date of Job Completion: / 15-02

Home Builder: BEAZER HOMES

Address: 3009 DOUGLAS BLVD #150

ROSEVILLE, CA

Stucco Contractor: KENYON PLASTERING, INC.

Address: PO BOX 2077

North Highlands, CA

Telephone Number: 916/349-8191

Approved Contractor Number as

issued by the Stucco Manufacturer: 1001

Card Print Date: 10/05/2001

This is to certify that the stucco system on the building exterior at the above address had been installed in accordance with the evaluation report specified above and the manufacturer's instructions.

Signature of authorized representative of stucyo contractor

7-2-01

Date

CERTIFICATION OF INSULATION

| SPHONESS OF TRACT | 《美国传》中,中国的经 | | | | |
|--|--|---|--|--|-----------------|
| | LOT# | P.O. BOX 854, WE | P.O. BOX 854, WEST SACRAMENTO, CA 95691 LIC: #202026 | | |
| BENZER LOT 4011 | | 1309 MELODY ROAD, MARYSVILLE, CA 95901 LIC. #202026 | | | |
| 2 | P.O. BOX 9651, FRESNO, CA 93793-9651 LIC. #202026 P.O. BOX 1631, RENO, NV 89505 LIC. #10675 | | | | |
| 3524 Junilla | | 3326 A PONDEROSA WAY, LAS VEGAS, NV 89118 LIC. #10675 | | | |
| CL1551C5 | | DATE INSULATION COMPLETED | | | |
| CL1551C5 | | | | | |
| WALES | CER | INGS | F | LOORS | |
| (SQUARE FEET) | (| SQUARE FEET) | | SQUARE | FEET) |
| MATERIAL TO THE RESIDENCE OF THE PARTY OF TH | MATERIAL | | MATERIAL | | |
| FIBERGLASS | FIBER | GLASS | FORM | RGLASS | |
| BATTS | BATTS & BLOW | | BATTS | | |
| MANUFACTURER'S PRODUCT LD | MANUFACTURER'S PRODUCT I.D. | | MANUFACTURER'S PRODUCT I.D. | | |
| | | | Company of the second s | A CONTRACTOR OF THE BOOK OF THE BOOK OF THE CONTRACTOR OF THE CONT | |
| OCF | OCF | | OCF | | |
| | BAGS | ri, | | | |
| | The state of the s | 10 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 | | Company of the compan | 7 7 1 1 5 7 7 9 |
| | 34 | | | | |
| \ \ \ \ \ 3°\%' | 30 | 2 | | | |
| | | | | | |
| MATERIAL FORM FIBERGLASS | BATTS | RVALUE | MANUFA | OCF | e transfer |
| | A SELECTION OF SECURITY OF SEC | | | | |
| MATERIAL | The state of the s | MANUFACTURER | | 25. 22. 28 may 1 | |
| FOAM | | <u>.</u> | W R GRACE | | |
| | | ALI ELMETER | | Maria Company | |
| SIGNATURE—INSULATION CONTRACTOR | TITLE MANAGE | | DATE | | |
| SIGNATURE -GENERAL CONTACTOR | TITLE | | DATE | DATE 1226-01 | |
| REMARKS | | | | | |
| enemethy). | | | | e de la companya de La companya de la co | |
| | | | Astronomic Control | | |
| | | | | | |
| | . And the second second | | | | |
| | . 11 | | | | |
| | | • | | | |



Scheel

Structural

Engineer

Sacramento 5022 Sunrise Blvd. Fair Oaks, CA 95628 (916) 536-9585 (916) 536-0260 (fixx)

NORMAN SCHEEL Structural Engineer Email: norm@nssc.com

Project Manager Email: paulo@nsse.com

TIM SLOAN, P.E. Project Manager Email: htm@nssc.com

STEVE COOKSEY
CAD Supervisor
Email: steys@nssc.com

STACY MARLIN Office Manager Email: stacy@nsse.com

Davis 213 E Street Suite B Davis, CA 95616 (530)753-5300 (530)753-5380(fax)

TRACY HARRIS, P.E.
Project Manager
Email: tracy@nssedavis.com

DARRELL PEREIRA
Design Engineer
Emancel@nsscdavis.com

November 8, 2001

Beazer Homes 3009 Douglas Blvd. Suite 150 Roseville, CA 95661

RE: Classic Collections - Plan 1323B (Job #20311) Inspection Clarification for Trusses

To Whom It May Concern:


This letter is to clarify that it appears that the Truss Manufacturer's intent is to have the M1 truss supported at the entry wall and the A5 truss. In our opinion, the M1 truss does not require any kind of footing or thickened slab.

If you have any questions please call Rob Coon.

NORMAN SCHEEL

STRUCTURAL ENGINEER





-UTILITY SERVICE BOX

PLOT PLAN LOT 11 RIVER VIEW #2 VILLAGE 4B BEAZER HOMES CALIFORNIA CITY OF SACRAMENTO RODGERS INC. WOOD

AUG 200

maz

1055.015