

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

Hickman Plk TYPE VII BUILDINGS

| | | | |
|--------------------------|--|--|------------------------------|
| PERMIT NO. 377 | LOCATION <i>Lot 3 Blk I ^{unit} 215</i> | 2440 Street No | |
| DATE | PURPOSE <i>2nd Garage</i> | ROOMS <i>5</i> | APTS. <i>1</i> |
| ISSUED | OWNER <i>H. Dowell</i> | PHONE <i>M. 116</i> | |
| | ARCH'T | <i>2757 Santa Cruz</i> | |
| ZONE MAY 7 - 1917 | CONT'D | <i>John Keiser 3424 San Francisco Ave.</i> | |
| SACRAMENTO | TOWNSHIP | STORIES <i>2300 - 1</i> | SIZE <i>42 x 26 - 17'</i> |

| FOUNDATION | STORY | BSMT | 1 | 2 | 3 | ROOF | | | |
|---|-------------------------|------|---|---|---|------|------------------|--|---------------|
| Ex Wall <i>Concrete</i> <i>15 x 4 Posts</i> <i>6 x 8 Posts</i> Int Wall | Joists | | | | | | Chimneys | | Cement Tests |
| | Beams and Girders | | | | | | Fire Place | | |
| | Studs and Columns | | | | | | Gas Water Heater | | |
| | Bridging Fire Stops | | | | | | Heater Closet | | |
| Piers <i>15 x 15</i> <i>2 Rows</i> | Fire Escape Stand Pipes | | | | | | Furnace | | Window Courts |
| | Metal Lath | | | | | | Boiler Room | | |
| | Stairs | | | | | | Elevator Shaft | | |

DATE

CONDITION OF WORK--REMARKS

5/11/27

1ST / NSP. FORMS. O.K. A. W. Campbell

6/1/27

2ND / NSP. FRAME. O.K. A. W. Campbell

6/11/27

3RD / NSP. LATH ^{INTERIOR} Rustic Exterior O.K. A. W. Campbell

6/20/27

3RD / NSP. ^{Notified Court} to install concrete walls at back end of house for earth fill.
A. W. Campbell

COMPLETED
AND O. K.

Inspector

