

**CITY OF SACRAMENTO**  
1231 I Street, Sacramento, CA 95814

**Permit No: 0005617**  
**Insp Area: 1**

**Site Address: 517 U ST SAC**  
Parcel No: 009-0115-017

**Sub-Type: HSG**  
**Housing (Y/N): Y**

CONTRACTOR

OWNER  
TASNO TAKEGOSHI M D INC PE  
141 DAWN RIVER WY  
FOLSOM CA 95630

ARCHITECT

**Nature of Work: REPAIRS PER HOUSING CHECKLIST**

**CONSTRUCTION LENDING AGENCY :** I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).


Lender's Name \_\_\_\_\_ Lender's Address \_\_\_\_\_


**LICENSED CONTRACTORS DECLARATION:** I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.



License Class \_\_\_\_\_ License Number \_\_\_\_\_ Date \_\_\_\_\_ Contractor Signature \_\_\_\_\_

**OWNER-BUILDER DECLARATION:** I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00):

\_\_\_\_\_, I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)



 as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. \_\_\_\_\_ B & PC for this reason: 

Date  Owner Signature  24-5-2000

**IN ISSUING THIS BUILDING PERMIT,** the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date  24-5-2000 Applicant/Agent Signature 

**WORKER'S COMPENSATION DECLARATION:** I hereby affirm under penalty of perjury one of the following declarations:

\_\_\_\_\_, I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier \_\_\_\_\_ Policy Number \_\_\_\_\_ Exp Date \_\_\_\_\_

\_\_\_\_\_, (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date  24-5-2000 Applicant Signature 

**WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.**

**THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.**

Housing/Dangerous Bldgs Division  
Case Field Check List

Case # **HSG9901438**

Address: **517 U ST**

Location:

0005617H

<u>Date</u>	<u>Description</u>
09/15/99	<b>49.10.1002(12) Infestation of insects, vermin or rodents.</b>  RODENT INFESTATION
09/15/99	<b>49.10.1002(13) General dilapidation or improper maintenance of the building.)</b>  DRYROT AT FRONT AND REAR
09/15/99	<b>49.10.1003(2) Defective or deteriorated flooring or floor supports.</b>  LAUNDRY PORCH
09/15/99	<b>49.10.1008(20) Deteriorated or ineffective waterproofing of exterior walls, roof, foundation or floors including broken windows or doors.</b>  THROUGHT STRUCTURE
09/15/99	<b>Design Review requirements required.</b>
09/15/99	<b>49.07.702 Exposed conductors, wire joints or energized equipment.</b>  EXPOSED ELECTRICAL OUTLETS AND CEILING FIXTURES BOXES
09/15/99	<b>49.07.702 Inadequate working or otherwise required clearances.</b>  NO WORKING CLEARANCE AT SERVICE PANELS
09/15/99	<b>49.07.701 Provide approved type and installation of room heater which will maintain a temperature of 70 degrees three(3) feet above the floor.</b>  PROVIDE WORKING HEATERS

Housing/Dangerous Bldgs Divis.

Case Field Check List

Case # **HSG9901438**

Address: **517 U ST**

Location:

<u>Date</u>	<u>Description</u>
09/15/99	<b>49.05.521 Provide approved method for installation, and/or maintenance of DWV system (drain, waste, and venting).</b>  DRAIN AND WASTE SYSTEM , NOT DRAINING
09/15/99	<b>49.10.1006 Provide approved method and materials for installation of gas piping system.</b>  EXTERIOR GAS LINE ATTACHED TO FAILING STUCTURAL SUPPORT.
09/15/99	<b>Other requirements.</b>  THIS WAS NOT A COMPLETE INSPECTION. A COMPLETE INSPECTION OF THIS BUILDING AND ALL BUILDINGS ON THIS PARCEL WILL BE PROVIDED WHEN A WALK THROUGH IS COMPLETED WITH THE OWNER OR THE OWNER'S REPRESENTATIVE. A COMPLETE TERMITE REPORT IS REQUIRED