

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT No. A-1194	LOCATION 501 - Pico Way.
DATE 11/23/39	PURPOSE To Erect 1-6 Rm. Frame & Stucco Dwelling
ZONE 2-Fam	OWNER and garage Edgar H. Fletcher
	ARCH'T Roy Hess.
	CONT-R

VAL. 5000⁰⁰	STORIES 1 1/2	ROOMS	APTS.	SIZE See plans.
-------------------------------	-------------------------	-------	-------	---------------------------

Light Shafts		Elevator Shafts	
Vent Shafts		Boiler Rooms	
Owner's Inspector		Sprinkler System	
Lath		Gas Vents	
Fire Escapes		Chimneys	
Stand Pipes		Skylights	

DATE	CONDITION OF WORK—REMARKS
11/29/33	1 ST INSP. Basement Forms & Footings for Ext. Walls O.K. A.W. Campbell
12/1/33	1 ST INSP EXT WALL FORMS & PIERS O.K. A.W. Campbell
12/20/33	2 ND INSP. Frame in place O.K. A.W. Campbell
12/26/33	3 RD INSP. EXT. LATH 18 gauge wire used, 2" x 2" - 16 gauge. O.K. A.W. Campbell
12/29/33	3 RD INSP. INT. LATH IN PLACE O.K. A.W. Campbell
3/5/34	4 TH INSP. Dwg & Garage Completed O.K. A.W. Campbell Issued Certificate of Occupancy
	Streets Cleaned up O.K.
3/5/34	COMPLETE AND O.K. <i>Adwin H. Campbell</i> INSPECTOR