

A 207, F 621-622

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD \$22.

TYPE BUILDINGS

PERMIT NO.					
F-6073 -		LOCATION 2060 - Railroad Dr.		A-6	
DATE		PURPOSE Alterations to whse as wood-working area			
Dec. 16-66		OWNER M. Oats. & Benvenuti			
ZONE		ARCH'T			
M-1		CONTR Tennant		same	
VAL \$5,000.		STORIES	ROOMS	APTS.	SIZE
INSP.	DATE	BLDG. TYPE	Sprink. III No-Hr	OCCUPANCY GROUP	None (O) (C) 11,200 sq. ft
FORM					
JOIST					
FRAME					
SHEET ROCK					
FINAL					<i>ent</i>

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
12/22/66	OK to S.P. Walls. Stairway to Balcony does not comply. Calloway
1-7-67	Final - many corrections
1-18-67	Frame - P.T. studs must be 16" O.C. 5/8 S.P. required. P.S.
COMPLETE AND OK	INSPECTOR